

Maintenance Form - Section 2.45.3

General Information

Section: 2.45.3

Equipment/System: Audible & Visual Escape

Inspector: A

Date: 2026-02-22

Drawing Reference:

Locations: WESTBOUND BORE, COUNTY HALL, SUMP PUMPING STATION

Frequencies: 6 WEEKLY, 3 MONTHLY, 6 MONTHLY, ANNUALLY

Tasks Performed

☒ Carry out visual inspection of chaser lighting at each Emergency door position and check for damage.
Carry out repair / replacement to damaged units as necessary.

☐ Manually operate the system at each door position. Ensure that:
Each arrow functions and is sequential.
Strobe lighting on sign operates and sign is illuminated.
Audible sound and white noise alert are operational

☐ Replace any defective components necessary to bring the system back into full service.

☐ Inspect control panel for signs of water ingress and security of all connections and components.

☐ Operate door from EPCMS and log door checked.

Approval

Engineer: D (D)
Date: 2026-02-22

Supervisor: A (A)
Date: 2026-02-22