

# Maintenance Form - Section 2.45.3

## General Information

**Section:** 2.45.3

**Equipment/System:** Audible & Visual Escape

**Inspector:**

**Date:** 2026-02-22

**Drawing Reference:**

**Locations:** WESTBOUND BORE, COUNTY HALL, SUMP PUMPING STATION

**Frequencies:** 6 WEEKLY, 3 MONTHLY, 6 MONTHLY, ANNUALLY

## Tasks Performed

☐ Carry out visual inspection of chaser lighting at each Emergency door position and check for damage.

Carry out repair / replacement to damaged units as necessary.

☐ Manually operate the system at each door position. Ensure that:

Each arrow functions and is sequential.

Strobe lighting on sign operates and sign is illuminated.

Audible sound and white noise alert are operational

☐ Replace any defective components necessary to bring the system back into full service.

☐ Inspect control panel for signs of water ingress and security of all connections and components.

☐ Operate door from EPCMS and log door checked.

## Approval

**Engineer:**

Date: 2026-02-22

**Supervisor:**

Date: 2026-02-22

Generated: 22/02/2026 01:05:04