



Maintenance Form - Section 2.45.1

General Information

Section: 2.45.1

Equipment/System: Audible & Visual Escape

Inspector: Engineer Tester

Date: 2026-03-04

Drawing Reference:

Locations: EASTBOUND BORE, COUNTY HALL, SUMP PUMPING STATION

Frequencies: 6 MONTHLY

Tasks Performed

☒ Carry out visual inspection of chaser lighting at each Emergency door position and check for damage.

Carry out repair / replacement to damaged units as necessary.

☒ Manually operate the system at each door position. Ensure that:

Each arrow functions and is sequential.

Strobe lighting on sign operates and sign is illuminated.

Audible sound and white noise alert are operational

☒ Replace any defective components necessary to bring the system back into full service.

☐ Inspect control panel for signs of water ingress and security of all connections and components.

☐ Operate door from EPCMS and log door checked.

Approval

Engineer: Engineer Tester (ET)

Date: 2026-03-04

Supervisor:

Date: 2026-03-04

Generated: 04/03/2026 11:40:30