

Revit MEP Setup Checklist

LUA BIM LABS Starter - Track 2 Quick Reference | Track completion card - Day 14

Project Setup Checklist

Levels and Grids

- [v] Levels are copied or monitored from the architectural/structural model - not created independently
- [v] Floor-to-floor heights verified against the architectural model
- [v] Level names match the project naming convention (e.g., L01, B1, RF)
- [v] Structural grids are visible in MEP plan views for spatial reference

Shared Coordinates

- [v] Architectural model is linked into the MEP model
- [v] Shared coordinates acquired from the architectural model
- [v] Survey point and project base point confirmed - not moved by the MEP team
- [v] All discipline models (HVAC, piping, electrical) align to the same shared coordinate base

Worksets

- [v] Worksets created per discipline or system (e.g., HVAC, Plumbing, Electrical, Linked Models)
- [v] Each workset assigned to a responsible team member or role
- [v] Central file saved to the project CDE - not a local desktop folder
- [v] All modelers working from local copies, not the central file directly

Linked Models

- [v] Architectural model linked and pinned
- [v] Structural model linked and pinned
- [v] Other MEP discipline models linked for coordination reference
- [v] All link paths verified (not broken) before modeling starts

Discipline-Specific Settings

- [v] Correct Revit MEP template selected (Mechanical, Electrical, or Plumbing)
- [v] View discipline filter set to the correct MEP system per view
- [v] View range set to capture the ceiling MEP zone (cut height and bottom offset confirmed)
- [v] Linked model visibility set to Halftone so MEP elements are visually distinct

System Naming Conventions

Element	Example Format	Notes
File name	`[Project]-[Disc]-[Level]-[Author]-[Date].rvt`	e.g., `PRJ-MECH-ALL-LUA-20260529.rvt`
System name	`HVAC-SA-L03`	HVAC, Supply Air, Level 3
Equipment tag	`AHU-01-L03`	Air Handling Unit 01, Level 3
Plan view	`MEP-MECH-L03-PLAN`	MEP, Mechanical, Level 3, Plan
Coordination view	`3D-COORD-ZONE-A`	Zone A coordination 3D view

Template Verification Items

Before modeling begins, verify:

- [v] Correct MEP template is active (check File > Project Information)
- [v] System types exist for all required systems (Supply Air, Return Air, Chilled Water Supply, etc.)
- [v] Family library path is accessible and project-specific families are loaded

- [v] Revision table and title block are set up on sheet templates
- [v] View templates for each discipline are created and applied