

SQ1 – Valve Box, conditioning He circuits

Sensors and actuators used:

- Pressure: PT580
- Valve: FV090, FV091NO, FV092, FV600, FV601, FV602, FV640, FV641, FV642, FV643, Switch valves
- Control valve: CV600, CV601, CV602, CV603, CV580, CV590, CV-He-liquefier, CV644
- Purging system: vacuum pump P090

The user chooses:

- Number of cleaning cycle: Nb cycle
- Delay: tstarting, tvac1, tvac2, tp1, tp2
- Mode: Vacuum, Liquid or Magnet
- Pressure: Pvac, PvacMax, P He, P He min

Initial conditions:

- Sequences from 5 to 20 stopped

