Sensors and actuators used:

- Pressure: PT660, PT661, PT584
- Valve: FV581, FV582, FV584, FV554, FV555, FV556
- Control valve: CV581, CV582
- Level: LT682, LT683Cryostat-2K: Boolean

The user chooses:

- Level: LT683mini
- Pressure: PT660setpoint, PT584setpoint
- Control valve: CV581%opening

Initial conditions:

- Magnet insert selected
- Sequences from 1 to 3 stopped
- Sequences 15 and 16 stopped
- Sequence 8 in operation

