Sensors and actuators used:

- Pressure: PT660- Flow rate: FT581- Valve: FV642, FV643- Control valve: CV602, CV581

- Level: LI660 (LT660+LT661), LI670 (LT670+LT671)

The user chooses:

- Level: LI660setpoint, LI660mini, LI660Maxi, LI670setpoint, LI670mini, LI670Maxi

- Pressure: PT660setpoint (Patmospheric<P<1.5 bar)

- Flow: FT581limit

- Control valve: CV602%opening, CV581%opening

- Mode: regulation or intermittent

Initial conditions:

- Liquid or Vacuum insert selected
- Sequences from 1 to 3 stopped
- Sequences 10 and 13 stopped
- Sequence 8 in operation

Vacuum mode



