

Sensors and actuators used:

- Temperature: TT370, TT371, TT372
- Flow rate: FT380
- Valve: FV381, FV382
- Control valve: CV380
- Heater: EH370
- Compressor

The user chooses:

- Temperature: TT370L, TT370H, TT371setpoint, TT372setpoint
- Flow: FT380setpoint
- Control valve: CV380%opening
- Delay: tc1, tc2
- Mode: InletTemp (TT372) or OutletTemp (TT371) or Flow regulation (FT380)

Initial conditions:

- Sequence 3 stopped

