## SQ6 - Cryostat thermal shield cooling

## Sensors and actuators used:

- Temperature: TT740, TT744, TT745, TT747, TT748, TT749, TT750, TT752, TT753, TT754, TT755

- Valve: EV740, EV744, EV748

- Control valve: CV740

- Heater: EH740, EH744, EH748

## The user chooses:

- Temperature: TT740H, TT740L, TT740C, TT740W, TT744L, TT744H, TT744C, TT744W, TT745L, TT745H, TT747L, TT747H, TT748L, TT748H, TT748C, TT748W, TT750L, TT750H

- Control valve: CV740% opening

## **Initial conditions:**

- Liquid or Magnet insert selected
- Sequences 2 & 3 stopped
- Sequence 22 stopped



