

# Fresh Start Projects

## Safe Work Method Statement (SWMS)

### Organisational Details

Business Undertaking the Work:	<input type="text" value="Fresh Start Projects"/>	ABN:	<input type="text" value="98 765 432 109"/>
Business Address:	<input type="text" value="lala"/>	Business Phone #:	<input type="text" value="98 765 432 109"/>

### Project and Principal Contractor Details

Scope of the Work:	<input type="text" value="New residential building construction"/>		
Project Address:	<input type="text" value="lala"/>	Principal Contractor:	<input type="text" value="98 765 432 109"/>

### SWMS | JSEA Details

Developed By:	<input type="text" value="Fresh Start Projects"/>	Contact #:	<input type="text" value="98 765 432 109"/>
Date Developed:	<input type="text"/>	Email:	<input type="text" value="ryan.slater@droneanalytics.com.au"/>
Approved for Use By:	<input type="text" value="Jane Smith"/>	Contact #:	<input type="text" value="ryan.slater@droneanalytics.com.au"/>
Approval Date:	<input type="text"/>	Signature:	<input type="text" value="ryan.slater@droneanalytics.com.au"/>
Date Last Reviewed:	<input type="text"/>	Reviewed & Approved for Use by::	<input type="text" value="ryan.slater@droneanalytics.com.au"/>
Signature:	<input type="text" value="ryan.slater@droneanalytics.com.au"/>	Next Review Date:	<input type="text"/>

Monitoring and Review: Visual monitoring of control measures will be undertaken and reviewed if circumstances change. The SWMS | JSEA will be amended if there is a change in the activity.

Consultation: Relevant personnel (including HSR's where established) have been consulted in the development, and where required, review and amending of this SWMS | JSEA.

No	Task   Activity	Potential Hazards	Risk Scores (before)	Control Measures	Risk Score (After)	Responsible Person
2 General Construction						
2.1	<ul style="list-style-type: none"><li>• Use of hand and power tools</li></ul>	<ul style="list-style-type: none"><li>• Electrocutation</li><li>• Cuts and abrasions</li><li>• Eye and hearing damage</li></ul>	1	<ul style="list-style-type: none"><li>• Safety Glasses, Ear Protection and RCD.</li><li>• All Electrical leads and tools will be tested and tagged every 3 months in accordance with AS/NZS 3012:2010. A test register will also be available for inspection</li><li>• Guards on tools and equipment will be maintained and working effectively before being used on site.</li><li>• Guarding on tools will not be removed to perform any work activity.</li></ul>	4	Ryan