

TEST CERTIFICATE OF POWER TRANSFORMER			
Client		Tested On	
Plant		Tested By	
Location		Comp. Code	

1.0 NAME PLATE DETAILS :

Make		Vector Group	
Serial No.		% Impedance	
Rating in MVA		Tap Changer	
Voltage Ratio		No. Of Taps	
Type of Cooling			

2.0 INSULATION RESISTANCE TEST :

Megger Used : 5 KV
Range : M-Ω

H. V. - E	L. V. - E	H. V. - L. V.

3.0 VOLTAGE RATIO & TAP CONTINUITY TEST :

Measured voltage on LV Side								
Tap Position	Applied Voltage	r-y	y-b	b-r	r-n	y-n	b-n	Tap continuity
01	R-Y							
02	Y-B							
03	B-R							
04								
05								
06								
07								

4.0 MAGNETIC BALANCE TEST :

Supply Voltage (HV Side)	Voltage Measured (LV Side)		
	r - n	y - n	b - n
R - Y			
Y - B			
B - R			

5.0 VECTOR GROUP TEST :

Short 1R-2R and apply 440V on HT side.

Measured Voltage : RY-, YB-, BR-

1R-2R		1Y-2R		1B-2R	
1R-2Y		1Y-2Y		1B-2Y	
1R-2B		1Y-2B		1B-2B	
1RN		1YN		1BN	
2RN		2YN		2BN	

6.0 CONFORMITY TESTS :

1	Visual External damage to any part of the transformer	
2	Colour of silica jell / oil level in bottom seal/Leakage if any	
3	Proper Connections of body and neutral earthing	
4	Buchholz relay test for alarm/trip contact float operations	
5	Winding/oil temperature indicator alarm/trip contact operations	
6	MOG float switch contact operation	
7	Local / remote operations of OLTC	
8	Cooling System and Oil Circulation System Check a) ONAN System b) ONAF System c) OFAF System	

7.0 REMARKS :