

VCB (VACUUM CIRCUIT BREAKER) MAINTENANCE CHECK LIST			
CLIENT		DATE	
LOCATION		PANEL NO.	
MAKE & TYPE		VCB SR. NO.	
FEEDER		VCB AMP	
VCB VOLTAGE		VCB KA	
SWITCH BOARD		SERVICE BY	

Sr. No.	WORK DESCRIPTION METHOD OF CHECKING	Result
1	Visual Inspection of Breaker.	
2	Through Cleaning of the Breaker with CRC, removal of old grease & apply new Grease	
3	Lubrication of all moving parts and mechanism	
4	Checking of Closing and Tripping coil	
5	Checking of Test/Service Aux. Switch Operation	
6	Checking of hardware and it's tightness and circlips	
7	Checking of Closing and tripping Mechanism Operation	
8	Checking of condition & alignment of Jaw Contacts	
9	Breaker Aux. Switch Operation	
10	Checking of Front drive Key operation in Test and Service	
11	Checking of Closing Coil Resistance.	
12	Checking of Tripping Coil Resistance.	
13	Checking of Motor Coil Resistance.	
14	Checking of K1 (Anti Pumping Contactor) Resistance	
15	Checking of Roller Gap By Gauge-V0ernier	
16	Checking of Damper Gap By Gauge-Vernier	
17	Tightness of Power Connection and VCB wiring	
18	Checking of Scraping Earth Alignment	
19	Checking of Breaker ON/OFF operations in Test & Service Position	
20	Checking of Torque Contact Arm & VI Fixing (NM)	
21	Checking of Counter Reading	

1.0 Timing Test Report (All value in Mili Seconds) :

Phase	Closing Time	Tripping Time
R		
Y		
B		

2.0 Contact resistance (All Value in Micro Ohm) :

R - PHASE	Y-PHASE	B-PHASE

3.0 VI Details :

4.0 IR Test :

Phase to Earth (close condition)	Value in Ω	Phase to Phase	Value in Ω	Open Cond. Top-Bottom	Value in Ω
RE		RY		RR	
YE		YB		YY	
BE		BR		BB	

Remark:-