FOUNDATION PLAN SCALE: 16" = 1'-0"

1. SLAB ON GRADE TO BE 6" MIN THICK, 4,000 P.S.I. CONCRETE REINF 6 × 6 × W
2.9 × W 2.9 WWM AND 1.5 POUNDS PER C.YD. OF FIBER MESH OVER 6 MIL VAPOR BARRIER AND 4" MIN DEEP STONE BASE.

21'-3"

21'-3"

21'-3"

21'-3"

21'-3"

21'-3"

21'-3"

21'-3"

- 2. MODULUS OF SUBGRADE SHALL BE VERIFIED TO BE A MINIMUM OF 180 P.C.I.
- 3. ELEVATION TOP OF SLAB = 189.00'

21'-3"

20'-0"

20'-0"

22'-101/4"

21'-3"

21'-3"

21'-3"

21'-3"

21'-3"

4. ELEVATION TOP OF FOOTINGS NOTED (XX.XX') IN PLAN.

FOOTING SCHEDULE		
MARK	SIZE	REINFORCING
F50	5'-0" × 5'-0" × 1'-0"	6-#6 EACH WAY BOTT.
F66	6'-6" × 6'-6" × 2'-0"	7-#7 EACH WAY BOTT.
F75	7-6" × 7'-6" × 1'-4"	8-#7 EACH WAY BOTT.



NEW BUILDING AT HILLSIDE BUSINESS 7020 DORSEY ROA ANNE ARUNDEL CO

No. Description Date Revisions

Sheetommercial review AA CO. - PAC

**S-1** 

Proj. No.

Date

Scale

Last Rev.

© COPYRIGHT 2005, DUNLAP ENGINEERING, INC. DEI # : 205011