



FOOTING SCHEDULE		
MARK	SIZE	REINFORCING
F56	5'-6" x 5'-6" x 2'-0"	6-#6 EACH WAY BOTT.
F10	7'-0" x 7'-0" x 1'-4"	8-#6 EACH WAY BOTT.
F85	8'-6" x 8'-6" x 1'-6"	9-#7 EACH WAY BOTT.

FOUNDATION PLAN ~ 1/8" = 1'-0"

1. SLAB ON GRADE TO BE 6" MIN THICK, 4000 P.S.I. CONCRETE, REINF. 6 x 6 x 102.4 x 102.4 W/M, OVER 6 MIL VAPOR BARRIER AND 5" MIN. DEEP STONE BASE.
2. MODULUS OF SUBGRADE SHALL BE VERIFIED TO BE A MINIMUM OF 180 P.C.I.
3. ELEVATION TOP OF SLAB ON GRADE TO BE EL= 41.50'
4. ELEVATION TOP OF FOOTINGS NOTED (00.00') IN PLAN.