Guangzhou Building Materials Institute Limited Company

Test Report

GML-V020

Client: DONGGUAN TECH FREE AIR CONDITIONING MFY, LTD.

Laboratory: （Stamp）

Project Name: ---

Position of Construction: ---

Report No: V03-1800173（E）

Test Standard: BS EN 13501-1：2007+A1：2009

Sample Number: 1V031800207

Supervision: ---

Type of Test: Sample delivered by client

Date Received: 2018-07-17

Date Tested: 2018-07-27

Date of Issue: 2018-07-30

Sample Information					
Sample Name	EPDM rubber gusset strip	Sample Type	M03-42X04-1/29×19(8&6)mm E-d2	Sample Number	1 m^2
Productor	Hebei Cuishi rubber and plastic products Technology Co., Ltd			Date Product	---

Test Information						
Test Items	Measure Unit	Test Standard	Technical Requirement		Test Results	Individual Judgment
Fs	mm	ISO 11925-2:2010	E	≤150	37	Compliant
Whether the filter paper is ignited in 20s	---	ISO 11925-2:2010		NO	NO	Compliant
ISO 11925-2:2010 Specimen photos before and after the test see the next page						
Conclusion	The inspected items are satisfied the technical requirements of BS EN 13501-1：2007+A1：2009 about class E.					
Remark	Brand: Hebei cuishi					

Laboratory address: No.2, Keyan Road, Guangzhou, Guangdong, China

A000

1WT031804559

Certified by:

Checked by:

Tested by: 高世杰

Guangzhou Building Materials Institute Limited Company
Test Report (Continue)

Report No: V03-1800173（E）

Specimen photos before and after the test

Before the test

After the test