

MECHANICAL EQUIPMENT SCHEDULE — CENTRAL PLANT

Project: synthetic example · Drawing: M-201 · Per ASHRAE 90.1-2019

Tag	Type	Capacity	GPM	EWT/LWT	Pressure	kW	COP/EER
CH-1	Centrifugal Chiller	500 tons	1200	55/45 °F	—	275	0.55 kW/ton
CH-2	Centrifugal Chiller	500 tons	1200	55/45 °F	—	275	0.55 kW/ton
B-1	Condensing Boiler	2000 MBH	200	140/180 °F	60 psig	—	95 %
B-2	Condensing Boiler	2000 MBH	200	140/180 °F	60 psig	—	95 %
CHWP-1	Chilled Water Pump	—	1200	—	100 ft	50	—
CHWP-2	Chilled Water Pump	—	1200	—	100 ft	50	—
HWP-1	Hot Water Pump	—	200	—	80 ft	15	—
HWP-2	Hot Water Pump	—	200	—	80 ft	15	—
CT-1	Cooling Tower	500 tons	1500	85/95 °F	—	40	—
CT-2	Cooling Tower	500 tons	1500	85/95 °F	—	40	—
CWP-1	Condenser Water Pump	—	1500	—	60 ft	30	—
EXP-1	Expansion Tank	200 gal	—	—	30 psig	—	—