

Project 3

April 16, 2022

Gabe Morris

```
[1]: # Imports
import numpy as np
from scipy.optimize import fsolve
from msu_esd import Pipe
```

Contents

1	Given	3
1.1	Project 1 Overview	3
2	Find	5

1 Given

From Project 1, piping and pump requirements for a chilled fluid circulating system for a portion of the Orlando Airport were determined. A Z-network was used for the system, and the pumps head and flow rate requirements were found.

1.1 Project 1 Overview

From Project 1, the booster pump option was selected because it was more cost-efficient and offered more control over the system. The schematic is shown in Figure 1.




Figure 1: Booster Pump Schematic

The resulting head values are $b_2 = 67.65 \text{ ft}$, $b_4 = 101.95 \text{ ft}$, $b_7 = 55.7 \text{ ft}$, and $b_{10} = 44.9 \text{ ft}$. The main line pump has a head of $W_s = 145 \text{ ft}$. The summary of the piping lengths as well as material properties are given in Table 1.

Table 1: Summary of Piping

Pipe	L (ft)	D (in)	# Valves	# Elbows	K	C
1	2840	18.812	1	0	1.78	8
2	2380	10.02	1	5	5.53	8
3	1300	11.938	1	0	1.78	8
4	1630	10.02	1	5	5.53	8
5	3000	11.938	1	2	3.28	8
6	5000	11.938	1	2	3.28	8

Pipe	L (ft)	D (in)	# Valves	# Elbows	K	C
7	1580	11.938	1	0	1.78	8
8	1550	7.981	1	5	5.53	8
9	1550	7.981	1	7	7.03	8
10	5130	10.02	1	8	7.78	8
11	1875	11.938	1	1	2.53	8

Material: Galvanized Steel (Schedule 40)

Absolute Roughness: $\epsilon = 0.0005 \text{ ft}$

Working Fluid: Therminol D-12

Density: $\rho = 48.05 \frac{\text{lbm}}{\text{ft}^3}$

Heat Capacity: $c_p = 0.491 \frac{\text{Btu}}{\text{lbm}^\circ \text{F}}$

Viscosity: $\mu = 3.715 \frac{\text{lbm}}{\text{ft hr}}$

The system of equations using the Kirchhoff method is,

$$\left\{ \begin{array}{l} Q_1 = Q_3 + Q_2 \\ Q_3 = Q_4 + Q_5 \\ Q_6 = Q_2 + Q_4 \\ Q_5 = Q_7 + Q_{10} \\ Q_7 = Q_8 + Q_9 \\ Q_{11} = Q_6 + Q_7 \\ h_2 + K_1 Q_2 |Q_2| + h_6 + h_{11} + h_1 - 150 + 0.1 Q_1 |Q_1| - b_2 = 0 \\ h_4 + K_3 Q_4 |Q_4| - h_2 - K_1 Q_2 |Q_2| + h_3 + b_2 - b_4 = 0 \\ h_7 + h_8 + K_4 Q_8 |Q_8| - h_6 - h_4 - K_3 Q_4 |Q_4| + h_5 + b_4 - b_7 = 0 \\ h_9 + K_4 Q_9 |Q_9| - h_8 - K_4 Q_8 |Q_8| = 0 \\ h_{10} + K_2 Q_{10} |Q_{10}| - h_{11} - h_7 - h_9 - K_4 Q_9 |Q_9| + b_7 - b_{10} = 0 \end{array} \right.$$

The code block below outputs the flow rates for this system.

```
[2]: # Define known constants
K1, K2, K3, K4 = 4.5, 4.5, 4.5, 10 # Loss coefficients

rho = 48.05/32.174 # In slugs per cubic feet
mu = 3.715/(3600*32.174) # In slugs per (ft s) or lbf*s per ft squared
epsilon = 0.0005 # In ft

D20, D12, D10, D8 = np.array([18.812, 11.938, 10.02, 7.981])/12 # Diameters in_
↪ft

Ws = 145 # in ft

# Define pipe objects
p1 = Pipe(D20, 2840, epsilon, rho, mu, K=1.78, C=8)
p2 = Pipe(D10, 2380, epsilon, rho, mu, K=5.53, C=8)
```

```

p3 = Pipe(D12, 1300, epsilon, rho, mu, K=1.78, C=8)
p4 = Pipe(D10, 1630, epsilon, rho, mu, K=5.53, C=8)
p5 = Pipe(D12, 3000, epsilon, rho, mu, K=3.28, C=8)
p6 = Pipe(D12, 5000, epsilon, rho, mu, K=3.28, C=8)
p7 = Pipe(D12, 1580, epsilon, rho, mu, K=1.78, C=8)
p8 = Pipe(D8, 1550, epsilon, rho, mu, K=5.53, C=8)
p9 = Pipe(D8, 1550, epsilon, rho, mu, K=7.03, C=8)
p10 = Pipe(D10, 5130, epsilon, rho, mu, K=7.78, C=8)
p11 = Pipe(D12, 1875, epsilon, rho, mu, K=2.53, C=8)

def balanced(x, b2, b4, b7, b10):
    Q1, Q2, Q3, Q4, Q5, Q6, Q7, Q8, Q9, Q10, Q11 = x
    # all expressions need to be set to zero
    return [
        Q1 - Q2 - Q3,
        Q6 - Q2 - Q4,
        Q3 - Q4 - Q5,
        Q5 - Q10 - Q7,
        Q7 - Q8 - Q9,
        Q11 - Q6 - Q7,
        K1*Q2*abs(Q2) + p2.h(Q2) + p6.h(Q6) + p11.h(Q11) + p1.h(Q1) - Ws + 0.
        ↪ 1*Q1*abs(Q1) - b2,
        p4.h(Q4) + K3*Q4*abs(Q4) - p2.h(Q2) - K1*Q2*abs(Q2) + p3.h(Q3) + b2 -
        ↪ b4,
        p7.h(Q7) + p8.h(Q8) + K4*Q8*abs(Q8) - p6.h(Q6) - p4.h(Q4) -
        ↪ K3*Q4*abs(Q4) + p5.h(Q5) + b4 - b7,
        p9.h(Q9) + K4*Q9*abs(Q9) - p8.h(Q8) - K4*Q8*abs(Q8),
        p10.h(Q10) + K2*Q10*abs(Q10) - p11.h(Q11) - p9.h(Q9) - K4*Q9*abs(Q9) -
        ↪ p7.h(Q7) + b7 - b10
    ]

Q_guess = np.array([5, 1, 4, 2, 2, 3, 1, 3, -2, 1, 4]) # This does satisfy
↪ mass conservation
b = 67.65, 101.95, 55.7, 44.9
balanced_solution = fsolve(balanced, Q_guess, args=(b, ))
balanced_solution # flow rates in ft^3/s

```

```

[2]: array([10.69253924,  2.71300891,  7.97953032,  2.7132475 ,  5.26628283,
          5.42625641,  2.55233847,  1.27984524,  1.27249323,  2.71394436,
          7.97859488])

```

2 Find

Using the results from Project 1 and the Goulds handout, accomplish the following:

- Are viscous fluid pump corrections needed?
- Select the required main-line pump (company, model number, RPM, rotor diameter). A copy

of the manufacturer's pump performance information is needed in the report. If booster pumps are used, then continue to use the same booster pumps increases in head as in Project 1 (the corrected version), but you do not need to specify an exact model.

- c. Generate a curve fit for H vs. Q for the main-line pump of part (b). Verify using the Hardy-Cross or Kirchhoff program that the selected pump is suitable. This means that the H - Q curve fit is to be placed in the Hardy-Cross or Kirchhoff program and the resulting flow rates in the individual loads are to be computed and compared with the required flow rates. Compute the power required for the pump including viscous corrections, if needed.
- d. The management team also wants a parallel pump arrangement, using identical pumps, for the main line to be examined. Booster pumps, if used, are the same as in Part (b). Select the required pump (model number, RPM, rotor diameter). A copy of the manufacturer's pump performance information is needed. Use the Hardy-Cross or Kirchhoff program to find the behavior of the system with (1) both pumps in parallel and (2) only one of the parallel pumps in operation. This gives some idea of the system capability of the parallel arrangement if one pump is down. For the parallel analysis, determine the power required (including viscous corrections, if needed) for the two parallel pump operating conditions.
- e. Provide a summary of the recommended pumps for the system including the system capacity when only one of the pumps in the parallel configuration is operating. A recommendation as to which arrangement to use, single main pump or parallel main pumps, is desired.