

Year progress

Short interruptions

Less than 3 min and under 1% nominal voltage

6 events

10 to 100 allowed per year

Long interruptions

More than 3 min and under 1% nominal voltage


0 events

10 to 50 allowed per year



Rotate cell phone to start Network Analyzer

Grid Voltage



95% of the year between $230 \pm 10\%$ V with no events allowed outside $\pm 10\%$



Harmonic distort



100% of the year between $230 \pm 10\%$ V with no events allowed outside $\pm 10\%$

