

JUST FILE #	Pepsi Beverages Company	DATE	2020-07-08	JUST REF NO.	2019-01
-------------	-------------------------	------	------------	--------------	---------

CUSTOMER	Pepsi Beverages Company				
	new york				
PHONE	905-568-7918	FAX	905-568-7879	EMAIL	

### **TEST EQUIPMENT USED FOR CALIBRATION**

DESCRIPTION	Multimeter	DESCRIPTION	Pressure Gauge
SERIAL NO	154255	SERIAL NO	1611070065
MODEL NO	Multi 18s	MODEL NO	DPG-254LM
EXPIRY DATE	2020-07-03	EXPIRY DATE	2020-07-03
MANUFACTURER	Rishab	MANUFACTURER	DPG

### **INSTRUMENT IDENTIFICATION**

LOCATION	SYRUP ROOM	DESCRIPTION	...
SERIAL NO	...	DUE. DATE	2022-07-08
TOLERANCE	0.5	MODEL NO	7MF4033-1CY10
TAG NO	LT-01	MANUFACTURER	SIEMENS
CAL. DATE	2020-07-08	RANGE	223.2

### **CALIBRATION RESULTS**

% FULL SCALE	AS FOUND			AS FOUND		
	INPUT	OUTPUT	ERROR	INPUT	OUTPUT	ERROR
0	0.00	4.18	0.01	0.00	4.01	4.01
25	55.80	8.18	0.01	55.80	8.01	8.01
50	111.60	12.18	0.01	111.60	12.01	12.01
75	167.40	16.18	0.01	167.40	16.01	16.01
100	223.20	20.18	0.01	223.20	20.01	20.01

### **CALIBRATION REPORT**

PASSED	FAILED	COMMENTS
YES	NA	Unit Working Within Tolerance

CALIBRATION BY	Kanwar Dhanjal	SIGN	SIGN	CHECKED BY	SIM	SIGN	SIGN
----------------	----------------	------	------	------------	-----	------	------