

TACLB020326E

INVOICE

Natasha King
10206 Briar Dr
Houston, TX 77042
(713) 876-2220

DESCRIPTION	AMOUNT
Checked controls and wiring to condensing unit	
*bad capacitor	
Installed new dual capacitor	
Serviced outside unit/checked filters	
*checked freon levels—good	
*washed down condensers	
*checked filters—needed to be changed	
parts and labor subtotal	\$ 297.00
TOTAL	\$ 297.00

Make all checks payable to Houston Power Savers
If you have any questions concerning this invoice, Kenneth Longoria 713-3062694

THANK YOU FOR YOUR BUSINESS!