

HINDUSTAN PETROLEUM CORPORATION LIMITED

(A Government of India Enterprise)

QUALITY CONTROL LABORATORY

LABORATORY TEST REPORT

TRANSFORMER OIL 210L EC DRUM(2376211)

Laboratory Serial No.

Sample Drawn By

JDE Serial No

1101723

Date Sample Drawn

Batch No / Lot No

M1-21-L-504

Date Received In Lab

Work Order No

900720

Date Tested

Tank /Kettle/Location

WHS

Particular of Sample

Plant Code/ Name

Sampling Plan

Test Line Number	Test Description/ Characteristics	Units	Test Method	Specifications		Result Value
				Min	Max	
1	TRANSFORMER OIL FLASH POINT	°C	IS 1448 P 21	135.0	300.0	174.0
2	TRANSFORMER OIL FURFURL	mg/kg	IS 15668	0	.05	0
3	TRANSFORMER OIL GAS TEND	mm3/min	IEC 60628 METHOD A	-	9999	14.8
4	TRANSFORMER OIL ACID OXIDISED	mg KOH/g	12422 (C) 164 h 1.9.4	0	1.20	.02
5	TRANSFORMER OIL DDF OXIDISED	.	IS 12422(C) 164 H, 1.9.6	0	.500	.001
6	TRANSFORMER OIL SLUD OXIDISED	wt. %	IS 12422(C) 164 H, 1.9.1	0	.80	.01
7	TRANSFORMER OIL ACIDITY	mg KOH/g	IEC 62021-1	0	.01	.01
8	TRANSFORMER OIL APPEARANCE	.	VISUAL	B&C	B&C	B&C
9	TRANSFORMER OIL BDV	kV	IS 6792	30	999	54
10	TRANSFORMER OIL CORROSI SULFUR	.	DIN 51353	NOT CORROSIVE	NOT CORROSIVE	NOT CORROSIVE
11	TRANSFORMER OIL DBDS	mg/kg	IS16497 PART 1	0	5.000	0
12	TRANSFORMER OIL DDF@90	.	IS 16086	0	.005000	.000490
13	TRANSFORMER OIL DENSITY@20	g/ml	IS 1448 P 16	.8000	.8950	.8317
14	TRANSFORMER OIL INHIBITOR	wt. %	IS 13631	0	.010	.010
15	TRANSFORMER OIL INTER TENSION	mN/m	ASTM D 971	-	-	42.5
16	TRANSFORMER OIL KV@0°C	mm2/sec	IS 1448 P 25	0	1800.00	61.82
17	TRANSFORMER OIL KV@40°C	mm2/sec	IS 1448 P 25	0	15.00	10.79
18	TRANSFORMER OIL METAL PASSIVAT	mg/kg	IS 13631	1.00	5.00	1.00
19	TRANSFORMER OIL PARTICLE COUNT	.	IS 13236	-	10000000000000	5
20	TRANSFORMER OIL PCA	wt. %	IP 346	0	3.00	1.00
21	TRANSFORMER OIL PCB	mg/kg	IS 16082	0	2	0
22	TRANSFORMER OIL POT COR SULFUR	.	IS 16310	NOT CORROSIVE	NOT CORROSIVE	NOT CORROSIVE
23	TRANSFORMER OIL POUR POINT	°C	IS 1448 P 10	-99	-10	-27
24	TRANSFORMER OIL TOTAL SULFUR	wt. %	ISO 14596 OR ASTM D 4294	0	99999998.951	.002
25	TRANSFORMER OIL WATER CONTENT	mg/kg	IEC 60814 NOTE 3 IS 335:2018	0	30	24

Note:

- 1) The report refers only to the sample tested.
- 2) The test report shall not be reproduced except in full without prior written approval of the Lab Incharge.
- 3) This test report shall not be used in any advertising media or as evidence in the Court of Law without prior written consent of Laboratory.
- 4) This is a system generated test report and hence does not require signature.

Approved By :