

HINDUSTAN PETROLEUM CORPORATION LIMITED

(A Government of India Enterprise)

QUALITY CONTROL LABORATORY

MAZGAON TERMINAL

LUBE PLANT, HAY BUNDER ROAD, MAZGAON

MUMBAI,400033

LABORATORY TEST REPORT**TRANSFORMER OIL 210L EC DRUM(2376211)**

Laboratory Serial No.	FB-110	Sample Drawn By	OPERATION OFFICER
JDE Serial No	1243556	Date Sample Drawn	22/04/23
Batch No / Lot No	M1-23-D-447	Date Received In Lab	22/04/23
Work Order No	1051705	Date Tested	24/04/23
Tank /Kettle/Location	WHS	Particular of Sample	DRUM
Plant Code/ Name		Sampling Plan	IS :6855

Test Line Number	Test Description/ Characteristics	Units	Test Method	Specifications		Result Value
				Min	Max	
1	TRANSFORMER OIL FLASH POINT	°C	IS 1448 P 21	135.0	300.0	168.4
2	TRANSFORMER OIL FURFURL	mg/kg	IS 15668	0	.05	0
3	TRANSFORMER OIL GAS TEND	mm3/min	IEC 60628 METHOD A	-	9999	9.8
4	TRANSFORMER OIL ACID OXIDISED	mg KOH/g	12422 (C) 164 h 1.9.4	0	1.20	.06
5	TRANSFORMER OIL DDF OXIDISED	.	IS 12422(C) 164 H, 1.9.6	0	.500	.002
6	TRANSFORMER OIL SLUD OXIDISED	wt. %	IS 12422(C) 164 H, 1.9.1	0	.80	.06
7	TRANSFORMER OIL ACIDITY	mg KOH/g	IEC 62021-1	0	.01	0
8	TRANSFORMER OIL APPEARANCE	.	VISUAL	B&C	B&C	B&C
9	TRANSFORMER OIL BDV	kV	IS 6792	30	999	72
10	TRANSFORMER OIL CORROSI SULFUR	.	DIN 51353	NOT CORROSIVE	NOT CORROSIVE	NOT CORROSIVE
11	TRANSFORMER OIL DBDS	mg/kg	IS16497 PART 1	0	5.000	0
12	TRANSFORMER OIL DDF@90	.	IS 16086	0	.005000	.001400
13	TRANSFORMER OIL DENSITY@20	g/ml	IS 1448 P 16	.8000	.8950	.8401
14	TRANSFORMER OIL INHIBITOR	wt. %	IS 13631	0	.010	.010
15	TRANSFORMER OIL INTER TENSION	mN/m	ASTM D 971	-	-	42.0
16	TRANSFORMER OIL KV@0°C	mm2/sec	IS 1448 P 25	0	1800.00	66.74
17	TRANSFORMER OIL KV@40°C	mm2/sec	IS 1448 P 25	0	15.00	11.27
18	TRANSFORMER OIL METAL PASSIVAT	mg/kg	IS 13631	1.00	5.00	1.00
19	TRANSFORMER OIL PARTICLE COUNT	.	IS 13236	-	10000000000000	5
20	TRANSFORMER OIL PCA	wt. %	IP 346	0	3.00	1.00
21	TRANSFORMER OIL PCB	mg/kg	IS 16082	0	2	0
22	TRANSFORMER OIL POT COR SULFUR	.	IS 16310	NOT CORROSIVE	NOT CORROSIVE	NOT CORROSIVE
23	TRANSFORMER OIL POUR POINT	°C	IS 1448 P 10	-99	-10	-12
24	TRANSFORMER OIL TOTAL SULFUR	wt. %	ISO 14596 OR ASTM D 4294	0	99999998.951	0
25	TRANSFORMER OIL WATER CONTENT	mg/kg	IEC 60814 NOTE 3 IS 335:2018	0	30	19

Remarks : SAMPLE MEETS THE SPECIFICATION IS 335 : 2018 IN ALL ABOVE TEST PARAMETERS.

Note:

- 1) The report refers only to the sample tested.
- 2) The test report shall not be reproduced except in full without prior written approval of the Lab Incharge.
- 3) This test report shall not be used in any advertising media or as evidence in the Court of Law without prior written consent of Laboratory.
- 4) Test results reported are valid at the time of testing
- 5) This is a system generated test report and hence does not require signature.

Reviewed and Authorized by:

WARANG CHANDRAKANT PRABHAKAR(30074520)