

## FIRE SAFETY STRATEGY REPORT

Project: Victoria Court

Reference: BSR-GW2-005

Location: Birmingham

Date: October 2025

Prepared in accordance with:

- Building Regulations 2010
- Approved Document B

### BUILDING DESCRIPTION

Project: Victoria Court, Birmingham

Height: 21m

Storeys: 7

Building Use: Residential

Units: 40 apartments

### MEANS OF ESCAPE

Two staircases provided serving all floors.

Travel distances within acceptable limits.

Fire doors: FD60S

Compartmentation: 60 minutes

### EXTERNAL WALLS

External wall system: Brick and mineral wool insulation

Materials: Non-combustible

### FIRE PROTECTION

Sprinklers: Provided to BS EN 12845:2015

Fire alarm: L1 system to BS 5839-1

Emergency lighting: Provided

### STRUCTURAL FIRE RESISTANCE

Structural elements: 60 minutes fire resistance

Design to relevant Eurocodes

Note: Some specifications require further detail during detailed design stage.

Prepared by:

Jane Doe BEng

Fire Safety Consultants Ltd

END OF REPORT