

Silverline House — 25-Storey Residential HRB

Fire Door Schedule

Document Reference: 2.2.5

Revision: Rev A

Date: March 2026

Project Reference: SLH-2026

1 Introduction

1 Scope

This schedule lists all fire doors within the building, their fire resistance rating, specification, and location by floor and grid reference. All fire doors comply with BS 476-22:1987 or BS EN 1634-1:2014 and are third-party certified to LPS 1197 or equivalent.

2 Schedule Notes

Fire doors are categorised as FD30S (30-minute with smoke seal) for apartment entrance doors and FD60S (60-minute with smoke seal) for staircase and lift lobby enclosures. Ironmongery is listed separately in the Ironmongery Schedule (document ref SLH-ARC-052). Door closers are compliant with BS EN 1154 and BS EN 1155 for hold-open devices with automatic release on alarm activation.