

An Advanced Approach to Radiation Detection Technology: The Design, Development, and Theoretical Implementation of a Reverse-Engineered Geiger-Müller Counter Utilizing a Novel Nanotechnology-Based Design

Narayani Garg

12th Grade; IBDP II

Category: *Biomedical Engineering (ENBM)*

Sub-Category: *Biomedical Sensors and Imaging (IMG)*

South Iredell High School; Iredell Statesville School District

Statesville, Iredell County, North Carolina

Personal Research Paper

Abstract

This research presents the theoretical development of a novel carbon nanotube-based Geiger-Müller (CNT-GM) counter, designed to address the limitations of traditional Geiger-Müller counters and radiation detection technologies. The CNT-GM counter model utilizes a carbon nanotube filled with helium gas as the ionization medium, generating electrical pulses upon interaction with ionized particles. Laser micro-welding techniques would be utilized to ensure proper sealing of the nanotube structures. For adaptability, the CNT-GM counter can be integrated into fabric substrates using conductive cotton pathways for signal transmission. A lightweight microcontroller was investigated to record and wirelessly transmit radiation data, while an ethylene-polyurethane encapsulation would provide moisture resistance and durability. Additionally, a second model was developed featuring a multilayered structure of carbon nanotubes and graphite, allowing for radiation shielding for applications in extreme environments. Theoretical simulations demonstrated the effectiveness of the CNT-GM counter in diverse conditions, indicating its potential for use in wearable radiation monitoring, industrial safety, and environmental surveillance. By leveraging the unique properties of nanomaterials, this research contributes to the development of lightweight, flexible, and durable radiation detection systems.

Introduction

The detection of ultraviolet (UV) and ionizing radiation has been a cornerstone of scientific progress, with applications spanning medical diagnostics, safety monitoring, and research methodologies. Among the numerous devices engineered for radiation detection, the Geiger-Müller (GM) counter, developed in 1928 by Hans Geiger and Walther Müller, remains a widely recognized tool. The GM counter operates by detecting the ionization of gas within a sealed tube, translating radiation interactions

into measurable electrical pulses. Its reliability has cemented its place in the scientific and industrial toolkit for nearly a century.

However, as technology advances, the traditional GM counter is increasingly showing its limitations. Its reliance on rigid metallic or glass enclosures and conventional electrical circuitry renders it unsuitable for many modern applications requiring flexibility, portability, or integration. For instance, wearable radiation detectors are becoming crucial for military personnel operating in hazardous environments and for medical professionals routinely exposed to ionizing radiation. To address these challenges, utilizing nanotechnology—the manipulation of matter at the nanoscale to achieve certain properties—offers an opportunity for radiation detection systems.

This paper explores the theoretical implications of reverse-engineering the GM counter using a nanotechnology-based design. The proposed design focuses on integrating nanoscale materials with unique electrical and mechanical properties to create adaptable and efficient radiation detection systems.

Research Question

This research seeks to address the following question: How can a reverse-engineered Geiger-Müller counter, utilizing carbon nanotubes as a structural body, tungsten as the central anode, and helium gas as the ionization medium, overcome the limitations of traditional GM counters while enabling applications in dynamic and wearable radiation detection systems?

This inquiry emerges from personal curiosity about nanotechnology and radiation detection technologies. As I delved into this topic, I began by exploring the history and applications of radiation detectors, specifically the Geiger-Müller counter. Further exploration led me to the potential of nanotechnology, particularly carbon nanotubes (CNTs), which possess exceptional mechanical and electrical properties. I became intrigued by the idea of leveraging CNTs as a structural material to overcome the rigidity of traditional GM counters while exploring the use of tungsten—a material known

for its robustness in radiative environments—as the anode. The integration of helium gas as the ionization medium, chosen for its inert properties and efficient ionization characteristics, was another key to the formation of this research question.

This research is significant because it aligns with pressing needs in multiple sectors. In healthcare, radiation workers require unobtrusive, wearable monitoring systems. In military operations, soldiers in hazardous environments need lightweight and robust detectors integrated into their gear. Beyond these applications, advancements in nanotechnology-based GM counters could enable more precise environmental monitoring and enhance IoT sensor networks.

Engineering Objectives

1. Use Flexible and Nanotechnological Materials in the GM Model

The primary objective is to develop a theoretical design of a reverse-engineered Geiger-Müller counter that incorporates carbon nanotubes as the structural body, tungsten wire as the central anode, and helium gas as the ionization medium. The parts of the model should maintain the functionality of a GM counter and have manufacturing processes that allow them to be merged.

2. Evaluate the Suitability of Materials Used

To validate the feasibility of the proposed design, this research will analyze the selected materials for their performance under expected operating conditions. Carbon nanotubes, as cylindrical nanostructures composed of graphene sheets, offer exceptional mechanical strength and electrical conductivity. These properties make CNTs ideal for housing for the counter. Tungsten, known for its high melting point and stability under radiation, will serve as the anode, supporting the ionization process. Helium gas, chosen for its low atomic mass and high ionization potential, will act as the ionization medium.

3. Create a Lightweight and Durable Model for Wearable Technologies

Another goal is to address the limitations of traditional GM counters by creating a lightweight, flexible, and durable integrations of the initial CNT-GM design into textiles. The integration of carbon nanotubes and tungsten into the design will enable the development of a detector that can be used to create wearable technologies.

4. Investigate Applications of the Model

The final objective is to explore potential applications of the reverse-engineered GM counter across various industries. This includes investigating the feasibility of weaving carbon nanotubes into fabrics to create radiation-detecting garments.

Background Information

Geiger-Müller Counters

The concept of using ionization for radiation detection dates back to the early 20th century. Hans Geiger, in 1908, developed the first device capable of detecting alpha particles through ionization (United States Nuclear Regulatory Commission, 2020). While groundbreaking, this early device was limited in scope, capable only of detecting specific radiation types. In 1928, Geiger collaborated with Walther Müller to create the modern GM counter. This innovation included the incorporation of an inert gas within a sealed tube and the addition of a quenching agent, enabling the detection of beta and gamma radiation (Dutfield, 2022).

The GM counter's design and utility evolved further throughout the 20th century. During the Cold War, these devices became essential for monitoring fallout from nuclear tests, leading to advancements in their durability and accuracy (Walton, 2023). Today, modern GM counters are equipped with digital displays and amplification circuits.

The GM counter operates on the principle of gas ionization within a sealed environment. The primary components include the sealed tube, the central anode, the cathode, and the gas mixture. The sealed tube serves as the chamber where radiation-induced ionization occurs. This tube is filled with an inert gas, such as argon, at low pressure, along with a small quantity of a halogen or organic vapor to act as a quenching agent. The central anode, typically a thin wire, is maintained at a high positive voltage relative to the tube wall, which serves as the cathode (Images Scientific Instruments, n.d.).

When a particle of ionizing radiation enters the GM tube, it collides with a gas molecule, stripping away an electron and creating a positive ion. This initial ionization event triggers a chain reaction as the freed electron accelerates toward the anode, colliding with other gas molecules and producing additional ion pairs. This process, known as the Townsend avalanche, amplifies the ionization to produce a detectable electrical pulse (Chung, 2018).

The electrical pulse generated during ionization is sent to an external circuit for measurement. Modern GM counters often include digital processors that convert these pulses into radiation counts, which are displayed on an LCD or analog meter.

Despite their versatility, GM counters have limitations. They cannot differentiate between radiation types or measure energy levels, which restricts their use in applications requiring spectroscopic analysis. However, their affordability, portability, and ease of use continue to make them indispensable in many fields.


Table 1. Pros and Cons of GM Counters

<u>Component</u>	<u>Advantages</u>	<u>Disadvantages</u>
Sealed Tube	Provides a controlled environment for ionization and enhances durability.	Fragility of glass tubes makes them prone to mechanical damage; limited flexibility of metal tubes.

Central Anode	Enables efficient collection of electrons.	Can degrade over time, especially under prolonged exposure to high radiation intensities.
Gas Mixture	Allows efficient ionization and stable operation across a range of radiation levels.	Precise composition requirements increase manufacturing complexity.

Carbon Nanotubes (CNTs)

Carbon nanotubes (CNTs) are cylindrical nanostructures composed entirely of carbon atoms arranged in a hexagonal lattice, forming a seamless tube. First discovered in 1991 by Sumio Iijima, CNTs have become one of the most studied nanomaterials due to their exceptional mechanical, electrical, and



thermal characteristics. These nanostructures are often described as rolled-up sheets of graphene, a single layer of carbon atoms arranged in a two-dimensional honeycomb lattice. Depending on how the graphene sheet is rolled, CNTs can exhibit different structural and electronic properties (Williams, n.d.). The image (Filchakova & Saik, 2021) shows this.

The diameter of CNTs typically ranges from 0.4 to 10 nanometers, while their length can extend to several micrometers or even millimeters. This extreme aspect ratio contributes to their unique behavior, which combines strength, conductivity, and chemical stability. CNTs are classified into two primary types: single-walled carbon nanotubes (SWCNTs) and multi-walled carbon nanotubes (MWCNTs) (Saifuddin et al., 2012).

CNTs are synthesized using various methods, each used to produce specific types, quantities, and qualities of nanotubes. The three most common synthesis techniques are:

1. Chemical Vapor Deposition (CVD):

CVD is the most widely used method for producing CNTs. In this process, a substrate coated with a metal catalyst (such as iron, nickel, or cobalt) is exposed to a carbon-containing gas, such as methane, acetylene, or ethylene, at high temperatures (600–1200°C). The carbon atoms decompose on the catalyst surface and recombine to form nanotubes. The growth can be controlled to produce SWCNTs or MWCNTs, depending on the reaction parameters (Kumar & Ando, 2010).

2. Arc Discharge Method:

This technique involves passing a high current between two carbon electrodes in an inert gas atmosphere. The heat generated vaporizes the carbon, leading to the formation of nanotubes in the soot. While this method yields high-quality CNTs, it is less scalable compared to CVD (Shkol'nik, 2011).

3. Laser Ablation:

In laser ablation, a high-powered laser vaporizes a carbon target in a high-temperature furnace filled with inert gas. This process produces high-purity CNTs but is expensive and limited in scalability (Neumann & Gemert, 2014).

CNTs are categorized based on the number of concentric graphene layers and their chirality (the angle at which the graphene sheet is rolled).

1. Single-Walled Carbon Nanotubes (SWCNTs):

SWCNTs consist of a single graphene sheet rolled into a cylindrical tube. They are versatile and exhibit exceptional electrical conductivity, often behaving as semiconductors or metals depending on their chirality (Tomada & Amsharov, 2018).

Table 2. Pros and Cons of SWCNTs

<u>Advantages</u>	<u>Disadvantages</u>
High electrical conductivity.	Difficult and expensive to produce in large quantities.
Excellent mechanical strength and flexibility.	Purification challenges due to the presence of unwanted byproducts.
Unique optical properties.	

2. Multi-Walled Carbon Nanotubes (MWCNTs):

MWCNTs consist of multiple concentric graphene cylinders nested within one another. They are generally more robust and easier to produce than SWCNTs, making them suitable for industrial applications (Ahn et al., 2010).

Table 3. Pros and Cons of MWCNTs

<u>Advantages</u>	<u>Disadvantages</u>
Greater mechanical strength due to multiple layers.	Lower electrical conductivity than SWCNTs.
Higher chemical stability under extreme conditions.	Complex structure makes their characterization more challenging.
More cost-effective production compared to SWCNTs.	

CNTs possess a mechanical strength several times that of steel, yet they are significantly lighter, enabling the creation of durable yet lightweight structures. CNTs also exhibit electrical conductivity due to the delocalized π -electrons along their graphene structure, allowing minimal scattering and high electron mobility (Pichler et al., 1998). Additionally, CNTs have a high thermal conductivity, excellent chemical stability, and a large surface area, which improves their interaction with other materials and makes them suitable for applications in sensors, energy storage, and composite materials.

CNTs in Radiation Environments

When exposed to ionizing radiation, CNTs exhibit enhanced electrical conductivity as a direct result of their ability to absorb and transport the energy of incoming particles. For instance, gamma radiation has been shown to increase the electrical conductivity of CNTs by inducing localized defects that enhance electron mobility.

Radiation-induced effects in CNTs depend on the type and intensity of radiation as well as the structural configuration of the nanotubes. Studies have shown that multi-walled carbon nanotubes (MWCNTs) are more resistant to damage than single-walled carbon nanotubes (SWCNTs) due to their layered structure, which provides an additional degree of shielding (Vasilev, 2021).

Tungsten as the Central Anode

Tungsten (chemical symbol W, atomic number 74) is a transition metal located in Group 6 of the periodic table. It is naturally found in minerals such as scheelite (CaWO_4) and wolframite ($(\text{Fe,Mn})\text{WO}_4$) and is typically extracted through hydrometallurgical or pyrometallurgical processes. Tungsten is characterized by its density (19.25 g/cm^3) and high atomic number, which contribute to its effectiveness in radiation-related applications. Its high atomic number improves its capacity to interact with ionizing radiation, producing secondary electron emissions that amplify detection signals in radiation detectors like GM counters. One of tungsten's most remarkable properties is its exceptionally high melting point of 3422°C , the highest of all metals, which makes it suitable for use in extreme environments, such as high-radiation and high-temperature applications. Additionally, tungsten has a low coefficient of thermal expansion, excellent thermal conductivity, and high mechanical strength, making it resistant to deformation and damage under stress or prolonged exposure to intense heat (Barrier Technologies, 2022).

Tungsten makes it an excellent candidate for functioning as a central anode in radiation detection devices, particularly in advanced Geiger-Müller (GM) counters. An anode is a positively charged

electrode that attracts electrons emitted during the ionization process. The design of tungsten anodes varies depending on the application. For instance, a thin, cylindrical tungsten wire is commonly used in radiation detectors. Tungsten anodes are typically manufactured using powder metallurgy, where tungsten powder is sintered at high temperatures to form dense, solid structures. This method allows for the production of highly pure tungsten components with minimal inclusions (Chen et al., 2022).

Helium as an Ionization Gas

Helium (chemical symbol He, atomic number 2) is a noble gas with chemical and physical properties that make it ideal for use in advanced radiation detection systems. It is the second lightest element in the periodic table, with a molar mass of 4.0026 g/mol, and is composed of two protons, two neutrons, and two electrons. Helium is found abundantly in natural gas deposits and is extracted via cryogenic distillation or membrane separation techniques. Helium's inertness is attributed to its closed-shell electronic configuration ($1s^2$), which makes it highly stable and nonreactive under normal conditions, even in the presence of ionizing radiation or high electric fields. Helium has a high ionization potential of 24.6 eV, which means a significant amount of energy is required to remove an electron from a helium atom (McMahon et al., 2012).

In Geiger-Müller counters, the ionization gas plays a central role in converting ionizing radiation into detectable electrical signals. Helium is effective in this role due to its ability to efficiently ionize and transport charge. Helium's high ionization energy reduces the risk of over-ionization and prevents signal saturation. The process of incorporating helium into a radiation detector involves filling the detector's chamber with helium gas under controlled pressure conditions. Lower pressures are used to minimize scattering and dead time, while higher pressures increase the probability of ionization events by concentrating the gas molecules (Mansur & Coghlan, 2003).

Design and Development

A critical innovation in this model is the exploitation of the extensive surface area provided by CNTs, which significantly improves the detector's charge collection efficiency. The high surface-to-volume ratio of CNTs increases the likelihood of interaction between ionizing radiation and the detector material. This interaction leads to the production of more free electrons and ions, thereby amplifying the signal generated during radiation detection.

The nanoscale dimensions of CNTs also enable the formation of a highly conductive network, facilitating rapid transport of charge carriers to the signal processing unit. This rapid transport reduces signal attenuation and improves the time resolution of the detector, making it capable of capturing high-energy radiation events with greater accuracy.

Manufacturing Carbon Nanotubes (CNTs)

The production of CNTs relies on chemical vapor deposition (CVD), a widely used method that ensures high purity, precise dimensional control, and scalability. Transition metals such as iron (Fe), nickel (Ni), and cobalt (Co) are commonly utilized due to their strong catalytic activity in decomposing carbon-rich gases. These metals are deposited onto substrates like silicon (Si) or alumina (Al_2O_3) in the form of nanoparticles. The nanoparticles act as nucleation sites, guiding the growth of CNTs by breaking down the hydrocarbon gases introduced during the synthesis process. The size of these nanoparticles determines the diameter of the resulting CNTs, with smaller particles leading to single-walled carbon nanotubes (SWCNTs) and larger particles leading to the formation of multi-walled carbon nanotubes (MWCNTs) (Dutfield, 2022).

Once the catalyst is prepared, the substrate is placed in a chemical vapor deposition (CVD) chamber, which is heated to high temperatures, typically ranging from 700°C to 900°C . This temperature range provides the necessary activation energy for the catalytic decomposition of carbon-rich gases while

preventing unwanted reactions that could introduce defects into the CNT structure. After reaching the desired temperature, a hydrocarbon gas, such as methane (CH_4) or ethylene (C_2H_4), is introduced into the chamber. The metal catalyst nanoparticles act to break down these gas molecules, releasing individual carbon atoms. These carbon atoms then diffuse across the surface of the catalyst, where they form a graphene sheet—a single layer of carbon atoms bonded in a hexagonal pattern.

The graphene sheet tends to minimize its energy by wrapping into a cylindrical shape around the catalyst nanoparticle, forming a carbon nanotube. The vertical growth of the tube continues as carbon atoms are continuously deposited, leading to the elongation of the nanotube. Post-synthesis, the CNTs are harvested from the substrate and purified to remove residual catalyst particles and byproducts that may interfere with their intended application (Zhang et al., 2011).

Positioning the Tungsten Wire as the Central Anode

The central anode in this advanced Geiger-Müller counter is a tungsten wire, which acts as the charge collector, central to the ionization process within the radiation detection system. Tungsten wire is fabricated through a process known as wire drawing. This involves passing tungsten rods through progressively smaller dies—precision-engineered molds with specific hole sizes—until the wire reaches the desired diameter, typically between 10 and 50 micrometers. Tungsten's high melting point ($3,422^\circ\text{C}$) and inherent strength make it particularly suitable for this process. Between each stage of drawing, the wire undergoes annealing, a heat treatment process that involves heating the wire to high temperatures followed by controlled cooling. Annealing alleviates internal stresses induced during the drawing process. The final product is an ultra-thin yet strong tungsten wire, precisely wound onto spools for ease of handling and integration (Midwest Tungsten Service, n.d.).

Inserting the Tungsten Wire into the CNT Detector

The integration of the tungsten wire into the CNT-based radiation detector takes place in a controlled environment within a sealed gas chamber. This chamber is equipped with robotic micromanipulators, which are high-precision tools capable of handling materials on the nanoscale. Using the micromanipulators, the tungsten wire is carefully inserted into the hollow core of the CNT structure. Optical microscopy and imaging techniques are employed to center within the CNT to maintain a uniform electric field along the detector's length.

Filling the CNTs with Helium Gas:

Helium gas is introduced into the chamber at a regulated pressure, typically between 0.1 and 0.5 atmospheres (atm). This pressure range ensures sufficient helium penetration into the CNTs' hollow cores and avoids excessive pressure that could displace the tungsten wire or compromise the CNT structure. To facilitate infiltration, the chamber is equipped with mass flow controllers. Helium's small atomic size and monoatomic nature allow it to diffuse into these nanoscale cavities through capillary action, a phenomenon driven by surface tension and the pressure gradient between the external environment and the CNT interior (Monthieux, 2002)

Sealing Carbon Nanotubes (CNTs)

Effective sealing not only prevents helium leakage but also secures the tungsten wire, maintaining its alignment with the detector's electrical field. Laser micro-welding has emerged as the most effective sealing method for helium-filled CNTs in this application. This technique employs a focused laser beam to selectively heat and fuse the open ends of CNTs, creating a hermetic seal without compromising the structural integrity of the nanomaterial. The laser micro-welding process is conducted within the helium-filled chamber to prevent gas escape. Fiber lasers and diode lasers, which emit light at

wavelengths typically in the infrared range (e.g., 1.07 μm), are commonly used due to their controllability (EB Industries, n.d.).

The laser operates in short, high-intensity pulses, delivering sufficient energy to locally heat the CNT edges to temperatures exceeding 2500°C. At this temperature, the carbon atoms at the open ends of the CNTs rearrange to form stable covalent bonds, sealing the structure. The localized nature of the laser heating minimizes thermal damage to the surrounding CNT walls and prevents helium leakage during the process (Edgar et al., 2011).

Integration of the CNT-GM Counter Model

Model 1

By integrating the carbon nanotube (CNT)-based Geiger-Müller (GM) design into lightweight, flexible fabrics, these radiation measuring systems enable unobtrusive, real-time radiation monitoring.

Unbleached cotton is a preferred choice for base material due to its mechanical strength, thermal stability, and breathability. Cotton's natural UV reflection protects the electronics from photodegradation caused by prolonged exposure to ultraviolet radiation (Nosheen et al., 2022). Additionally, its hydrophilic properties enhance adherence with conductive materials and CNT structures, minimizing brittleness.

CNT GM counters, designed for nanoscale radiation detection, are woven into the cotton fibers using conductive yarns. These yarns, typically composed of silver-plated nylon or carbon fiber, provide structural anchoring for the CNTs while ensuring electrical conductivity. Conductive yarns are pre-coated with a polymer matrix to enhance adhesion and prevent delamination. The weaving process, conducted on computerized jacquard looms, allows for precise placement of CNT GM counters (Patel et al., 2013)

Conductive pathways are essential for transmitting radiation detection data. A grid pattern within the fabric is established using high-conductivity silver-plated nylon yarns. These materials offer excellent electrical properties and resist corrosion, essential for long-term functionality.

The embedded CNT GM counters are connected to a lightweight microcontroller for real-time data transmission. The microcontroller is powered by a flexible thin-film battery and incorporates analog-to-digital converters (ADCs) for processing the electrical pulses generated by the CNT GM counters into digital signals. Conductive adhesives are used to attach the electronics to the fabric, ensuring stable connections without adding bulk.

To enhance durability, a polyurethane coating is applied using a dip-coating technique. This coating offers resistance to moisture, sweat, and environmental contaminants while maintaining the fabric's flexibility and breathability.

Model 2

In space environments, radiation poses significant risks to human health and mission-critical equipment. The second model addresses these challenges by integrating CNT-based GM counters into a robust, multi-layered wearable fabric. This design is optimized to withstand high-energy cosmic rays, solar particle events, and microgravity-induced stresses, ensuring durability and functionality in extreme conditions.

Multi-layer CNT sheets are synthesized using chemical vapor deposition (CVD), a process involving the decomposition of gaseous carbon precursors on catalyst-coated substrates at high temperatures (700–900°C). This method produces vertically aligned CNT arrays with uniform thickness and orientation. The sheets are stacked and rolled under controlled pressure to enhance interlayer contact and minimize defects (Edgar et al., 2011).

Vacuum-assisted resin transfer molding (VARTM) binds the CNT sheets into a cohesive composite. This process involves a flexible, radiation-resistant epoxy resin such as bisphenol-A epoxy is chosen for its thermal stability and stress distribution properties. The resin is infused under vacuum conditions, ensuring complete penetration into the CNT layers and eliminating air pockets. The composite is cured at elevated temperatures (120–150°C), forming a rigid and cohesive material with enhanced mechanical and thermal properties. Conductive traces are fabricated using physical vapor deposition (PVD), which deposits thin metallic films onto the CNT composite surface. These traces connect the GM counters to the central detection electronics, enabling signal transmission. The embedded GM counters generate electrical pulses in response to radiation, which are amplified and digitized using onboard ADCs and field-programmable gate arrays (FPGAs) (Lattice Semiconductor, n.d.).

To enhance resilience against harsh space conditions, a multi-functional protective coating is applied. A polyimide layer provides thermal insulation, protecting the composite from temperature fluctuations (-150°C to +150°C) (Meng et al., 2023). An aluminized outer film reflects high-energy solar radiation, reducing thermal loading on the CNT layers. A silicone overcoat improves resistance to micrometeoroid impacts and space debris abrasion.

Application Simulation

Model 1

The theoretical advantages of integrating CNTs into unbleached cotton for radiation detection are significant. CNTs are sensitive to ionizing radiation due to their high surface area and excellent conductivity. When exposed to radiation, ionization events induce changes in electrical resistance, enabling precise detection even at low radiation levels. The lightweight and flexible nature of the CNT-integrated cotton fabric improves its comfort and wearability.

However, the integration of CNTs into wearable fabrics also presents challenges. Prolonged exposure to environmental factors such as sweat, ultraviolet (UV) radiation, and mechanical wear can degrade the material. For instance, sweat can corrode the CNT network, while UV radiation may induce photodegradation, compromising the device's electrical properties. Mechanical stresses from daily wear can disrupt the CNT alignment, reducing detection accuracy.

Environmental interferences, such as heavy rain or static electricity, may also impact the device's performance. Water infiltration can alter the electrical properties of the fabric, while static electricity can introduce noise into the sensor's output, potentially leading to false readings.

Proposed Improvements

To address these challenges and enhance the performance of the CNT-based GM counter, several modifications can be implemented. One such improvement is the application of a protective coating to shield the CNTs from environmental factors. A lightweight, waterproof coating made from materials such as polydimethylsiloxane (PDMS) or polyurethane can provide effective protection against moisture and UV radiation without compromising the fabric's flexibility.

Another improvement involves the integration of an embedded calibration module. This module, consisting of a microcontroller, can perform real-time self-calibration to account for baseline drifts caused by environmental changes or material wear. By monitoring and adjusting the sensor's performance, the calibration module ensures accuracy over time.

Model 2

The high sensitivity of CNTs, coupled with the multi-layer design, enhances the counter's ability to detect low-flux cosmic radiation as well as high-energy particle bursts. The multi-layer CNT structure offers flexibility and radiation shielding without the bulk associated with traditional metal-based shielding.

The overlapping CNT layers create a dense yet lightweight matrix that can absorb and scatter ionizing radiation.

Despite their advantages, CNTs face challenges in extreme thermal and microgravity environments. High temperatures can cause thermal expansion, while low temperatures may lead to brittleness, affecting the counter's performance. Similarly, the structural integrity of CNTs may be compromised in microgravity, as the absence of gravitational forces can lead to misalignment or delamination of the layers.

Proposed Improvements

To address temperature-related challenges, a thin insulating layer can be added to the multi-layer CNT structure. Materials such as aerogels or polyimide films, known for their excellent thermal stability and lightweight properties, can act as thermal barriers. These layers can prevent thermal expansion or contraction, preserving the CNT alignment and conductivity across extreme temperatures.

Reinforcing the CNT layers with a flexible polymer matrix, such as epoxy or polyethylene terephthalate (PET), can improve integrity without compromising flexibility. The polymer matrix provides mechanical support, reducing the risk of delamination and misalignment in microgravity. Additionally, polymers with high radiation resistance can further protect the CNT network from degradation caused by prolonged exposure to cosmic radiation.

Discussion

Future Research Directions

Future research should explore methods to reduce the size and weight of CNT-based GM counters, making them suitable for personal wearable devices. Techniques such as nanolithography, which uses electron beams to create intricate nanoscale patterns, could enable the precise fabrication of compact

sensors. Additionally, integrating flexible substrates, such as polyethylene terephthalate (PET), would allow CNT sensors to conform to the human body for unobtrusive monitoring.

Research should focus on embedding machine learning algorithms into CNT-GM systems to analyze radiation trends and predict exposure risks. The development of cloud-based platforms for real-time data aggregation and visualization could also improve accessibility for users.

Further research is needed to optimize CNT-GM technology for space missions. Investigations into the interaction between cosmic rays and CNT composites, as well as the long-term effects of microgravity on CNT alignment and functionality, would be essential to move forward.

Conclusion

Carbon nanotubes possess an exceptionally large surface area-to-volume ratio, combined with unique electrical properties such as ballistic electron transport and quantum conductivity. These features enable the CNT-GM counter to detect lower levels of ionizing radiation with higher accuracy than conventional metallic or gas-filled counters.

Traditional counters are constructed with rigid metallic tubes and bulky casings, limiting their adaptability to novel applications. In contrast, CNT-GM counters can be fabricated using flexible substrates, such as polyethylene or polyimide, which allow them to conform to non-linear surfaces. This adaptability is critical for continuous, hands-free radiation monitoring integrated into smart textiles or protective equipment.

The reduced weight and compactness of CNT-GM counters enhance their utility in portable or space-constrained applications. Unlike traditional counters, which rely on bulky detection chambers and associated electronics, CNT-GM counters utilize the nanoscale dimensions and lightweight nature of carbon nanotubes.

Bibliography

- Ahn, K., Kim, S.-M., & Yu, I. J. (2010, September 14). *Multi-Walled Carbon Nanotube (MWCNT) Dispersion and Aerosolization with Hot Water Atomization without Addition of Any Surfactant*. Science Direct. Retrieved January, 2025, from <https://www.sciencedirect.com/science/article/pii/S2093791111210096>
- Barrier Technologies. (2022, December 25). *Tungsten Shielding: Enhancing Safety in Radiation Protection*. Barrier Technologies. Retrieved January, 2025, from <https://barriertechnologies.com/tungsten-shielding/>
- Chen, C., Zhu, H., Shi, M., Hu, L., Xue, Z., Ye, H., Zhao, L., & Yan, C. (2022, April 8). *Oxygen vacancies-modulated tungsten oxide anode for ultra-stable and fast aqueous aluminum-ion storage*. Science Direct. Retrieved January, 2025, from <https://www.sciencedirect.com/science/article/abs/pii/S2405829722002021>
- Chung, K.-J. (2018, Fall). *Electrical Breakdown in Gases*. Department of Nuclear Engineering Seoul National University. Retrieved January, 2025, from https://ocw.snu.ac.kr/sites/default/files/NOTE/Lecture_06_Electrical%20breakdown%20in%20gases.pdf
- Dutfield, S. (2022, April 19). *Geiger counter: Design, facts and uses*. Live Science. Retrieved January, 2025, from <https://www.livescience.com/how-a-geiger-counter-works.html>
- EB Industries. (n.d.). *Laser Micro Welding*. EB Industries. Retrieved January, 2025, from <https://ebindustries.com/micro-welding/>
- Edgar, K., Tilley, R., Hendy, S., & Schebarchov, D. (2011, March 11). *Healing and sealing carbon nanotubes—growth and closure within a transmission electron microscope*. Royal Society Of

Chemistry. Retrieved January, 2025, from

<https://pubs.rsc.org/en/content/articlelanding/2011/nr/c0nr00864h>

Filchakova, M., & Saik, V. (2021, May 12). *Single-walled carbon nanotubes: structure, properties, applications, and health & safety*. Tuball. Retrieved January, 2025, from

<https://tuball.com/articles/single-walled-carbon-nanotubes>

Images Scientific Instruments. (n.d.). *How Geiger Counters Work and Detect Nuclear Radiation*. Images Scientific Instruments Inc. Retrieved January, 2025, from

<https://www.imagesco.com/geiger/about-geiger-counters.html>

Kumar, M., & Ando, Y. (2010, June). *Chemical Vapor Deposition of Carbon Nanotubes: A Review on Growth Mechanism and Mass Production*. Ingenta. Retrieved January, 2025, from

<https://www.ingentaconnect.com/contentone/asp/jnn/2010/00000010/00000006/art00003>

Lattice Semiconductor. (n.d.). *What is an FPGA*. Lattice Semiconductor. Retrieved January, 2025, from

<https://www.latticesemi.com/en/What-is-an-FPGA>

Mansur, L., & Coghlan, W. (2003, February 26). *Mechanisms of helium interaction with radiation effects in metals and alloys: A review*. Science Direct. Retrieved January, 2003, from

<https://www.sciencedirect.com/science/article/abs/pii/S0022311583900478#:~:text=Helium%20has%20been%20shown%20to,cavity%20radius%20concept%20is%20developed.>

McMahon, J., Morales, M., Pierleoni, C., & Ceperley, D. (2012, November 13). *The properties of hydrogen and helium under extreme conditions*. APS Physical Review Journals. Retrieved January, 2025, from <https://journals.aps.org/rmp/abstract/10.1103/RevModPhys.84.1607>

Meng, Q.-W., Cheng, L., & Ge, Q. (2023, November 27). *Recent advances and future challenges of polyamide-based chlorine-resistant membrane*. Science Direct. Retrieved January, 2025, from

<https://www.sciencedirect.com/science/article/pii/S2772823423000167>

- Midwest Tungsten Service. (n.d.). *How Tungsten Wire is Made*. Midwest Tungsten Service. Retrieved January, 2025, from <https://www.tungsten.com/blog/how-tungsten-wire-is-made>
- Monthioux, M. (2002, March 22). *Filling single-wall carbon nanotubes*. Science Direct. Retrieved January, 2025, from <https://www.sciencedirect.com/science/article/abs/pii/S0008622302001021>
- Neumann, M., & Gemert, M. (2014, January 8). *Ins and outs of endovenous laser ablation: afterthoughts*. National Library of Medicine. Retrieved January, 2025, from <https://pmc.ncbi.nlm.nih.gov/articles/PMC3953605/>
- Nosheen, A., Hussain, M., Khalid, M., Javid, A., Aziz, H., Iqbal, S., Ashraf, M., & Ali, S. (2022, July 21). *Development of protective cotton textiles against biohazards and harmful UV radiation using eco-friendly novel fiber-reactive bioactive agent*. Science Direct. Retrieved January, 2025, from <https://www.sciencedirect.com/science/article/abs/pii/S0957582022006474>
- Patel, P., Vasavada, D., & Mankodi, H. (2013, January 7). *Applications of electrically conductive yarns in technical textiles*. IEEE Xplore. Retrieved January, 2025, from <https://ieeexplore.ieee.org/abstract/document/6401374>
- Pichler, T., Knupfer, M., Golden, M. S., Fink, J., Rinzler, A., & Smalley, R. E. (1998, May 25). *Localized and Delocalized Electronic States in Single-Wall Carbon Nanotubes*. APS Physical Review Journals. Retrieved January, 2025, from <https://journals.aps.org/prl/abstract/10.1103/PhysRevLett.80.4729>
- Saifuddin, N., Raziah, A. Z., & Junizah, A. R. (2012, September 17). *Carbon Nanotubes: A Review on Structure and Their Interaction with Proteins*. Wiley Online Library. Retrieved January, 2025, from <https://onlinelibrary.wiley.com/doi/10.1155/2013/676815>

- Shkol'nik, S. M. (2011, January 25). *Anode phenomena in arc discharges: a review*. Plasma Sources Science and Technology. Retrieved January, 2025, from <https://iopscience.iop.org/article/10.1088/0963-0252/20/1/013001/meta>
- Tomada, J., & Amsharov, K. (2018, July 25). *Single-Walled Carbon Nanotube's End-Cap Engineering—Molecular Seeds for Controlled Synthesis of Chirality-Pure SWCNT*. Science Direct. Retrieved January, 2025, from <https://www.sciencedirect.com/science/article/abs/pii/B9780124095472142106>
- United States Nuclear Regulatory Commission. (2020, March 19). *What is a Geiger Counter?* Nuclear Regulatory Commission. Retrieved January, 2025, from <https://www.nrc.gov/reading-rm/basic-ref/students/science-101/what-is-a-geiger-counter.html>
- Vasilev, C. (2021, December 14). *Repelling Radiation with Carbon Nanotubes*. Azonano. Retrieved January, 2021, from <https://www.azonano.com/article.aspx?ArticleID=5916>
- Walton, J. (2023, December 27). *History Of The Geiger Counter: Radiation and Readouts*. Mira Safety. Retrieved January, 2025, from <https://www.mirasafety.com/blogs/news/history-of-the-geiger-counter-radiation?srltid=AfmBOopmwFP2Iua0gHHRdwKMLCHcExyE7mvS6dTSHB5Dw9fnFKpWOqla>
- Williams, N. (n.d.). *What are Carbon Nanotubes? Uses, Properties and Structure*. Ossila. Retrieved January, 2025, from [https://www.ossila.com/pages/what-are-carbon-nanotubes#:~:text=Carbon%20nanotubes%20\(CN Ts\)%2C%20also,diameter%20of%201%2D3%20nanometers](https://www.ossila.com/pages/what-are-carbon-nanotubes#:~:text=Carbon%20nanotubes%20(CN Ts)%2C%20also,diameter%20of%201%2D3%20nanometers).
- Zhang, Q., Huang, J.-Q., Zhao, M.-Q., Qian, W.-Z., & Wei, F. (2011, July 5). *Carbon Nanotube Mass Production: Principles and Processes*. European Chemical Societies Publishing. <https://chemistry-europe.onlinelibrary.wiley.com/doi/abs/10.1002/cssc.201100177>