



SERVICE REPORT PANEL PDU
PT. DWI MITRA EKATAMA MANDIRI
JL. Alaydrus, 45-45-B, Jakarta, 10130 (021) 6332316



Customer								
Company name	NeutraDC Cikarang	Type	Standing	Specification	400 A	MOP No.	DME-TDE/MOP/PDU/01	
Equipment Name	PANEL PDU	Serial No.	21W00038			Quarter	08/01/2026	
CI Description	IT LOAD	Product Name	GSPE	Location	Crac Room 1	Date		
CI Name		Prod.Year	2021	Area	Campus	Engineer / Technician		
Inspection / Checking								
No	Activity	Parameter	Condition	Remarks				
1	Inspection unsafe action and unsafe condition before start activity maintenance	Complete personal protective equipment	Good	Not Good				
2	Check cable grounding to act know voltage in body panel. Measurement current and resistance using claim earth	tight	Good	Not Good				
3	Inspection & check visual all support panel like a condition paint panel, pilot lamp, chassis panel, padlock system and cleaning using vacuum cleaner.	does not peel or rust	Good	Not Good				
4	Inspection & check status breaker incoming and outgoing, cable wiring panel, and fuse	The cable terminals are not loose,	Good	Not Good				
5	Inspection relay, power supply unit, measurement voltage	Good Condition	Good	Not Good				
6	Inspection visual tightness all connection cable in terminal cable, label marking, terminal breaker and all mounting nut.	tight	Good	Not Good				
7	Check condition connection cable using thermal imager if the found anomaly like a hot spot on the connection.	Normally <45°C (depending on rating), make sure not to exceed manufacturer standards.	Good	Not Good				
8	Cleaning panel used vacuum cleaner and apply sanpoly to finish it	Good condition & clean	Good	Not Good				
9	Inspection and check visual trafo isotrans with analysis condition temperature operational trafo using thermal imager and measurement noise with sound level	Normally <70 dB(dependent on rating), make sure not to exceed manufacturer standards.	Good	Not Good				
10	Cleaning, remove object from top of controller	There are no dangerous foreign objects on the controller panel.	Good	Not Good				
11	Inspection DPM, and ensure measurement on reading in DPM. Take a photo	All parameter ready reading in DPM	Good	Not Good				
Cleaning								
1	Cleaning support panels using a vacuum cleaner	Clean						
2	Clean the panel with a vacuum and apply sanpoly.	Clean						
Digital Power Meter Recording								
Wire	Result (Ampere)	Wire	Result	Wire	Result (Voltage)	Wire	Result (Voltage)	Remarks
R		KW		R-S		R-N		
S		KVA		S-T		S-N		
T		KVAR		T-R		T-N		
N		Cos p				N-G		
Temperature Monitoring ISO- Trans								
	Result (°C)	Standard	Remarks					
R		Temperature < 45 °C						
S								
T								
Voltage & Ampere Measurement								
Wire	Result (Voltage)	Wire	Result (Voltage)	Wire	Result (Ampere)	Remarks		
R-S		R-N		R				
S-T		S-N		S				
T-R		T-N		T				
		N-G		N				
Thermal Measurement								
Breaker	Result Temperature (°C)	Standard	Remarks					
		Temperature < 45 °C						
Grounding Resistance Measurement								
Wire	Result (Ω)	Standard	Remarks					
Grounding		<5Ω						
Noise Measurement								
	Result (dB)	Standard	Remarks					
Measurement		<75 dB						
Analysis/Remark								
☐ Normal operation			Remark :					
☐ Abnormal operation			Fault symptom					
(Please fill the items if the service is repair)			Fault analysis					
			Work done/					
			action taken					
			Fault Part SN					
			Fault part Name					
TIME SPENT								
Date	Departure			Start		Finish		
CUSTOMER ACKNOWLEDGEMENT:								
Prepared			Checked			Approved		

Engineer

SM/PM

Client / Owner