

INSPECTION DOCKET

AIKO

Ambli, Ahmedabad, Gujarat

Internal maintenance walk-through · 17 September 2026

OVERALL SCORE

70.8%

46 of 65 points

NEEDS IMPROVEMENT

OUTLET / BRAND

AIKO

LOCATION

Ambli, Ahmedabad, Gujarat

CATEGORY

Restaurant

REPORT TYPE

Internal maintenance
walk-through

INSPECTION DATE

17 September 2026

INSPECTED & PREPARED BY

Vishal Patel

At a glance

Check points
reviewed

65

Compliant

41

Observation
(partial)

10

Non-compliant



14

Critical items
failed

10

Score by category

■ 80% and above ■ 50-79% ■ below 50%



Score per check point: OK 1 · OBS 0.5 · NC 0. Category and overall scores are the share of points available.

Inspector's summary

The walk-through evaluated all 65 applicable check points. AIKO scored 46 of 65 — 70.8% — which sits in the **Needs Improvement** band.

Weakest areas: PM Records / Safety Training **0%**, Energy Efficiency **0%**, HVAC **33%**, Fire & Life Safety **40%**, Refrigeration **50%**, Waste / Housekeeping **50%**.

- 1** Close the fire-safety gaps first — alarm panel fault, missing emergency exit, no drill or training on record. These carry the highest life-safety and legal exposure.
- 2** Replace or repair equipment marked completely non-functional — the missing thermometer (#39) and the dishwasher (#32) block food-safety checks entirely.
- 3** Start a PM and energy-tracking log; both categories currently score 0%.
- 4** Tighten housekeeping — cover the waste bins and clean the garbage area (#61), and label all cleaning chemicals (#63).
- 5** Re-audit three to four weeks after the above are closed.

Critical — act within 48 hours

10 critical check points failed

NO.	CHECK POINT	AREA	REMARK	EVIDENCE
#5	Water test report (IS 10500) within limits and current	A · Statutory Documents	No report available	
#11	Main distribution board clean, closed and labelled	C · Electrical / Power		
#32	Dishwasher - wash/rinse temperature and cycle correct	G · Kitchen Equipment (Electric)	Not working	
#35	Walk-in chiller/freezer temperature maintained per log	H · Refrigeration		
#39	Thermometer/probe calibration record current	H · Refrigeration	No thermometer available	
#41	Water tank covered, clean, no overflow	I/J · Plumbing / RO Water		
#49	Fire alarm panel fault-free, battery healthy	L · Fire & Life Safety	No alarm	
#50	Emergency exit and signage unobstructed, illuminated	L · Fire & Life Safety	No emergency exit door	
#51	Fire drill conducted, staff able to operate extinguisher	L · Fire & Life Safety	Fire drill not conducted, training not given	
#64	Staff safety training (electrical/fire) record current	S/T · PM Records / Safety Training	No training given	

Full checklist, by category

OK compliant **OBS** observation (partial) **NC** non-compliant

A · Statutory Documents				7 items · 71%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE
1	FSSAI licence valid, correct address, and displayed	Critical	OK	
2	Fire NOC / Fire Safety Certificate valid	Critical	OK	
3	Electrical installation and load sanction documents available	High	OBS	Needs to be verified from accounts
4	Trade / Shop licence valid	High	OBS	Needs to be verified from accounts
5	Water test report (IS 10500) within limits and current	Critical	NC	No report available
6	Pest control contract and service report current	High	OK	
7	Staff medical fitness record current	High	OK	
B · Civil / Building				3 items · 83%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE
8	No cracks, dampness or fungus on walls/ceiling	High	OK	
9	Floor/tiles safe, no broken or slippery areas	High	OBS	
10	Doors/windows sealed against pest entry	High	OK	
C · Electrical / Power				10 items · 80%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE
11	Main distribution board clean, closed and labelled	Critical	NC	
12	MCB/RCCB/ELCB installed, rated and trip-tested	Critical	OK	
13	Earthing system tested and within limits	Critical	OK	
14	Cable/wiring not damaged, loose or exposed	Critical	OBS	
15	Sockets/switches/plugs correctly rated, protected in wet areas	High	OBS	
16	Load balance – phase current within capacity, no repeated tripping	High	OK	
17	Clearance in front of panel, rubber mat and shock chart available	High	OK	
18	Emergency/exit lighting working on backup	Critical	OK	
19	Local isolator available for each fixed appliance	High	OK	
20	Surge protection (for POS/IT load)	Low	OK	

D · HVAC					3 items · 33%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE	
21	Split/cassette AC performance adequate, filter clean	High	OK		
22	Condensate drain – no leakage or dripping	High	NC		
23	Air curtain at entrance working across full width	High	NC		
E · Exhaust / Hood					4 items · 88%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE	
24	Hood captures smoke/steam effectively	Critical	OK		
25	Hood baffle filter clean and properly fitted	Critical	OBS		
26	Grease build-up in exhaust duct within limits, deep-clean current	Critical	OK		
27	Exhaust fan/motor – no overheating or abnormal noise	Critical	OK		
G · Kitchen Equipment (Electric)					7 items · 79%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE	
28	Induction/electric range – controls and wiring safe	High	OBS		
29	Deep fryer – thermostat and high-limit cut-out working	Critical	OK		
30	Electric oven/combi oven – heating and door seal serviceable	High	OK		
31	Mixer/grinder/processor – guard and interlock working	High	OK		
32	Dishwasher – wash/rinse temperature and cycle correct	Critical	NC	Not working 	
33	Ice machine – cleanliness and performance proper	Critical	OK		
34	All equipment stable, hot/moving parts guarded	High	OK		
H · Refrigeration					5 items · 50%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE	
35	Walk-in chiller/freezer temperature maintained per log	Critical	NC		
36	Door gasket seals and door self-closes	High	OBS	Door does not close by itself	
37	Condenser clean, airflow unobstructed	High	OK		
38	High-temperature alarm/monitoring working	Critical	OK		
39	Thermometer/probe calibration record current	Critical	NC	No thermometer available	

I/J · Plumbing / RO Water				4 items · 63%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE
40	Water pressure and supply adequate at peak	High	OK	
41	Water tank covered, clean, no overflow	Critical	NC	
42	RO TDS reading logged daily and within limits	Critical	OBS	No record available
43	Drinking water points clean and sanitised	High	OK	
K · Drainage / Grease Trap				3 items · 100%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE
44	Floor drain/grating flowing freely, no blockage	High	OK	
45	Grease trap clean, per schedule, no overflow	Critical	OK	
46	No drain odour or sewer backflow	Critical	OK	
L · Fire & Life Safety				5 items · 40%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE
47	Fire extinguisher charged, seal intact, in date	Critical	OK	
48	Kitchen hood suppression system serviced and unobstructed	Critical	OK	
49	Fire alarm panel fault-free, battery healthy	Critical	NC	No alarm
50	Emergency exit and signage unobstructed, illuminated	Critical	NC	No emergency exit door
51	Fire drill conducted, staff able to operate extinguisher	Critical	NC	Fire drill not conducted, training not given
M/N · Washroom / Pest Prevention				3 items · 100%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE
52	Hand wash station – soap, hot/running water, signage complete	Critical	OK	
53	Washroom ventilation and drainage working, no odour	High	OK	
54	No signs of pest activity (ILT / bait station check)	Critical	OK	
O/P · FOH / IT-POS				3 items · 100%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE
55	Dining furniture and guest floor safety proper	High	OK	
56	CCTV – all cameras live, recording and retention current	High	OK	
57	POS/KOT printer working, data backup current	High	OK	

Q · Backup Power / Utilities					3 items · 100%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE	
58	UPS/inverter healthy, backup time tested	Critical	OK		
59	DG set weekly test run, stable under load	Critical	OK		
60	Mains-DG changeover/ATS working safely	Critical	OK		
R · Waste / Housekeeping					3 items · 50%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE	
61	Waste bins covered, garbage area clean and pest-free	High	NC		
62	Cleaning schedule followed, record maintained with signature	High	OK		
63	Cleaning chemicals labelled, stored safely away from food	Critical	OBS	Some items are not labelled	
S/T · PM Records / Safety Training					1 item · 0%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE	
64	Staff safety training (electrical/fire) record current	Critical	NC	No training given	
U · Energy Efficiency					1 item · 0%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE	
65	Doors self-closing / condenser clean – energy loss avoided	Medium	NC		

Status corrections

Changed where the remark did not support the mark

NO.	CHECK POINT	WAS	NOW	WHY
3	Electrical installation and load sanction documents available	OK	OBS	Remark noted the document still needs verification from accounts — cannot count as fully compliant.
63	Cleaning chemicals labelled, stored safely away from food	OK	OBS	Remark said some items are unlabelled — a partial defect, not full compliance.
32	Dishwasher – wash/rinse temperature and cycle correct	OBS	NC	Remark said the equipment is not working — a complete failure, not a partial one.
39	Thermometer/probe calibration record current	OBS	NC	Remark said no thermometer is available at all — calibration is impossible without the instrument.