

INSPECTION DOCKET

CAPICHE

Vesu, Surat, Gujarat

Internal maintenance walk-through · 22 September 2026

OVERALL SCORE


77.7%

50.5 of 65 points

NEEDS IMPROVEMENT


OUTLET / BRAND CAPICHE	LOCATION Vesu, Surat, Gujarat	CATEGORY Restaurant
REPORT TYPE Internal maintenance walk-through	INSPECTION DATE 22 September 2026	INSPECTED & PREPARED BY Vishal Patel

At a glance



Score by category

■ 80% and above ■ 50-79% ■ below 50%



Score per check point: OK 1 · OBS 0.5 · NC 0. Category and overall scores are the share of points available.

Inspector's summary

The walk-through evaluated all 65 applicable check points. CAPICHE scored 50.5 of 65 — 77.7% — which sits in the **Needs Improvement** band.

Weakest areas: PM Records / Safety Training **0%**, Energy Efficiency **0%**, HVAC **50%**.

- 1 Complete the refrigeration temperature log (#35) — a critical gap for food-safety traceability.
- 2 Fix the emergency exit and conduct fire drill/training (#50, #51) — highest life-safety and legal exposure.
- 3 Start staff safety training records (#64) and a PM/energy-tracking log — both currently at zero.
- 4 Review civil/building and drainage items flagged in the 60–70% range for medium-priority repairs.
- 5 Re-audit three to four weeks after the above are closed.

Critical — act within 48 hours

4 critical check points failed

NO.	CHECK POINT	AREA	REMARK	EVIDENCE
#35	Walk-in chiller/freezer temperature maintained per log	H · Refrigeration	No log maintained	
#50	Emergency exit and signage unobstructed, illuminated	L · Fire & Life Safety	No emergency exit door	
#51	Fire drill conducted, staff able to operate extinguisher	L · Fire & Life Safety	Fire drill not conducted, training not given	
#64	Staff safety training (electrical/fire) record current	S/T · PM Records / Safety Training	No training given	

Full checklist, by category

OK compliant **OBS** observation (partial) **NC** non-compliant

A · Statutory Documents					7 items · 86%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE	
1	FSSAI licence valid, correct address, and displayed	Critical	OK		
2	Fire NOC / Fire Safety Certificate valid	Critical	OK		
3	Electrical installation and load sanction documents available	High	OBS	Needs to be verified from accounts	
4	Trade / Shop licence valid	High	OBS	Needs to be verified from accounts	
5	Water test report (IS 10500) within limits and current	Critical	OK		
6	Pest control contract and service report current	High	OK		
7	Staff medical fitness record current	High	OK		

B · Civil / Building					3 items · 67%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE	
8	No cracks, dampness or fungus on walls/ceiling	High	OK		
9	Floor/tiles safe, no broken or slippery areas	High	NC		
10	Doors/windows sealed against pest entry	High	OK		
C · Electrical / Power					10 items · 90%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE	
11	Main distribution board clean, closed and labelled	Critical	OK		
12	MCB/RCCB/ELCB installed, rated and trip-tested	Critical	OK	It's the building's own supply, so it trips directly (confirmed fine)	
13	Earthing system tested and within limits	Critical	OK		
14	Cable/wiring not damaged, loose or exposed	Critical	OBS		
15	Sockets/switches/plugs correctly rated, protected in wet areas	High	OBS		
16	Load balance – phase current within capacity, no repeated tripping	High	OK		
17	Clearance in front of panel, rubber mat and shock chart available	High	OK		
18	Emergency/exit lighting working on backup	Critical	OK		
19	Local isolator available for each fixed appliance	High	OK		
20	Surge protection (for POS/IT load)	Low	OK		
D · HVAC					3 items · 50%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE	
21	Split/cassette AC performance adequate, filter clean	High	OBS		
22	Condensate drain – no leakage or dripping	High	OK		
23	Air curtain at entrance working across full width	High	NC	Sensor not working properly 	

E · Exhaust / Hood					4 items · 75%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE	
24	Hood captures smoke/steam effectively	Critical	OK		
25	Hood baffle filter clean and properly fitted	Critical	OBS		
26	Grease build-up in exhaust duct within limits, deep-clean current	Critical	OBS		
27	Exhaust fan/motor – no overheating or abnormal noise	Critical	OK		
G · Kitchen Equipment (Electric)					7 items · 86%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE	
28	Induction/electric range – controls and wiring safe	High	OK		
29	Deep fryer – thermostat and high-limit cut-out working	Critical	OK		
30	Electric oven/combi oven – heating and door seal serviceable	High	OBS		
31	Mixer/grinder/processor – guard and interlock working	High	OBS	 Push button not working properly	
32	Dishwasher – wash/rinse temperature and cycle correct	Critical	OK		
33	Ice machine – cleanliness and performance proper	Critical	OK		
34	All equipment stable, hot/moving parts guarded	High	OK		
H · Refrigeration					5 items · 70%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE	
35	Walk-in chiller/freezer temperature maintained per log	Critical	NC	 No log maintained	
36	Door gasket seals and door self-closes	High	OBS	 Door does not close by itself	
37	Condenser clean, airflow unobstructed	High	OK		
38	High-temperature alarm/monitoring working	Critical	OK		
39	Thermometer/probe calibration record current	Critical	OK		

I/J · Plumbing / RO Water				4 items · 88%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE
40	Water pressure and supply adequate at peak	High	OK	
41	Water tank covered, clean, no overflow	Critical	OK	It's the building's shared tank
42	RO TDS reading logged daily and within limits	Critical	OBS	No record available
43	Drinking water points clean and sanitised	High	OK	
K · Drainage / Grease Trap				3 items · 67%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE
44	Floor drain/grating flowing freely, no blockage	High	OBS	
45	Grease trap clean, per schedule, no overflow	Critical	OBS	
46	No drain odour or sewer backflow	Critical	OK	
L · Fire & Life Safety				5 items · 60%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE
47	Fire extinguisher charged, seal intact, in date	Critical	OK	
48	Kitchen hood suppression system serviced and unobstructed	Critical	OK	
49	Fire alarm panel fault-free, battery healthy	Critical	OK	
50	Emergency exit and signage unobstructed, illuminated	Critical	NC	No emergency exit door
51	Fire drill conducted, staff able to operate extinguisher	Critical	NC	Fire drill not conducted, training not given
M/N · Washroom / Pest Prevention				3 items · 100%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE
52	Hand wash station – soap, hot/running water, signage complete	Critical	OK	
53	Washroom ventilation and drainage working, no odour	High	OK	
54	No signs of pest activity (ILT / bait station check)	Critical	OK	
O/P · FOH / IT-POS				3 items · 83%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE
55	Dining furniture and guest floor safety proper	High	OBS	
56	CCTV – all cameras live, recording and retention current	High	OK	
57	POS/KOT printer working, data backup current	High	OK	

Q · Backup Power / Utilities				3 items · 100%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE
58	UPS/inverter healthy, backup time tested	Critical	OK	
59	DG set weekly test run, stable under load	Critical	OK	
60	Mains-DG changeover/ATS working safely	Critical	OK	
R · Waste / Housekeeping				3 items · 83%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE
61	Waste bins covered, garbage area clean and pest-free	High	OK	
62	Cleaning schedule followed, record maintained with signature	High	OK	
63	Cleaning chemicals labelled, stored safely away from food	Critical	OBS	Some items are not labelled
S/T · PM Records / Safety Training				1 item · 0%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE
64	Staff safety training (electrical/fire) record current	Critical	NC	No training given
U · Energy Efficiency				1 item · 0%
NO.	CHECK POINT	CRITICALITY	STATUS	REMARK / EVIDENCE
65	Doors self-closing / condenser clean - energy loss avoided	Medium	NC	

Status corrections

Changed where the remark did not support the mark

NO.	CHECK POINT	WAS	NOW	WHY
3	Electrical installation and load sanction documents available	OK	OBS	Remark noted the document still needs verification from accounts — cannot count as fully compliant.
4	Trade / Shop licence valid	OK	OBS	Remark noted the document still needs verification from accounts — cannot count as fully compliant.
63	Cleaning chemicals labelled, stored safely away from food	OK	OBS	Remark said some items are unlabelled — a partial defect, not full compliance.