

Test Report


Customer Details

AG Facilities Solutions for Building Maintenance LLC

FOR CONTRACTING AND GENERAL MAINTENANCE LLC P.O. Box: 283307

Danube Bldg. Shk. Zayed Rd., Dubai, UAE Tel.: 046052633 Tel.: 045217987

Report No. WD-R-260421-0222



Request No. : WD-Q-260421-0046

Received Date : 21/04/2026

Sample No. : WD-S-260421-0920

Sampling Date	: 21/04/2026	Report Date.	: 25/04/2026
Analysis Start Date.	: 21/04/2026	Analysis End Date.	: 25/04/2026
Sample Location.	: Dubai Safari Park, Dubai - United Arab Emirates	Sampled By	: Adnan
Sample Identification	: Tank Water	Sampling Method	: WMGP-APHA9060A 24th Edition
Temperature °C	: 30.4	Source of Sample	: Water Tank
Sampling Point	: Gate Number 2 - GRP Water Tank	Sample Description	: Domestic Water
Sampling Apparatus	: Sterile PET Bottle	Sample volume	: 500ml
Neutralizer	: Sodium Thiosulfate##	Sampling Time	: 06:00 am
Samplerrefno	: M1	Mode of Transportation	: Refrigerated Vehicle of Samples

Parameters	Test Methods	Units	Results	Specification	MOU
Enterococci	BS EN ISO 7899:2	CFU/ 100ml	<1	Zero	6.46%
Escherichia coli	APHA 9222 I	CFU/ 100ml	<1	Zero	7.06%
Staphylococcus aureus #	APHA 9213 B	CFU/ 100ml	<1	Zero	-
Total Coliforms	APHA 9222B	cfu/ 100ml	<1	Zero	7.06%
Total Bacterial Count-TBC	APHA 9215B	CFU/ ml	<1	500*	6.99%
Pseudomonas aeruginosa.	APHA 9213E	CFU/ 100ml	<1	Zero	7.32%
Fecal Coliform	APHA 9222 D	CFU/ 100ml	<1	Zero	6.52%

Note : Specification Reference:

*Dubai Municipality Health and Safety Department Environmental Health Section; Technical Guidelines for Legionella Control in water System; DM-HSD-GU44-LCWS2; 2024.

(Guidelines value for TBC is not available in GSO 149/2021 specification).

GCC Standardization Organization (GSO):GSO149/2021 (E): un-bottled drinking water.

Remarks :Statement of Compliance:-

The microbiological status of the above test results are within the limits of Specifications.

Analyst	Reviewed By	Method Variation
AMJ	Amanullah	None

Key Words :CFU-Colony Forming Units, APHA (American Public Health Association)- Standard method for the Examination of water and waste water 24th Edition; ISO-International Organization for Standardization, <1 is considered as "NotDetected" or "Zero".

MOU=Measurement Uncertainty. Employed Decision Rule: Simple acceptance applied for qualitative analysis & zero-value specifications, and for other types of specification values, binary acceptance based on the guard banding formula shall be applied.

#-Not accredited by EIAC.

##- Amount of neutralizer added as per SOP-WMGP 18



Test Report

Report No. : WD-R-260421-0222

Signed for and on behalf of Wimpey Laboratories

Sreya Satheesan P
Senior Microbiologist



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WRF2-W-001 Issue No.:01 Rev No:00 Issued Date:19-05-2020

- End of Text -