

Test Report

Customer Details

AG Facilities Solutions for Building Maintenance LLC

FOR CONTRACTING AND GENERAL MAINTENANCE LLC P.O. Box: 283307

Danube Bldg. Shk. Zayed Rd., Dubai, UAE Tel.: 046052633 Tel.: 045217987

Report No. WD-R-260421-0235



Request No. : WD-Q-260421-0046

Received Date : 21/04/2026

Sample No. : WD-S-260421-0933

Sampling Date	: 21/04/2026	Report Date.	: 03/05/2026
Analysis Start Date.	: 21/04/2026	Analysis End Date.	: 03/05/2026
Sample Location.	: Dubai Safari Park, Dubai - United Arab Emirates	Sampled By	: Adnan
Sample Identification	: Tank Water	Sampling Method	: BS7592 SECTION2
Temperature °C	: 30.4	Source of Sample	: Water Tank
Sampling Point	: Gate Number 2 - GRP Water Tank	Sample Description	: Domestic Water
Sampling Apparatus	: Sterile PET Bottle	Sample volume	: 1000ml
Neutralizer	: 1ml 180mg Na2S2O3	Sampling Time	: 06:00 am
Samplerrefno	: L1	Mode of Transportation	: Refrigerated Vehicle of Samples

Parameters	Test Methods	Units	Results	Specification	MOU
Enumeration of legionella	ISO 11731	CFU/L	Not Detected	<1000	7.02%

Note : Confirmatory Identification Test

Legionella species Absent

Legionella pneumophila serotype1 Absent

Legionella pneumophila serotype 2-15 Absent

Specification:

Dubai Municipality Health and Safety Department Environmental Health Section; Technical

Guidelines for Legionella Control in Water System; DM-HSD-GU44-LCWS2;2024

Test Procedure: 7, Medium Used: BCYE+Cys+GVPC

Sample Volume filtered is 250 ml & Detection limit is 4 cfu/l.

Remarks :Statement of Compliance:

The sample analyzed is of satisfactory quality with respect to above tested parameters.

Analyst	Reviewed By	Method Variation
SC	Amanullah	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization.

MOU=Measurement Uncertainty. Employed Decision Rule: Simple acceptance applied for qualitative analysis & zero-value specifications, and for other types of specification values, binary acceptance based on the guard banding formula shall be applied.

Signed for and on behalf of Wimpey Laboratories



Sreya Satheesan P

Senior Microbiologist



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WRF2-W-002 Issue No.:01 Rev No:00 Issued Date:19-05-2020

- End of Text -