

Test Report

Customer Details

AG Facilities Solutions for Building Maintenance LLC

FOR CONTRACTING AND GENERAL MAINTENANCE LLC P.O. Box: 283307

Danube Bldg. Shk. Zayed Rd., Dubai, UAE Tel.: 046052633 Tel.: 045217987

Report No. WD-R-260616-0203



Request No. : WD-Q-260616-0045

Received Date : 16/06/2026

Sample No. : WD-S-260616-0706

Sampling Date	: 16/06/2026	Report Date.	: 22/06/2026
Analysis Start Date.	: 16/06/2026	Analysis End Date.	: 22/06/2026
Sample Location.	: Dubai Safari Park- Dubai, UAE	Sampled By	: Adnan
Sample Identification	: Water Body	Sampling Method	: APHA 1060B #
Temperature °C	: 26	Source of Sample	: Others
Sampling Point	: Asian Village AV-03 Gibbon Moat Circulation	Preservation	: Cool Box
Sample Description	: Water Body	Sampling Apparatus	: Sterile PET Bottle
Sampling Time	: 01:50 PM	Mode of Transportation	: Refrigerated Vehicle of Samples

Parameters	Test Methods	Units	Results	LOQ
Sulfate. #	HACH 8051	mg/L	11.3	0.02
Nitrate. #	HACH 8039	mg/L	4.9	0.02
Fluoride #	HACH 8029	mg/L	Not detected	0.02
Zinc	APHA 3120 B	mg/L	Not detected	0.01
Ammonia-N #	APHA 4500 NH3 B/ 4500 NH3 C	mg/L	<0.5	0.5
Vanadium #	APHA 3120 B	mg/L	Not detected	0.05
Turbidity #	APHA 2130B	NTU	8.9	1
Total Dissolved Solids(TDS)	APHA 2540 C	mg/L	311	10
Total Alkalinity as CaCO3	APHA 2320 B	mg/L	58	1
Sodium	APHA 3120 B	mg/L	73.6	0.1
Phosphate, #	HACH 8048	mg/L	Not detected	0.02
pH @25°C	APHA 4500 H+B	-	8.28	-
Nitrite #	HACH 8507	mg/L	<0.02	0.02
Nickel(Ni)	APHA 3120 B	mg/L	Not detected	0.01
Mercury(Hg) #	ICP-AES	mg/L	Not detected	0.01
Lead (Pb)	APHA 3120 B	mg/L	Not detected	0.03
Copper(Cu)	APHA 3120 B	mg/L	Not detected	0.01
Cobalt (Co)	APHA 3120 B	mg/L	Not detected	0.01
Chromium(Cr)	APHA 3120 B	mg/L	Not detected	0.01
Cadmium (Cd)	APHA 3120 B	mg/L	Not detected	0.01
Boron #	APHA 3120 B	mg/L	Not detected	0.05
Arsenic(As)	APHA 3120 B	mg/L	Not detected	0.02
Aluminium (Al)	APHA 3120 B	mg/L	Not detected	0.05

Analyst	Reviewed By	Method Variation
AMS	RM	None

Test Report

Report No. : WD-R-260616-0203

Key Words :APHA (American Public Health Association) - Standard method for the Examination of water and wastewater 24th Edition

#Not accredited by EIAC

Not detected is considered as below LOD

Signed for and on behalf of Wimpey Laboratories



Rin Mary Thomas

Section In-charge – Chemistry (Water)

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WRF1-W-001 Issue No.:01 Rev No:00 Issued Date:19-05-2020

- End of Text -