

TEST REPORT

Customer Name	: DXB Entertainments PJSC	
Address	: Sheikh Zayed Road, Opposite Palm Jebel Ali, Exit 5, Saih Shuaib, PO Box 33772, Dubai, UAE	Report no.: DR25-044368-1
Contact person	: Mr. Rajeevkumar Nair	
Project	: Evaporation Pond in Resort Wide	
Project No.	: -	Job No. : DJ25-035112
Contract/LPO No.	: PO-00001351	Sample No. : DS25-044368
Project location	: Resort Wide, DPR	Report Date : 22/10/2025
Test location	: AHSL - DXB	Test Date : 17/10/2025-24/10/2025
Sample description	: Pond Water	Sampled by : AHSL Representative
Sampling method	: Grab (SOP #CHEM-009)	Source of sample : Ground Water
Sampling location	: RTA Pond 2	Sampling Date&Time : 17/10/2025 10:50 AM
On-site treatment	: Sample Transported In Ice Box	Sample container : PET Bottle
Received Date&Time	: 17/10/2025 06:52 PM	Sample Quantity : 1000ML
Sample delivered by	: AHSL Representative	

TEST RESULTS

Test Parameter	Test Method	Unit	MoU	MDL	Result
pH at 25 °C	^A APHA 4500 – H+B; 24th Ed	-	±0.08	0.10	7.99
Total Suspended Solids103-105 °C (TSS)	^A APHA 2540D; 24th Ed	mg/L	-	5.0	< 5
Chemical Oxygen Demand (COD)	^A APHA 5220B; 24th Ed	mg/L	±0.71	10	29.8
Biochemical Oxygen (BOD) (5 days @ 20 °C)	^A APHA 5210B; 24th Ed	mg/L	±0.68	5.0	6.75
Ammonia-Nitrogen (NH3-N)	HACH 8038/04/2017 Ed 9	mg/L	±0.02	0.10	0.35
Sulphide	^A HACH 8131	mg/L	-	0.05	< 0.05
Copper (Cu)	^A APHA 3120 B; 24th Ed	mg/L	-	0.01	< 0.01
Cadmium (Cd)	^A APHA 3120 B; 24th Ed	mg/L	-	0.01	< 0.01
Nickel (Ni)	^A APHA 3120 B; 24th Ed	mg/L	-	0.01	< 0.01
Manganese (Mn)	^A APHA 3120 B; 24th Ed	mg/L	±0.0007	0.01	0.01
Lead (Pb)	^A APHA 3120 B; 24th Ed	mg/L	-	0.01	< 0.01
Zinc (Zn)	^A APHA 3120 B; 24th Ed	mg/L	±0.001	0.01	0.02
Chromium (Cr)	^A APHA 3120 B; 24th Ed	mg/L	±0.002	0.01	0.04
Turbidity	^A APHA 2130 B; 24th Ed	NTU	±0.19	0.10	1.96
Nitrate Nitrogen (NO3-N)	HACH 8192	mg/L	±0.02	0.01	0.31
Phosphate (PO43-)	^A HACH 8048	mg/L	±0.01	0.06	0.36
Fluoride	^A HACH 8029/08/2018 Ed 10	mg/L	±0.09	0.05	0.91

Tested by : EM00738,EM00499,EM00533,EM00687,EM00715

Verified by : EM00533

Test Method Variations : None

Remarks : None

^A Indicates AHSL Dubai is accredited by EIAC (LB-TEST-001)

MDL- Method Detection Limit MoU - Measurement of uncertainty. The reported expanded uncertainty is based on standard uncertaintymultiplied by a coverage factor K=2, Providing a level of confidence of approximately 95%.

This report relates only to the sample tested and shall only be reproduced in full and with the written approval of AHS laboratories

TR/CM G6/Rev00

Page 1 of 2

Report no.: DR25-044368-1

ABU DHABI, U.A.E.
P.O. BOX 31039
TEL.: (02) 5542234
FAX : (02) 5547015

DUBAI, U.A.E
P.O. BOX 16756
TEL.: (04) 3472201

JEBEL ALI, U.A.E.
P.O. BOX 16756
TEL.: (04) 8818461

RAS AL KHAIMAH, U.A.E.
P.O. BOX 34987
TEL.: (07) 2432328

KALBA, SHARJAH, U.A.E.
P.O. BOX 145133
TEL.: (09) 2779543

E-mail : alhoty@alhotystanger.ae, Website : www.alhotystangeruae.com

TEST REPORT

Customer Name : DXB Entertainments PJSC



Report no.: DR25-044368-1



(Signature)

Approved by : Mr. Saneesh S G, Senior Chemist

THIS IS A COMPUTER GENERATED REPORT AND NO SIGNATURE REQUIRED

الحوطي
ALHOTY

This report relates only to the sample tested and shall only be reproduced in full and with the written approval of AHS laboratories

TR/CM G6/Rev00

Page 2 of 2

Report no.: DR25-044368-1

ABU DHABI, U.A.E.
P.O. BOX 31039
TEL.: (02) 5542234
FAX : (02) 5547015

DUBAI, U.A.E
P.O. BOX 16756
TEL.: (04) 3472201

JEBEL ALI, U.A.E.
P.O. BOX 16756
TEL.: (04) 8818461

RAS AL KHAIMAH, U.A.E.
P.O. BOX 34987
TEL.: (07) 2432328

KALBA, SHARJAH, U.A.E.
P.O. BOX 145133
TEL.: (09) 2779543

E-mail : alhoty@alhotystanger.ae, Website : www.alhotystangeruae.com