

Project: Battery Place Paving

Date: 10/25/2013

Engineer: KS Engineers

RE: Addenda #1
of Pages: 1

The following revisions and/or clarifications are to be made to the proposal documents for "(Insert project name)". They are a result of issues discussed at the pre-proposal conference held on ("insert date of pre-bid conference") and any questions received by close of business of same date (insert date again or insert correct date).

Clarifications:

1. Attached is Addenda to schedule of values
- 2.
- 3.
- 4.

.

:

:

Questions: (answers to all question are shown in Italics immediately after the question) for example:

1. During the pre-bid meeting today, the KSE Engineer stated that the asphalt would be an I-mix as per NYS specifications(or at least that is what I understood). However, the drawings and specifications for this project state HMA Type 6 Top Course. Please confirm that the asphalt will be Type 6." *There was no discussions of using I-mix in the pre-bid meeting. Contract Drawings and Contract Proposals are specifying to utilize DOT Item:*

1254/11-09 Hot Mix Asphalt Type 6 Top Course (403.178902 DOT) ton

There will be NO CHANGES to the HMA mix.

2. After performing calculations for the project I'm trying to understand where 550 tons of asphalt is going to be used. According to my calculations the 2" to be replaced after milling would take approximately 65 tons of asphalt. That would leave 485 tons unaccounted for, and i can see using that much to wedge and level the area. *The total area of pavement to be replaced is:*

*4,500 sq ft X 110 lb/sq yd/inch / 9 sq ft/yd / 2000 lb/ton X 2 inches thick top = **55.00 Ton***

3. Does the "Request for Great Plains Vendor Maintenance" form need to be filled out by the bidder? *No*

By signing the line below, I am acknowledging that all pages of the addenda has been received reviewed and understood, and will be incorporated into the bid price submitted. This document must be attached to the proposal for consideration.

Print Name

Signature

Date

Number of pages received: _____<fill in>

Distributed to: All present and all prospective Proposers

Addenda No.: 1

Due to typo in placing decimal points the following action must be taken:

Delete Quantity:

<u>Item Number:</u>	<u>Item Description:</u>	<u>Unit:</u>	<u>Quantity:</u>	<u>Price per Unit:</u>	<u>Total per Item:</u>
1254/11-09	Hot Mix Asphalt Type 6 Top Course	Ton	550.00		

Insert Quantity

<u>Item Number:</u>	<u>Item Description:</u>	<u>Unit:</u>	<u>Quantity:</u>	<u>Price per Unit:</u>	<u>Total per Item:</u>
1254/11-09	Hot Mix Asphalt Type 6 Top Course	Ton	55.00		