

Project: Tear Drop Park Deck Wood Repair **Date:** February 19, 2013

Engineer: Ensign Engineer **RE:** Addenda #2
of Pages: 2

The following revisions and/or clarifications are to be made to the proposal documents for "(Insert project name)". They are a result of issues discussed at the pre-proposal conference held on ("insert date of pre-bid conference") and any questions received by close of business of same date (insert date again or insert correct date).

Clarifications:

1. Attached is the sign in sheet from the pre proposal meeting
- 2.
- 3.
- 4.

Questions: (answers to all question are shown in *Italics* immediately after the question) for example:

1. Detail 3 on bid drawing A104 shows existing guardrail. Please advise if this guardrail should be removed during repair work and reinstalled. If yes, please advise which item on unit prices schedule this work should be included. *The guardrails are supported independently from the structural support for the decking and do not need to be removed for the deck repair*
2. Dimensions of lumber shown on bid documents are nominal sizes and actual sizes will be slightly less. For example 4"x6" lumber in actuality is 3 1/2"x5 1/2", 2"x6" in actuality is 1 1/2" x 5 1/2". Please advise if it will be acceptable. *Yes, these sizes are acceptable*
3. According to the bid documents, contractor to reinstall IPE decking with the current underside facing up. However, there is radius side of Sand Lot Deck (detail 2 on drawing A101) and when existing deck is turned over the radius of IPE wood pieces will not match existing radius. Please advise. *At the upper deck portion of the sand lot deck, contractor to reinstall decking with its current face up as to follow the radius of the current design*

By signing the line below, I am acknowledging that all pages of the addenda has been received reviewed and understood, and will be incorporated into the bid price submitted. This document must be attached to the proposal for consideration.

Print Name _____ Signature _____ Date _____
Number of pages received: _____ <fill in>

Distributed to: All present and all prospective Proposers

NEW * YORK

GENERAL CONTRACTORS

10:00 A.M.

Page\PROJECTS\Venus Callendar\Pre-Proposal Conference Sign-In Sheet form.xls