

**Project:** Phase 3 Pile Remediation

**Date:** March 25th, 2014

**Engineer:** McLaren Engineering

**RE:** Addendum #3  
**# of Pages:** (# of pages)

---

The following revisions and/or clarifications are to be made to the proposal documents for **Phase 3 Pile Remediation locations 1 & 2**". They are a result of issues discussed at the pre-proposal conference held on ("March 25th 2014") and any questions received by close of business of same date (March 25th, 2014).

**Clarifications:**

In response to the questions received:

- Are the estimates for pile length or jackets?  
*Estimates are for the length of the pile jackets.*
- what is the overall length of the piles  
*The overall length of the piles should be estimated based on the schedules on the Drawing(s) titled "Repair Plan(s)"*
- what is the number of piles?  
There are 343 piles in Location 1 and 301 piles in Location 2 as detailed on Drawings S-3.0 and S-3.1
- How many 3 sided?  
*Assume that 5% of all back wall piles need a "Back wall Corner Encasement" for bidding purposes.*
- How many corners?  
*Assume that 95% of all back wall piles need a "Back wall Three Side Encasement" for bidding purposes*

**\*Please note, there will be a trailer on the barge for the CM\***

---

By signing the line below, I am acknowledging that all pages of the addenda has been received reviewed and understood, and will be incorporated into the bid price submitted. This document must be attached to the proposal for consideration.

---

Print Name

Signature

Date

Number of pages received: \_\_\_\_\_ <fill in>

Distributed to: All present and all prospective Proposers