

**Project:** Pier A Plaza Construction Services

**Date:** March 29, 2013

**Designer:** Arup

**RE:** Addendum #02  
**# of Pages:** (1 pages)

---

The following revisions and/or clarifications are to be made to the proposal documents for "Pier A Plaza Construction Services". They are a result of issues discussed at the pre-proposal conference held on March 20, 2013 and any questions received by close of business on March 27, 2013.

**Questions:**

1. Detail 1 of C-601 shows "Pavers on HD Asphalt." Is this correct? Detail shows Average concrete but breakdown calls for 6" reinforced concrete base slab under new pavers. Also, in breakdown BPCA calls for 3" thick asphalt hex tile paver with 2" mortar bed. Please clarify.  
*Answer: Detail 1 of C-601 title shall read "Pavement Section". Average concrete is the specified concrete mix (see specification) for the 6" reinforced concrete base slab. The Schedule of Values (Exhibit F) shall read: "3" thick asphalt hex tile paver with 3/4" bituminous setting bed".*
2. Is there a specification for the trash receptacles, bike racks and all other site furnishings?  
*Answer: See specification section: 12 93 00 Site Furnishings.*
3. There seems to be items in the specifications that do not apply to this project. IE: Asphalt Paving, Pavement markings, Stone Screenings. Please Clarify.  
*Answer: The items listed are to be part of the base contract. Unit costs should be submitted by Contractor. Scope will be defined at a later stage.*
4. Can the bid due date be extended as we are having difficulty with the short lead time and our subcontractors getting us competitive pricing.  
*Answer: No. Bid due date is Wednesday, April 03, 2013, by 3 pm.*
5. *Can the time for questions be extended as the original date is the 25th of March but that date is not a Wednesday? Please Clarify.*  
*Answer: All questions received by close of business on Wednesday, March 27, 2013, will be responded in Addendum #01 and Addendum #02.*

---

By signing the line below, I am acknowledging that all pages of the addenda has been received reviewed and understood, and will be incorporated into the bid price submitted. This document must be attached to the proposal for consideration.

\_\_\_\_\_  
Print Name

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date

Number of pages received: \_\_\_\_\_ <fill in>

Distributed to: All present and all prospective Proposers