

Plain-language encabulation explainer

TECH-001 · Version 1.0 · 2026-07-06 · Project Technical Team · approved

TECH-001 §1 — Encabulation is this case's fictional accelerated test method. The platform exposes specimens to temperature cycling, mechanical load and electrical bias at the same time, then records deformation, leakage and failure events. A specimen is one coupon or packaged device in a test position.

TECH-001 §2 — Per-run capacity means simultaneous test positions in one controlled cycle. Two consecutive 24-position cycles do not provide 48 positions per run. The specified ranges are –40 to 125 °C, 0 to 500 N load and 0 to 24 V bias. More capacity can improve throughput, but the minimum must first be met.

TECH-001 §3 — Site Acceptance Test (SAT) is the dated on-site demonstration that installation, controls, data export and training are accepted. CSV and JSON are portable data formats. Preventive maintenance is scheduled care; a two-business-day response is the maximum elapsed working-day response to a reported fault. Coverage must span SAT through the stated project end date.

TECH-001 §4 What a run produces

TECH-001 §4.1 — A controlled run begins with a specimen map and a programmed profile. Each position is assigned a channel identifier so an exported reading can be linked to the tested coupon or device. The controller records the applied conditions and measured response over time. The event log records alarms, pauses, fault states and operator actions that may explain an unusual trace. The research team uses both the readings and events to decide whether a run is suitable for analysis.

TECH-001 §4.2 — One run can contain many specimens, but every included specimen must experience the defined combined-stress profile while the same cycle is active. Running half the samples on Monday and half on Tuesday produces two separate runs. The results may be compared in a later analysis, but the chamber's simultaneous capacity has not changed. This distinction matters when a research plan needs comparable conditions within a cohort.

TECH-001 §5 Why service and export matter

TECH-001 §5.1 — The validated dataset is prepared near the end of the programme, and questions about failed or anomalous runs may continue during close-out. Local CSV or JSON files allow the team to inspect the original measurements without relying on a supplier account. Warranty, planned maintenance and fault response help keep the instrument usable while those records are being created and checked. A support term should be compared using its actual commencement and final covered day.