

IF IN ANY DOUBT PLS ASK

DO NOT SCALE



CONT. ON  
2"-WNA-418-1402-A82Y-G  
E 676884  
N 603047  
EL +102230

CONT. ON  
2"-WNA-418-1401-1-A82Y-G  
E 676831  
N 602970  
EL +101830

GENERAL NOTES :-

- 1) ALL DIMENSIONS ARE IN MM.
- 2) FLANGE CONN. DRILLING AS PER ANSI B16.5 CLASS 150#.
- 3) PTFE LINING AS PER ASTM D4895 STANDARD.
- 4) TESTING AND DIMENSIONS AS PER ASTM 1545.

INSPECTION

- HYDRO TEST :- 29 KG/CM2
- SPARK TEST :- 15 KVA

PACKING:- WOODEN / PLASTIC COVERS WILL BE USED  
TO PROTECT ALL LINED PORTIONS.

|         |                       |         |           |      |
|---------|-----------------------|---------|-----------|------|
| 17      | BALL VALVE            | 3/4"    | 118       | 01NO |
| 16      | BALL VALVE            | 2"      | 178       | 01NO |
| 15      | BLIND FLANGE CL150    | 3/4"    | --        | 01NO |
| 14      | WN FLANGE CL150       | 3/4"    | --        | 01NO |
| 13      | WN FLANGE CL150       | 2"      | --        | 03NO |
| 12      | FIGURE-8 FLANGE CL150 | 2"      | --        | 01NO |
| 11      | 90 DEG ELBOW          | 2"      | --        | 04NO |
| 10      | WELDOLET              | 2"x3/4" | --        | 01NO |
| 9       | EQUAL TEE             | 2"x2"   | --        | 02NO |
| 8       | PIPE SPOOL <16>       | 2"      | 160       | 01NO |
| 7       | PIPE SPOOL <15>       | 2"      | 1041      | 01NO |
| 6       | PIPE SPOOL <14>       | 3/4"    | 100       | 01NO |
| 5       | PIPE SPOOL <13>       | 2"      | 220       | 01NO |
| 4       | PIPE SPOOL <12>       | 2"      | 1670      | 01NO |
| 3       | PIPE SPOOL <11>       | 2"      | 340       | 01NO |
| 2       | PIPE SPOOL <10>       | 2"      | 273       | 01NO |
| 1       | PIPE SPOOL <9>        | 2"      | 6287      | 01NO |
| PART NO | DESCRIPTION           | SIZE    | LENGTH MM | QTY. |

|      |             |    |      |      |           |  |                  |      |
|------|-------------|----|------|------|-----------|--|------------------|------|
| REV. | DESCRIPTION | BY | CHD. | APPD | SCALE=NTS |  | SHEET NO. 2 OF 2 | REV. |
|      |             |    |      |      |           |  |                  | -1   |

| CORROSION RESISTANT EQUIPMENT PVT LTD             |           |      |         |                                        |  |  |  |
|---------------------------------------------------|-----------|------|---------|----------------------------------------|--|--|--|
| CUSTOMER: ENGINEERS INDIA LTD, NEW DELHI          |           |      |         |                                        |  |  |  |
| PROJECT: MIL PROJECT, TNT PLANT, HEF KHADKI, PUNE |           |      |         |                                        |  |  |  |
|                                                   | NAME      | SIGN | DATE    | LINE NO.<br><br>2"-WNA-418-1401-A82Y-G |  |  |  |
| DRAN                                              | RAM GAWAS |      | 15.7.26 |                                        |  |  |  |
| CHK                                               |           |      |         |                                        |  |  |  |
| APPD.                                             |           |      |         |                                        |  |  |  |