

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/2022/SZ/ *Sch No 01/12*

Dated: 05/01/2022

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Boys Senior Secondary School, New Building SPS Shed (School ID-1924014) located at Varun Marg, Defence Colony, New Delhi -110049, comprised of Ground + Three Upper Floors only owned / occupied by Delhi Govt., have complied with the fire prevention and Fire safety requirements in accordance with NBC / Director of Education Circular Dated 01/03/2011 and verified by the officer concerned of Fire Service on 27.12.2021 in presence of Mr. Brij Kishor, A.E.(E) and that the building / premises is fit for occupancy class "Educational" (Group B) with effect from 05/01/2022 for a period of 3 (Three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 05/01/2022 at New Delhi by.

*(Signature)*  
(ATUL GARG)  
DIRECTOR.

**Copy to:-**

1. Principal, Govt. Boys Senior Secondary School, New Building SPS Shed (School ID-1924014), Varun Marg, Defence Colony, New Delhi -49.
2. Assistant Engineer (E), Sub-div.-I-3, Edu. Maint., Div. M1-3, PWD, Hauz Khas, New Delhi-110016.
3. Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.