BEE 4750/5750

Homework 7: Mixed Integer Programming

2026-11-04

Due Date
Thursday, 11/12/26, 9:00pm

Overview

Instructions

- Problem 1 asks you to formulate a wastewater plant's choice of nitrogen upgrades with binary variables, then solve it in `JuMP`.
- Problem 2 asks you to solve a small integer program by hand with branch and bound.
- Write your answers in Markdown cells. For the sketches, a photo or scan of a hand drawing is fine: save it in this folder and insert it with `![](sketch.png)`.

Load Environment

```
import Pkg
Pkg.activate(@__DIR__)
Pkg.instantiate()
```

```
using JuMP
using HiGHS
using Plots
```

Problems (Total: 50 Points)

Problem 1 (30)

A city's wastewater treatment plant discharges to an estuary where nitrogen feeds algal blooms that leave the water low in oxygen each summer. Its new permit requires it to remove at least 90 tonnes of nitrogen per year (t N/yr) more than it does now. The plant already converts the ammonia in its wastewater to nitrate. Its engineers have shortlisted four upgrades:

- **Anoxic zones** turn part of the aeration basins into unaerated zones, where bacteria convert nitrate to nitrogen gas (**denitrification**) using carbon already in the wastewater.

- A **methanol feed** adds methanol to the anoxic zones, giving those bacteria extra carbon so they remove more nitrate.
- **Sidestream treatment** is a separate reactor that treats the ammonia-rich liquid pressed out of the plant's digested sludge, before that liquid returns to the plant.
- A **denitrification filter** is a new filter at the end of the plant, where bacteria on the filter media remove nitrate from the effluent.

Upgrade	Maximum removal (t N/yr)	Installation cost ($1,000/yr)	Operating cost ($/kg N removed)
Anoxic zones	40	300	2
Methanol feed	40	20	5
Sidestream treatment	20	100	1
Denitrification filter	80	250	3

Installation costs are annualized: the construction cost is spread over the life of the upgrade, so the installation cost is per year, like the operating cost of a year's removal. An upgrade that is installed costs its full installation cost however much nitrogen it removes; one that is not installed costs nothing and removes nothing.

There are two rules governing which combinations of upgrades are allowed:

1. The sidestream reactor and the filter would both be built on the plant's one open site, which has room for only one of them (the **site rule**).
2. The methanol feeds the bacteria in the anoxic zones, so the methanol feed can be installed only if the anoxic zones are (the **methanol rule**).

The plant wants to meet its removal requirement at the lowest annual cost.

Problem 1.1 (4)
Define the decision variables, with units. Which are binary and which are continuous?

Problem 1.2 (10)
Write the objective function. Then write the permit constraint and one constraint for each upgrade's removal capacity.

Problem 1.3 (6)
Write the site rule and the methanol rule as one linear constraint each.

Problem 1.4 (10)
Implement your model in `JuMP` and solve it with `HiGHS`. Report which upgrades are installed, how much each removes, and the annual cost.

```
# Upgrades in the order: anoxic zones, methanol feed, sidestream, filter
max_removal = [40, 40, 20, 80]            # [t N/yr]
```

```
installation_cost = [300, 20, 100, 250]   # [$1,000/yr]
operating_cost = [2, 5, 1, 3]             # [$/kg N]
required_removal = 90                     # [t N/yr]

nitrogen = Model(HiGHS.Optimizer)
set_silent(nitrogen)

# Add the variables, the objective, the permit and linking constraints,
# and the two rules.
```

Problem 2 (20)

A water utility must add ultraviolet (UV) disinfection to its drinking-water plant, as a second barrier against *Cryptosporidium*. It can buy two kinds of UV reactor:

Reactor	Capacity (MGD)	Price ($100,000)	Power (kW)
Medium-pressure	5	2	10
Low-pressure	2	1	2

Medium-pressure reactors cost less per MGD of capacity, and low-pressure reactors use less power per MGD. A state grant covers $1,000,000 of reactors, and the UV building's electrical service has 41 kW to spare. The utility wants as much UV capacity, in million gallons per day (MGD), as the grant and the power supply allow. With x_1 medium-pressure and x_2 low-pressure reactors, the problem is

$$\begin{aligned} \max_{x_1, x_2} \quad & z = 5x_1 + 2x_2 && \text{(MGD)} \\ \text{subject to:} \quad & 2x_1 + x_2 \le 10 && \text{(grant, \$100,000)} \\ & 10x_1 + 2x_2 \le 41 && \text{(power, kW)} \\ & x_1, x_2 \ge 0, \text{integer} \ . \end{aligned}$$

Solve it by branch and bound, by hand.

Problem 2.1 (7)

Node 1 is the LP relaxation: the same problem without the integer requirement. Sketch its feasible region with x_1 on the horizontal axis, label each corner with its coordinates, and find node 1's LP optimum and its z. Is that z an upper or a lower bound on the best capacity the utility can actually buy? Why?

Problem 2.2 (13)

Branch on x_1: node 2 adds $x_1 \le 3$, and node 3 adds $x_1 \ge 4$. Solve the LP at each node (a sketch with its corners is enough), and report each solution and its z. Which node(s) can be pruned, and by which rule? What is the best purchase, and its capacity?