

§4 Read Cell Voltage:  
Send - 0001FF  
Receive like - DAEFFF - 3502 mV  
Read Cell Temperature:  
Send - 0002FF  
Receive like - 01CFFF - 28°C  
Read Load State:  
Send - 0003FF  
Receive Like - 038FFF - 56%  
Set Load State:  
000BFF - 0% load  
064BFF - 100% load  
Calibrate Cell Voltage:  
D809FF - Set measured voltage to 3456 mV  
Calibrate Cell Temperature:  
020AFF - Set measured Temperature to 32°C  
Remark - 'FF' is CRC field, now not implemented yet.