

Document Title: Instrument List (01-K-101)

Sheet: 1 of 9
Rev. 4

Project Name: CEYHAN PDH-PP PROJECT	Master Shop Order: 23E033
End User: CEYHAN POLIPROPILEN ÜRETİM A.Ş.	Serial Number: 23E033A001
Purchaser: TECNICAS REUNIDAS S.A	Set: 1
Purchase Order No.: 1041005010	Model: 70MD3-3 + 56M6
Item No.: 01-K-101	Service: REACTOR EFFLUENT COMPRESSOR
Job No:	

☐ FOR APPROVAL To avoid delay and maintain shipping promise, the approved print must be returned by: _____ _____	☒ FOR RECORD Any requested change of this equipment will result in: 1. Contract price adjustment. 2. Extended shipping promise as this contract is in the manufacturing process.
By:	P.Mahesh
Date:	Dec.19.'25

		Ceyhan Polipropilen Üretim A.Ş.			
CEYHAN PDH-PP PROJECT					
CONTRACTOR PROJECT No.:	10410	CONTRACTOR UNIT:	01		
REQUISITION FOR PURCHASE No.:	1041005011	EQUIPMENT TAG:	01-K-101		
REVIEW RESPONSE BY CONTRACTOR:					
CONTRACTOR review and comments do not indicate either responsibility or liability for accuracy and completeness of this document or alter any contractual terms and conditions:					
☐ A - REJECTED ☐ F - REVIEWED WITHOUT COMMENTS ☐ R - AS BUILT		☐ B - REVIEWED WITH MAJOR COMMENTS ☐ I - FOR INFORMATION		☒ C - REVIEWED WITH MINOR COMMENTS ☐ M - VOID	
				REVIEW DATE:	12-JAN-2026
CONTRACTOR/EMPLOYER DOCUMENT	05011-CPP-01-00-4V-IIN-01-K-101-0001	CONTRACTOR/EMPLOYER REV:	01		
					
DOCUMENT TITLE:		Instrument List (01-K-101)			
CODE:	LIS-0006	VENDOR DOCUMENT No.:	23E033A001AA55A0NA0-CNNN	REV:	4

9					
8					
7					
6					
5					
4	All	Dec.19.'25	P. Mahesh	C.Annam	Suriya
3	All	Sep.23.'25	P. Mahesh	C.Annam	Suriya
2	All	Jul.10.'25	P. Mahesh	C.Annam	Suriya
1	All	May.27.'25	P. Mahesh	C.Annam	Suriya
0	All	Feb.19.'25	P. Mahesh	C.Annam	Suriya
Rev	Page	Date	Approved By	Checked By	Prepared By

					General comment: 1. Local indication instruments are missing in the list vendor to check and align with instruments in P&ID 2. Repeat of previous revision comment: TBD, VTA and missing details should be update in next revision for approval code of final issue.															
DOCUMENT NAME Instrument List (01-K-101)																		Revision		Page
																		No.	Date	
Doc. No: 05011-CPP-01-00-4V-IIN-01-K-101-0001																		4	18-Dec-25	2 OF 9
TAG NUMBER	INSTRUMENT TYPE DESCRIPTION	LINE NUMBER	EQUIP NO	VLV FAIL	POWER SUPPLY	LOCATION	P&ID	VENDOR SCOPE	HAZARDOUS AREA CLASSIFICATION	ELECTRICAL AREA CERTIFICATION	RANGE			DATA SHEET	MANUFACTURER	STATUS	REMARKS			
	TAG SERVICE				SIGNAL VOLTAGE LEVEL						MIN	MAX	UOM	REQUISITION Nº				MODEL		
01-PT-01017	PRESSURE TRANSMITTER LP COMP SUCTION PRESS	48"-PR-01-011003-BH3A-HC	01-K-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	NO (TR SCOPE)	IEC ZONE 2, GROUP IIC, T3	Ex d	0	1.8	barg	-	-					
01-PT-01039	PRESSURE TRANSMITTER LP COMP SUCTION PRESS				24VDC LOOP POWERED 4-20 mA HART									-	-					
01-PG-01018	PRESSURE GAUGE LP COMP SUCTION PRESS	72"-PR-01-011903-AA3A-HC	01-K-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	NO (TR SCOPE)	IEC ZONE 2, GROUP IIC, T3	Ex d	0	1.8	barg	-	-					
01-PDT-01038	PRESSURE GAUGE LP COMP SUCTION PRESS	72"-PR-01-011903-AA3A-HC	01-K-101	NA	NA	LGB	05011-CPP-01-00-4V-PID-01-K-101-0002	YES	NA	NA	-1	1.5	barg	05011-CPP-01-00-4V-DSH-01-K-101-0009	WIKA					
	DIFFERENTIAL PRESSURE TRANSMITTER LP COMP SUCTION DIFF PRESS				24VDC LOOP POWERED 4-20 mA HART									-	232.30	-				
01-TT-01054	TEMPERATURE TRANSMITTER REC COOLER TEMP	72"-PR-01-011903-AA3A-HC	01-K-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	NO (TR SCOPE)	IEC ZONE 2, GROUP IIC, T3	Ex d	0	0.07	barg	-	-					
01-TE-01054	TEMPERATURE ELEMENT-RTD REC COOLER TEMP				24VDC LOOP POWERED 4-20 mA HART	-	-													
01-TW-01054	TEMPERATURE TRANSMITTER REC COOLER TEMP	NA	01-C-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	NO (TR SCOPE)	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	-	-					
	THERMOWELL REC COOLER TEMP				-									-	-					
01-XV-01052	ANTI SURGE VALVE LP COMP ANTI-SURGE VALVE	30"-PR-01-012002-AA3A-PP	01-K-101	FO	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	100	%	-	FISHER					
01-ZT-01052	POSITION TRANSMITTER LP COMP ANTI-SURGE POSITION				24VDC LOOP POWERED 4-20 mA HART									-	VALVE: FBT, POSITIONER: DVC6200, ODV					
01-XVY-01052	AUX SOLENOID VALVE LP COMP ANTI-SURGE VALVE SOLENOID	30"-PR-01-012002-AA3A-PP	01-K-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	100	%	-	FISHER					
	LIMIT SWITCH				24VDC									-	4400	-				
01-XZSO-01052	LP COMP ANTI-SURGE VALVE FULLY OPEN	30"-PR-01-012002-AA3A-PP	01-K-101	NA	24VDC LOOP POWERED 24VDC	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0022	ASCO					
01-XZSC-01052	LIMIT SWITCH LP COMP ANTI-SURGE VALVE FULLY CLOSE				24VDC LOOP POWERED 24VDC									-	WSNFT8327B102	-				
01-XPG-01052	PRESSURE GAUGE LP COMP VOLUME TANK PRESS	NA	01-XVTK-01052	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	YES	NA	NA	0	16	barg	-	TOPWORX					
	PRESSURE RELIEF VALVE LP COMP VOLUME TANK RELIEF VALVE				24VDC									-	7J-13569-JSM-N	-				
01-XPSV-01502	LP POSITIONER LP & HP COMPRESSOR RECYCLE VALVE	NA	01-XVTK-01052	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	YES	NA	NA	0	100	%	05011-CPP-01-00-4V-DSH-01-K-101-0022	TOPWORX					
	POSITION TRANSMITTER LP & HP COMPRESSOR RECYCLE VALVE				24VDC LOOP POWERED 4-20 mA HART									-	7J-13569-JSP-N	-				
01-PV-01017	LIMIT SWITCH LP & HP COMP RECYCLE VALVE FULLY CLOSE	NA	01-K-101	NA	24VDC	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	NO (TR SCOPE)	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	-	WIKA					
01-ZT-01017	LP & HP COMPRESSOR RECYCLE VALVE				24VDC LOOP POWERED 4-20 mA HART									-	233.50	-				
01-PZSC-01017	LIMIT SWITCH LP & HP COMP RECYCLE VALVE FULLY CLOSE	NA	01-K-101	NA	24VDC LOOP POWERED 24VDC	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	NO (TR SCOPE)	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0022	LESER					
	PRESSURE GAUGE LP COMP DISCHARGE PRESS				-									4594.2184	-					
01-PG-01019	PRESSURE TRANSMITTER LP COMP DISCHARGE PRESS	48"-PR-01-011904-AA3A-PP	01-K-101	NA	NA	LGB	05011-CPP-01-00-4V-PID-01-K-101-0002	YES	NA	NA	0	4	barg	-	WIKA					
01-PT-01040	FLOW ELEMENT-VENTURI LP COMP DISCHARGE FLOW				24VDC LOOP POWERED 4-20 mA HART									-	232.30	-				
01-FE-01018	DP FLOW TRANSMITTER LP COMP DISCHARGE FLOW	48"-PR-01-011904-AA3A-PP	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	NO (TR SCOPE)	NA	NA	NA	NA	NA	-	-					
01-FT-01018	TEMPERATURE ELEMENT-RTD LP COMP DISCHARGE TEMP				24VDC LOOP POWERED 4-20 mA HART									-	-					
01-TE-01059	TEMPERATURE TRANSMITTER LP COMP DISCHARGE TEMP	48"-PR-01-011904-AA3A-PP	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	NO (TR SCOPE)	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	-	-					
01-TT-01059	THERMOWELL LP COMP DISCHARGE TEMP				24VDC LOOP POWERED 4-20 mA HART									-	-					
01-TW-01059	PRESSURE GAUGE HP COMP SUCTION PRESS	48"-PR-01-011904-AA3A-PP	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	NO (TR SCOPE)	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	-	-					
01-PG-01041	PRESSURE TRANSMITTER HP COMP SUCTION PRESS				24VDC LOOP POWERED 4-20 mA HART									-	-					
01-PT-01041	DIFFERENTIAL PRESSURE TRANSMITTER HP COMP SUCTION DIFF PRESS	40"-PR-01-012205-AA3A-HC	01-K-101	NA	NA	LGB	05011-CPP-01-00-4V-PID-01-K-101-0002	YES	NA	NA	0	4	barg	05011-CPP-01-00-4V-DSH-01-K-101-0009	WIKA					
01-PDT-01042	TEMPERATURE ELEMENT-RTD HP COMP REC INTERSTAGE COOLER TEMP				24VDC LOOP POWERED 4-20 mA HART									-	232.30	-				
01-TE-01063	TEMPERATURE TRANSMITTER HP COMP REC INTERSTAGE COOLER TEMP	NA	01-C-102	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	NO (TR SCOPE)	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	-	-					
01-TT-01063	THERMOWELL HP COMP REC INTERSTAGE COOLER TEMP				24VDC LOOP POWERED 4-20 mA HART									-	-					
01-TW-01063	ANTI SURGE VALVE HP COMP ANTI-SURGE VALVE	20"-PR-01-012104-BA3A-PP	01-K-101	FO	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	NO (TR SCOPE)	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	-	-					
01-XV-01053	POSITION TRANSMITTER HP COMP ANTI-SURGE POSITION				24VDC LOOP POWERED 4-20 mA HART									-	05011-CPP-01-00-4V-DSH-01-K-101-0022	FISHER				
01-ZT-01053	AUX SOLENOID VALVE HP COMP ANTI-SURGE VALVE SOLENOID	20"-PR-01-012104-BA3A-PP	01-K-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	100	%	05011-CPP-01-00-4V-DSH-01-K-101-0022	VALVE: EWT, POSITIONER: DVC6200, ODV					
01-XVY-01053	LIMIT SWITCH HP COMP ANTI-SURGE VALVE FULLY OPEN				24VDC LOOP POWERED 4-20 mA HART									-	4400	-				
01-XZSO-01053	LIMIT SWITCH HP COMP ANTI-SURGE VALVE FULLY CLOSE	20"-PR-01-012104-BA3A-PP	01-K-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0022	ASCO					
01-XZSC-01053	PRESSURE GAUGE HP COMP VOULUME TANK PRESS				24VDC LOOP POWERED 4-20 mA HART									-	WSNFT8327B102	-				
01-XPG-01053	PRESSURE RELIEF VALVE HP COMP VOULUME TANK RELIEF VALVE	NA	01-XVTK-01053	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	YES	NA	NA	0	16	barg	05011-CPP-01-00-4V-DSH-01-K-101-0022	TOPWORX					
	01-XPSV-01503				24VDC									-	7J-13569-JSP-N	-				
01-PG-01143	LP POSITIONER LP & HP COMPRESSOR RECYCLE VALVE	30"-PR-01-012103-BA3A-PP	01-K-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0022	TOPWORX					
01-PT-01043	POSITION TRANSMITTER HP COMP ANTI-SURGE POSITION				24VDC LOOP POWERED 4-20 mA HART									-	7J-13569-JSP-N	-				
01-FE-01019	AUX SOLENOID VALVE HP COMP ANTI-SURGE VALVE SOLENOID	30"-PR-01-012103-BA3A-PP	01-K-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0022	TOPWORX					
01-FT-01019	LIMIT SWITCH HP COMP ANTI-SURGE VALVE FULLY OPEN				24VDC LOOP POWERED 4-20 mA HART									-	7J-13569-JSP-N	-				
01-TE-01061	LIMIT SWITCH HP COMP ANTI-SURGE VALVE FULLY CLOSE	30"-PR-01-012103-BA3A-PP	01-K-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0022	TOPWORX					
01-TT-01061	PRESSURE GAUGE LP COMP VOLUME TANK PRESS				24VDC									-	7J-13569-JSP-N	-				
01-TW-01061	PRESSURE RELIEF VALVE LP COMP VOLUME TANK RELIEF VALVE	30"-PR-01-012103-BA3A-PP	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0002	NO (TR SCOPE)	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	-	-					
01-LT-01501	TEMPERATURE TRANSMITTER (DP DIAPHRAGM SEAL) RUNDOWN TANK LEVEL				24VDC LOOP POWERED 4-20 mA HART									-	YOKOGAWA	-				
01-FO-01501	RESTRICTION ORIFICE RUNDOWN TANK LEVEL ORIFICE	NA	01-K-101-D01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	0.06	barg	05011-CPP-01-00-4V-DSH-01-K-101-0009	HUALICN					
		NA	01-K-101-D01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0009	HRJ40201B.1-2					

		General comment: 1. Local indication instruments are missing in the list vendor to check and align with instruments in P&ID 2. Repeat of previous revision comment: TBD, VTA and missing details should be update in next revision for approval code of final issue.										 Revision				Page				
DOCUMENT NAME																No.		Date		3 OF 9
Instrument List (01-K-101)																				
Doc. No: 05011-CPP-01-00-4V-IIN-01-K-101-0001																4		18-Dec-25		
TAG NUMBER	INSTRUMENT TYPE DESCRIPTION	LINE NUMBER	EQUIP NO	VLV FAIL	POWER SUPPLY	LOCATION	P&ID	VENDOR SCOPE	HAZARDOUS AREA CLASSIFICATION	ELECTRICAL AREA CERTIFICATION	RANGE			DATA SHEET	MANUFACTURER	STATUS	REMARKS			
	TAG SERVICE				SIGNAL VOLTAGE LEVEL						MIN	MAX	UOM	REQUISITION N°				MODEL		
01-PT-01501	PRESSURE TRANSMITTER LUBE OIL HEADER PRESS	1.1/2"-L.O-01-101403-S15WN-N	01-K-101	NA	24VDC LOOP POWERED 4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	3	bar/g	05011-CPP-01-00-4V-DSH-01-K-101-0009	ROSEMOUNT					
01-PZT-01502A	PRESSURE TRANSMITTER LUBE OIL HEADER PRESS A	1.1/2"-L.O-01-101403-S15WN-N	01-K-101	NA	24VDC LOOP POWERED 4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	3	bar/g	05011-CPP-01-00-4V-DSH-01-K-101-0009	ROSEMOUNT					
01-PZT-01502B	PRESSURE TRANSMITTER LUBE OIL HEADER PRESS B	1.1/2"-L.O-01-101403-S15WN-N	01-K-101	NA	24VDC LOOP POWERED 4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	3	bar/g	05011-CPP-01-00-4V-DSH-01-K-101-0009	ROSEMOUNT					
01-PZT-01502C	PRESSURE TRANSMITTER LUBE OIL HEADER PRESS C	1.1/2"-L.O-01-101403-S15WN-N	01-K-101	NA	24VDC LOOP POWERED 4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	3	bar/g	05011-CPP-01-00-4V-DSH-01-K-101-0009	ROSEMOUNT					
01-PG-01501	PRESSURE GAUGE LUBE OIL HEADER PRESS	1.1/2"-L.O-01-101403-S15WN-N	01-K-101	NA	NA	LGB	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	0	2.5	bar/g	05011-CPP-01-00-4V-DSH-01-K-101-0009	WIKA					
01-PG-01502	PRESSURE GAUGE MOTOR LUBE OIL SUPPLY PRESSURE (DE)	3/4"-L.O-01-101405-S15WN-N	01-KM-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	0	2.5	bar/g	05011-CPP-01-00-4V-DSH-01-K-101-0009	WIKA					
01-PG-01503	PRESSURE GAUGE MOTOR LUBE OIL SUPPLY PRESSURE (NDE)	3/4"-L.O-01-101406-S15WN-N	01-KM-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	0	2.5	bar/g	05011-CPP-01-00-4V-DSH-01-K-101-0009	WIKA					
01-PT-01503	PRESSURE TRANSMITTER MOTOR LUBE OIL SUPPLY PRESSURE (NDE)	3/4"-L.O-01-101405-S15WN-N	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	3	bar/g	05011-CPP-01-00-4V-DSH-01-K-101-0009	ROSEMOUNT					
01-PT-01504	PRESSURE TRANSMITTER MOTOR LUBE OIL SUPPLY PRESSURE (DE)	3/4"-L.O-01-101406-S15WN-N	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	3	bar/g	05011-CPP-01-00-4V-DSH-01-K-101-0009	ROSEMOUNT					
01-FO-01502	RESTRICTION ORIFICE MOTOR LUBE OIL SUPPLY FLOW (DE)	3/4"-L.O-01-101406-S15WN-N	01-KM-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	NA	NA	NA	23E033AM01M0KDA0NA0-CNNN	TBD					
01-FO-01503	RESTRICTION ORIFICE MOTOR LUBE OIL SUPPLY FLOW (NDE)	3/4"-L.O-01-101405-S15WN-N	01-KM-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	NA	NA	NA	23E033AM01M0KDA0NA0-CNNN	TBD					
01-SG-01501	SIGHT GLASS LUBE OIL RETURN (NDE) SIGHT GLASS	4"-L.O-01-101421-S15WN-PP	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	NA	NA	NA	-	TBD					
01-SG-01502	SIGHT GLASS LUBE OIL RETURN (DE) SIGHT GLASS	3"-L.O-01-101420-S15WN-PP	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	NA	NA	NA	-	TBD					
01-SG-01503	SIGHT GLASS LUBE OIL RETURN (CPL) SIGHT GLASS	2"-L.O-01-101419-S15WN-N	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	NA	NA	NA	-	TBD					
01-SG-01504	SIGHT GLASS LUBE OIL RETURN (NDE) SIGHT GLASS	6"-L.O-01-101418-S15WN-PP	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	NA	NA	NA	-	TBD					
01-SG-01505	SIGHT GLASS LUBE OIL RETURN (DE) SIGHT GLASS	3"-L.O-01-101417-S15WN-PP	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	NA	NA	NA	-	TBD					
01-SG-01506	SIGHT GLASS LUBE OIL RETURN (CPL) SIGHT GLASS	3"-L.O-01-101416-S15WN-PP	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	NA	NA	NA	-	TBD					
01-SG-01507	SIGHT GLASS GEAR OIL RETURN SIGHT GLASS	10"-L.O-01-101415-S15WN-PP	01-K-101-GB01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	NA	NA	NA	-	TBD					
01-SG-01508	SIGHT GLASS GEAR OIL RETURN(CPL) SIGHT GLASS	2"-L.O-01-101414-S15WN-N	01-KM-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	NA	NA	NA	-	TBD					
01-SG-01509	SIGHT GLASS MOTOR OIL RETURN (DE) SIGHT GLASS	3"-L.O-01-101413-S15WN-PP	01-KM-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	NA	NA	NA	-	TBD					
01-SG-01510	SIGHT GLASS MOTOR OIL RETURN (NDE) SIGHT GLASS	2"-L.O-01-101425-S15WN-PP	01-KM-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	NA	NA	NA	-	TBD					
01-SG-01517	SIGHT GLASS RUNDOWN TANK LUBE OIL RETURN SIGHT GLASS	4"-L.O-01-012103-AA2B-N	01-K-101-D01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	NA	NA	NA	23E033AL01L02ZA0-SNNN	HUALI					
01-TG-01502	TEMPERATURE GAUGE LUBE OIL RETURN (NDE) TEMP	4"-L.O-01-101421-S15WN-PP	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	0	160	°C	05011-CPP-01-00-4V-DSH-01-K-101-0009	WIKA					
01-TW-01502	THERMOWELL LUBE OIL RETURN (NDE) TEMP	4"-L.O-01-101421-S15WN-PP	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0009	GAUGE: S5550 THERMOWELL: TW10-F					
01-TG-01503	TEMPERATURE GAUGE LUBE OIL RETURN (DE) TEMP	3"-L.O-01-101420-S15WN-PP	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	0	160	°C	05011-CPP-01-00-4V-DSH-01-K-101-0009	WIKA					
01-TW-01503	THERMOWELL LUBE OIL RETURN (DE) TEMP	3"-L.O-01-101420-S15WN-PP	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0009	GAUGE: S5550 THERMOWELL: TW10-F					
01-TG-01504	TEMPERATURE GAUGE LUBE OIL RETURN (NDE) TEMP	6"-L.O-01-101418-S15WN-PP	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	0	160	°C	05011-CPP-01-00-4V-DSH-01-K-101-0009	WIKA					
01-TW-01504	TEMPERATURE GAUGE LUBE OIL RETURN (NDE) TEMP	6"-L.O-01-101418-S15WN-PP	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0009	GAUGE: S5550 THERMOWELL: TW10-F					
01-TG-01505	TEMPERATURE GAUGE LUBE OIL RETURN (DE) TEMP	3"-L.O-01-101417-S15WN-PP	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	0	160	°C	05011-CPP-01-00-4V-DSH-01-K-101-0009	WIKA					
01-TW-01505	THERMOWELL LUBE OIL RETURN (DE) TEMP	3"-L.O-01-101417-S15WN-PP	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0009	THERMOWELL: TW10-F					
01-TG-01506	TEMPERATURE GAUGE GEAR OIL RETURN TEMP	10"-L.O-01-101415-S15WN-PP	01-K-101-GB01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	0	160	°C	05011-CPP-01-00-4V-DSH-01-K-101-0009	WIKA					
01-TW-01506	THERMOWELL GEAR OIL RETURN TEMP	10"-L.O-01-101415-S15WN-PP	01-K-101-GB01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0009	GAUGE: S5550 THERMOWELL: TW10-F					
01-TG-01507	TEMPERATURE GAUGE MOTOR OIL RETURN (DE) TEMP	3"-L.O-01-101413-S15WN-PP	01-KM-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	0	160	°C	05011-CPP-01-00-4V-DSH-01-K-101-0009	WIKA					
01-TW-01507	THERMOWELL MOTOR OIL RETURN (DE) TEMP	3"-L.O-01-101413-S15WN-PP	01-KM-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0009	THERMOWELL: TW10-F					
01-TG-01508	TEMPERATURE GAUGE MOTOR OIL RETURN (NDE) TEMP	2"-L.O-01-101412-S15WN-PP	01-KM-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	0	160	°C	05011-CPP-01-00-4V-DSH-01-K-101-0009	WIKA					
01-TW-01508	THERMOWELL MOTOR OIL RETURN (NDE) TEMP	2"-L.O-01-101412-S15WN-PP	01-KM-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0003	YES	NA	NA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0009	GAUGE: S5550 THERMOWELL: TW10-F					
01-TE-01501	TEMPERATURE ELEMENT-RTD 56M6 HP COMP BALANCE LINE TEMP	NA	01-K-101	NA	NA															

TAG NUMBER	INSTRUMENT TYPE DESCRIPTION	LINE NUMBER	EQUIP NO	VLV FAIL	POWER SUPPLY	LOCATION	P&ID	VENDOR SCOPE	HAZARDOUS AREA CLASSIFICATION	ELECTRICAL AREA CERTIFICATION	RANGE			DATA SHEET	MANUFACTURER	STATUS	REMARKS
	SIGNAL VOLTAGE LEVEL				MIN						MAX	UOM	REQUISITION N°	MODEL			
													TAG SERVICE				
01-VYE-01501	RADIAL VIBRATION PROBE LP COMP RADIAL VIBRATION (NDE)-Y	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0009 -	BENTLY NEVADA 330105-02-12-05-02-05		
01-VYT-01501	RADIAL VIBRATION TRANSMITTER LP COMP RADIAL VIBRATION (NDE)-Y	NA	01-K-101	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	100	µm	05011-CPP-01-00-4V-DSH-01-K-101-0009 -	BENTLY NEVADA 330180-91-05		
01-VXE-01502	RADIAL VIBRATION PROBE LP COMP RADIAL VIBRATION (DE)-X	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0009 -	BENTLY NEVADA 330105-02-12-05-02-05		
01-VXT-01502	RADIAL VIBRATION TRANSMITTER LP COMP RADIAL VIBRATION (DE)-X	NA	01-K-101	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	100	µm	05011-CPP-01-00-4V-DSH-01-K-101-0009 -	BENTLY NEVADA 330180-91-05		
01-VYE-01502	RADIAL VIBRATION PROBE LP COMP RADIAL VIBRATION (DE)-Y	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0009 -	BENTLY NEVADA 330105-02-12-05-02-05		
01-VYT-01502	RADIAL VIBRATION TRANSMITTER LP COMP RADIAL VIBRATION (DE)-Y	NA	01-K-101	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	100	µm	05011-CPP-01-00-4V-DSH-01-K-101-0009 -	BENTLY NEVADA 330180-91-05		
01-ZE-01502A	AXIAL VIBRATION PROBE HP COMP AXIAL POSITION (NDE)-A	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0009 -	BENTLY NEVADA 330101-00-08-10-02-05		
01-ZT-01502A	AXIAL VIBRATION TRANSMITTER HP COMP AXIAL POSITION (NDE)-A	NA	01-K-101	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	-1000	1000	µm	05011-CPP-01-00-4V-DSH-01-K-101-0009 -	BENTLY NEVADA 330180-91-05		
01-ZE-01502B	AXIAL VIBRATION PROBE HP COMP AXIAL POSITION (NDE)-B	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0009 -	BENTLY NEVADA 330101-00-08-10-02-05		
01-ZT-01502B	AXIAL VIBRATION TRANSMITTER HP COMP AXIAL POSITION (NDE)-B	NA	01-K-101	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	-1000	1000	µm	05011-CPP-01-00-4V-DSH-01-K-101-0009 -	BENTLY NEVADA 330180-91-05		
01-ZE-01502C	AXIAL VIBRATION PROBE HP COMP AXIAL POSITION (NDE)-C	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0009 -	BENTLY NEVADA 330101-00-08-10-02-05		
01-ZT-01502C	AXIAL VIBRATION TRANSMITTER HP COMP AXIAL POSITION (NDE)-C	NA	01-K-101	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	-1000	1000	µm	05011-CPP-01-00-4V-DSH-01-K-101-0009 -	BENTLY NEVADA 330180-91-05		
01-VXE-01503	RADIAL VIBRATION PROBE HP COMP RADIAL VIBRATION (NDE)-X	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0009 -	BENTLY NEVADA 330105-02-12-05-02-05		
01-VXT-01503	RADIAL VIBRATION TRANSMITTER HP COMP RADIAL VIBRATION (NDE)-X	NA	01-K-101	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	100	µm	05011-CPP-01-00-4V-DSH-01-K-101-0009 -	BENTLY NEVADA 330180-91-05		
01-VYE-01503	RADIAL VIBRATION PROBE HP COMP RADIAL VIBRATION (NDE)-Y	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0009 -	BENTLY NEVADA 330105-02-12-05-02-05		
01-VYT-01503	RADIAL VIBRATION TRANSMITTER HP COMP RADIAL VIBRATION (NDE)-Y	NA	01-K-101	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	100	µm	05011-CPP-01-00-4V-DSH-01-K-101-0009 -	BENTLY NEVADA 330180-91-05		
01-VXE-01504	RADIAL VIBRATION PROBE HP COMP RADIAL VIBRATION (DE)-X	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0009 -	BENTLY NEVADA 330105-02-12-05-02-05		
01-VXT-01504	RADIAL VIBRATION TRANSMITTER HP COMP RADIAL VIBRATION (DE)-X	NA	01-K-101	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	100	µm	05011-CPP-01-00-4V-DSH-01-K-101-0009 -	BENTLY NEVADA 330180-91-05		
01-VYE-01504	RADIAL VIBRATION PROBE HP COMP RADIAL VIBRATION (DE)-Y	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0009 -	BENTLY NEVADA 330105-02-12-05-02-05		
01-VYT-01504	RADIAL VIBRATION TRANSMITTER HP COMP RADIAL VIBRATION (DE)-Y	NA	01-K-101	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	100	µm	05011-CPP-01-00-4V-DSH-01-K-101-0009 -	BENTLY NEVADA 330180-91-05		
01-VXE-01505	RADIAL VIBRATION PROBE GEAR HSS RADIAL VIBRATION (DE)-X	NA	01-K-101-GB01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330105-02-12-05-02-05		
01-VXT-01505	RADIAL VIBRATION TRANSMITTER GEAR HSS RADIAL VIBRATION (DE)-X	NA	01-K-101-GB01	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	150	µm	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330180-91-05		
01-VYE-01505	RADIAL VIBRATION PROBE GEAR HSS RADIAL VIBRATION (DE)-Y	NA	01-K-101-GB01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330105-02-12-05-02-05		
01-VYT-01505	RADIAL VIBRATION TRANSMITTER GEAR HSS RADIAL VIBRATION (DE)-Y	NA	01-K-101-GB01	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	150	µm	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330180-91-05		
01-ZE-01503A	AXIAL VIBRATION PROBE GEAR AXIAL POSITON (NDE)-A	NA	01-K-101-GB01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330105-02-12-05-02-05		
01-ZT-01503A	AXIAL VIBRATION TRANSMITTER GEAR AXIAL POSITION (NDE)-A	NA	01-K-101-GB01	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	-1000	1000	µm	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330180-91-05		
01-ZE-01503B	AXIAL VIBRATION PROBE GEAR AXIAL POSITON (NDE)-B	NA	01-K-101-GB01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330105-02-12-05-02-05		
01-ZT-01503B	AXIAL VIBRATION TRANSMITTER GEAR AXIAL POSITON (NDE)-B	NA	01-K-101-GB01	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	-1000	1000	µm	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330180-91-05		
01-VE-01511	ACCELEROMETER GEAR HSS CASE ACCELERATION	NA	01-K-101-GB01	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	490	m/s2	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330400-01-05		
01-VE-01512	ACCELEROMETER GEAR LSS CASE ACCELERATION	NA	01-K-101-GB01	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	490	m/s2	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330400-01-05		
01-KE-01502	KEY PHASOR GEAR LSS KEYPHASOR (NDE)	NA	01-K-101-GB01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330105-02-12-05-02-05		
01-KT-01502	KEY PHASOR GEAR LSS KEYPHASOR (NDE)	NA	01-K-101-GB01	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	2000	RPM	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330180-91-05		
01-VXE-01507	RADIAL VIBRATION PROBE GEAR LSS RADIAL VIBRATION (NDE)-X	NA	01-K-101-GB01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330105-02-12-05-02-05		
01-VXT-01507	RADIAL VIBRATION TRANSMITTER GEAR LSS RADIAL VIBRATION (NDE)-X	NA	01-K-101-GB01	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	150	µm	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330180-91-05		
01-VYE-01507	RADIAL VIBRATION PROBE GEAR LSS RADIAL VIBRATION (NDE)-Y	NA	01-K-101-GB01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330105-02-12-05-02-05		
01-VYT-01507	RADIAL VIBRATION TRANSMITTER GEAR LSS RADIAL VIBRATION (NDE)-Y	NA	01-K-101-GB01	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	150	µm	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330180-91-05		
01-VXE-01506	RADIAL VIBRATION PROBE GEAR HSS RADIAL VIBRATION (NDE)-X	NA	01-K-101-GB01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330105-02-12-05-02-05		
01-VXT-01506	RADIAL VIBRATION TRANSMITTER GEAR HSS RADIAL VIBRATION (NDE)-X	NA	01-K-101-GB01	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	150	µm	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330180-91-05		
01-VYE-01506	RADIAL VIBRATION PROBE GEAR HSS RADIAL VIBRATION (NDE)-Y	NA	01-K-101-GB01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330105-02-12-05-02-05		
01-VYT-01506	RADIAL VIBRATION TRANSMITTER GEAR HSS RADIAL VIBRATION (NDE)-Y	NA	01-K-101-GB01	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	150	µm	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330180-91-05		
01-VXE-01508	RADIAL VIBRATION PROBE GEAR LSS RADIAL VIBRATION (DE)-X	NA	01-K-101-GB01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330105-02-12-05-02-05		
01-VXT-01508	RADIAL VIBRATION TRANSMITTER GEAR LSS RADIAL VIBRATION (DE)-X	NA	01-K-101-GB01	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	150	µm	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330180-91-05		
01-VYE-01508	RADIAL VIBRATION PROBE GEAR LSS RADIAL VIBRATION (DE)-Y	NA	01-K-101-GB01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330105-02-12-05-02-05		
01-VYT-01508	RADIAL VIBRATION TRANSMITTER GEAR LSS RADIAL VIBRATION (DE)-Y	NA	01-K-101-GB01	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	150	µm	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330180-91-05		
01-KE-01501	KEY PHASOR GEAR HSS KEYPHASOR (NDE)	NA	01-K-101-GB01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330105-02-12-05-02-05		
01-KT-01501	KEY PHASOR GEAR HSS KEYPHASOR (NDE)	NA	01-K-101-GB01	NA	-24VDC -	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	7000	RPM	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	BENTLY NEVADA 330180-91-05		
01-SE-01502	SPEED ELEMENT COMP SPEED TRANSMITTER	NA	01-K-101-GB01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0010 -	AI-TEK 70085-1010-412		

		General comment: 1. Local indication instruments are missing in the list vendor to check and align with instruments in P&ID 2. Repeat of previous revision comment: TBD, VTA and missing details should be update in next revision for approval code of final issue.																						
DOCUMENT NAME Instrument List (01-K-101) Doc. No: 05011-CPP-01-00-4V-IIN-01-K-101-0001												Revision		Page										
												No.	Date											
												4	18-Dec-25	5 OF 9										
TAG NUMBER	INSTRUMENT TYPE DESCRIPTION	LINE NUMBER	EQUIP NO	VLV FAIL	POWER SUPPLY	LOCATION	P&ID	VENDOR SCOPE	HAZARDOUS AREA CLASSIFICATION	ELECTRICAL AREA CERTIFICATION	RANGE			DATA SHEET	MANUFACTURER	STATUS	REMARKS							
	TAG SERVICE				SIGNAL VOLTAGE LEVEL						MIN	MAX	UOM	REQUISITION N°										
01-ST-01502	SPEED TRANSMITTER	NA	01-K-101-GB01	NA	24VDC LOOP POWERED	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	UCP	IEC ZONE 2, GROUP IIC, T3	Ex d	0	7000	RPM	05011-CPP-01-00-4V-DSH-01-K-101-0010	TBD									
	COMP SPEED TRANSMITTER				4-20 mA HART									-	-			-						
01-SE-01002	SPEED ELEMENT	NA	01-K-101-GB01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0010	AI-TEK									
	MOTOR SPEED TRANSMITTER				-									-	-			70085-1010-412						
01-ST-01002	SPEED TRANSMITTER	NA	01-K-101-GB01	NA	24VDC LOOP POWERED	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	UCP	IEC ZONE 2, GROUP IIC, T3	Ex d	0	2000	RPM	05011-CPP-01-00-4V-DSH-01-K-101-0010	TBD									
	MOTOR SPEED TRANSMITTER				4-20 mA HART									-	-			-	TBD					
01-VXE-01509	RADIAL VIBRATION PROBE	NA	01-KM-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0026	BENTLY NEVADA									
	MOTOR RADIAL VIBRATION (DE)-X				-									-	-			323933-00-00						
01-VXT-01509	RADIAL VIBRATION TRANSMITTER	NA	01-KM-101	NA	-24VDC	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	200	µm	05011-CPP-01-00-4V-DSH-01-K-101-0026	BENTLY NEVADA									
	MOTOR RADIAL VIBRATION (DE)-X				-									-	-			330180-51-05						
01-VYE-01509	RADIAL VIBRATION PROBE	NA	01-KM-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0026	BENTLY NEVADA									
	MOTOR RADIAL VIBRATION (DE)-Y				-									-	-			323933-00-00						
01-VYT-01509	RADIAL VIBRATION TRANSMITTER	NA	01-KM-101	NA	-24VDC	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	200	µm	05011-CPP-01-00-4V-DSH-01-K-101-0026	BENTLY NEVADA									
	MOTOR RADIAL VIBRATION (DE)-Y				-									-	-			330180-51-05						
01-VXE-01510	RADIAL VIBRATION PROBE	NA	01-KM-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0026	BENTLY NEVADA									
	MOTOR RADIAL VIBRATION (NDE)-X				-									-	-			323933-00-00						
01-VXT-01510	RADIAL VIBRATION TRANSMITTER	NA	01-KM-101	NA	-24VDC	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	200	µm	05011-CPP-01-00-4V-DSH-01-K-101-0026	BENTLY NEVADA									
	MOTOR RADIAL VIBRATION (NDE)-X				-									-	-			330180-51-05						
01-VYE-01510	RADIAL VIBRATION PROBE	NA	01-KM-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0026	BENTLY NEVADA									
	MOTOR RADIAL VIBRATION (NDE)-Y				-									-	-			323933-00-00						
01-VYT-01510	RADIAL VIBRATION TRANSMITTER	NA	01-KM-101	NA	-24VDC	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	200	µm	05011-CPP-01-00-4V-DSH-01-K-101-0026	BENTLY NEVADA									
	MOTOR RADIAL VIBRATION (NDE)-Y				-									-	-			330180-51-05						
01-TZE-01511A	TEMPERATURE ELEMENT-RTD	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0009	MINCO									
	LP COMP THRUST BRG TEMP (ACT)-A				-									-	-			S725PMWS90CAL10						
01-TZE-01511B	TEMPERATURE ELEMENT-RTD	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0009	MINCO									
	LP COMP THR BRG TEMP (ACT)-B				-									-	-			S725PMWS90CAL10						
01-TZE-01511C	TEMPERATURE ELEMENT-RTD	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0009	MINCO									
	LP COMP THR BRG TEMP (ACT)-C				-									-	-			S725PMWS90CAL10						
01-TZE-01512A	TEMPERATURE ELEMENT-RTD	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0009	MINCO									
	LP COMP THR BRG TEMP (INACT)-A				-									-	-			S725PMWS90CAL10						
01-TZE-01512B	TEMPERATURE ELEMENT-RTD	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0009	MINCO									
	LP COMP THR BRG TEMP (INACT)-B				-									-	-			S725PMWS90CAL10						
01-TZE-01513A	TEMPERATURE ELEMENT-RTD	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0009	MINCO									
	LP COMP JNL BRG TEMP (NDE)-A				-									-	-			S725PMWS90CAL10						
01-TZE-01513B	TEMPERATURE ELEMENT-RTD	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0009	MINCO									
	LP COMP JNL BRG TEMP (NDE)-B				-									-	-			S725PMWS90CAL10						
01-TZE-01514A	TEMPERATURE ELEMENT-RTD	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0009	MINCO									
	LP COMP JNL BRG TEMP (DE)-A				-									-	-			S725PMWS90CAL10						
01-TZE-01514B	TEMPERATURE ELEMENT-RTD	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0009	MINCO									
	LP COMP JNL BRG TEMP (DE)-B				-									-	-			S725PMWS90CAL10						
01-TZE-01515A	TEMPERATURE ELEMENT-RTD	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0009	MINCO									
	HP COMP THR BRG TEMP (ACT)-A				-									-	-			S725PMWS90CAL10						
01-TZE-01515B	TEMPERATURE ELEMENT-RTD	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0009	MINCO									
	HP COMP THR BRG TEMP (ACT)-B				-									-	-			S725PMWS90CAL10						
01-TZE-01515C	TEMPERATURE ELEMENT-RTD	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0009	MINCO									
	HP COMP THR BRG TEMP (ACT)-C				-									-	-			S725PMWS90CAL10						
01-TZE-01516A	TEMPERATURE ELEMENT-RTD	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0009	MINCO									
	HP COMP THR BRG TEMP (INACT)-A				-									-	-			S725PMWS90CAL10						
01-TZE-01516B	TEMPERATURE ELEMENT-RTD	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0009	MINCO									
	HP COMP THR BRG TEMP (INACT)-B				-									-	-			S725PMWS90CAL10						
01-TZE-01517A	TEMPERATURE ELEMENT-RTD	NA	01-K-101	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex nA	0	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0009	MINCO									

		General comment: 1. Local indication instruments are missing in the list vendor to check and align with instruments in P&ID 2. Repeat of previous revision comment: TBD, VTA and missing details should be update in next revision for approval code of final issue.															
DOCUMENT NAME Instrument List (01-K-101) Doc. No: 05011-CPP-01-00-4V-IIN-01-K-101-0001															Revision		Page
															No.	Date	
															4	18-Dec-25	6 OF 9
TAG NUMBER	INSTRUMENT TYPE DESCRIPTION	LINE NUMBER	EQUIP NO	VLV FAIL	POWER SUPPLY	LOCATION	P&ID	VENDOR SCOPE	HAZARDOUS AREA CLASSIFICATION	ELECTRICAL AREA CERTIFICATION	RANGE			DATA SHEET	MANUFACTURER	STATUS	REMARKS
	TAG SERVICE				SIGNAL VOLTAGE LEVEL						MIN	MAX	UOM	REQUISITION N°			
01-TT-01532A	TEMPERATURE TRANSMITTER MOTOR HOT AIR RTD	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	-50	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	PR ELECTRONICS 3337		
01-TT-01532B	TEMPERATURE TRANSMITTER MOTOR HOT AIR RTD-SPARE	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	-50	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	PR ELECTRONICS 3337		
01-TE-01530	TEMPERATURE ELEMENT-RTD MOTOR COLD AIR RTD (DE)	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	JUMO 903525/20-362-2001-2-6-300-252-04-5000-26		
01-TT-01530A	TEMPERATURE TRANSMITTER MOTOR COLD AIR RTD (DE)	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	-50	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	PR ELECTRONICS 3337		
01-TT-01530B	TEMPERATURE TRANSMITTER MOTOR COLD AIR RTD (DE)	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	-50	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	PR ELECTRONICS 3337		
01-TE-01531	TEMPERATURE ELEMENT-RTD MOTOR COLD AIR RTD (NDE)	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	JUMO 903525/20-362-2001-2-6-300-252-04-5000-26		
01-TT-01531A	TEMPERATURE TRANSMITTER MOTOR COLD AIR RTD (NDE)	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	-50	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	PR ELECTRONICS 3337		
01-TT-01531B	TEMPERATURE TRANSMITTER MOTOR COLD AIR RTD (NDE)-SPARE	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	-50	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	PR ELECTRONICS 3337		
01-LSL-01540	LEVEL SWITCH WATER LEAKAGE DETECTOR	NA	01-KM-101	NA	230VAC 24VDC	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	WIKI AL-ADF-I-NB1U - 1/2 NPT -C30EX		
01-PSH-01521	PRESSURE SWITCH PURGE COMPLETE	NA	01-KM-101	NA	250VAC 24VDC	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	EUROPEX LCS300-AD-INV		
01-PSLL-01522	PRESSURE SWITCH PURGE PRESSURE LOW ALARM	NA	01-KM-101	NA	250VAC 24VDC	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	EUROPEX LCS300-AD-INV		
01-PSL-01523	PRESSURE SWITCH PURGE IN PROGRESS	NA	01-KM-101	NA	250VAC 24VDC	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	EUROPEX LCS300-AD-INV		
01-TE-01527A	TEMPERATURE ELEMENT-RTD MOTOR WINDING TEMP (PHASE U1)	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	TERMOAPARATURA Xe-TOPE601-1xP100-08-80-2.5-10000-A-3-3x0.22-TT		
01-TT-01527A	TEMPERATURE TRANSMITTER MOTOR WINDING TEMP (PHASE U1)	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	-50	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	PR ELECTRONICS 3337		
01-TE-01527B	TEMPERATURE ELEMENT-RTD MOTOR WINDING TEMP (PHASE U2)-SPARE	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	TERMOAPARATURA Xe-TOPE601-1xP100-08-80-2.5-10000-A-3-3x0.22-TT		
01-TT-01527B	TEMPERATURE TRANSMITTER MOTOR WINDING TEMP (PHASE U2)-SPARE	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	-50	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	PR ELECTRONICS 3337		
01-TE-01527C	TEMPERATURE ELEMENT-RTD MOTOR WINDING TEMP (PHASE U3)-SPARE	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	TERMOAPARATURA Xe-TOPE601-1xP100-08-80-2.5-10000-A-3-3x0.22-TT		
01-TT-01527C	TEMPERATURE TRANSMITTER MOTOR WINDING TEMP (PHASE U3)-SPARE	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	-50	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	PR ELECTRONICS 3337		
01-TE-01528A	TEMPERATURE ELEMENT-RTD MOTOR WINDING TEMP (PHASE V1)	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	TERMOAPARATURA Xe-TOPE601-1xP100-08-80-2.5-10000-A-3-3x0.22-TT		
01-TT-01528A	TEMPERATURE TRANSMITTER MOTOR WINDING TEMP (PHASE V1)	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	-50	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	PR ELECTRONICS 3337		
01-TE-01528B	TEMPERATURE ELEMENT-RTD MOTOR WINDING TEMP (PHASE V2)-SPARE	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	TERMOAPARATURA Xe-TOPE601-1xP100-08-80-2.5-10000-A-3-3x0.22-TT		
01-TT-01528B	TEMPERATURE TRANSMITTER MOTOR WINDING TEMP (PHASE V2)-SPARE	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	-50	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	PR ELECTRONICS 3337		
01-TE-01528C	TEMPERATURE ELEMENT-RTD MOTOR WINDING TEMP (PHASE V3)-SPARE	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	TERMOAPARATURA Xe-TOPE601-1xP100-08-80-2.5-10000-A-3-3x0.22-TT		
01-TT-01528C	TEMPERATURE TRANSMITTER MOTOR WINDING TEMP (PHASE V3)-SPARE	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	-50	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	PR ELECTRONICS 3337		
01-TE-01529A	TEMPERATURE ELEMENT-RTD MOTOR WINDING TEMP (PHASE W1)	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	TERMOAPARATURA Xe-TOPE601-1xP100-08-80-2.5-10000-A-3-3x0.22-TT		
01-TT-01529A	TEMPERATURE TRANSMITTER MOTOR WINDING TEMP (PHASE W1)	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	-50	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	PR ELECTRONICS 3337		
01-TE-01529B	TEMPERATURE ELEMENT-RTD MOTOR WINDING TEMP (PHASE W2)-SPARE	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	TERMOAPARATURA Xe-TOPE601-1xP100-08-80-2.5-10000-A-3-3x0.22-TT		
01-TT-01529B	TEMPERATURE TRANSMITTER MOTOR WINDING TEMP (PHASE W2)-SPARE	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	-50	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	PR ELECTRONICS 3337		
01-TE-01529C	TEMPERATURE ELEMENT-RTD MOTOR WINDING TEMP (PHASE W3)-SPARE	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	TERMOAPARATURA Xe-TOPE601-1xP100-08-80-2.5-10000-A-3-3x0.22-TT		
01-TT-01529C	TEMPERATURE TRANSMITTER MOTOR WINDING TEMP (PHASE W3)-SPARE	NA	01-KM-101	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0005	YES	IEC ZONE 2, GROUP IIC, T3	Ex e	-50	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0026 -	PR ELECTRONICS 3337		
01-HS-01547A	HAND SWITCH PUSHBUTTON COMPRESSOR START	NA	01-K-101-LP01	NA	POTENTIAL FREE CONTACT 												

		General comment: 1. Local indication instruments are missing in the list vendor to check and align with instruments in P&ID 2. Repeat of previous revision comment: TBD, VTA and missing details should be update in next revision for approval code of final issue.										 Revision No. Date Page							
DOCUMENT NAME																4			
Instrument List (01-K-101)																18-Dec-25			
Doc. No: 05011-CPP-01-00-4V-IIN-01-K-101-0001																7 OF 9			
TAG NUMBER	INSTRUMENT TYPE DESCRIPTION	LINE NUMBER	EQUIP NO	VLV FAIL	POWER SUPPLY	LOCATION	P&ID	VENDOR SCOPE	HAZARDOUS AREA CLASSIFICATION	ELECTRICAL AREA CERTIFICATION	RANGE			DATA SHEET		MANUFACTURER	STATUS	REMARKS	
	TAG SERVICE				SIGNAL VOLTAGE LEVEL						MIN	MAX	UOM	REQUISITION N°	MODEL				
01-FI-01018B	FLOW INDICATOR LP COMP DISCHARGE FLOW	NA	01-K-101-LP01	NA	24VDC LOOP POWERED 4-20 mA HART	LOP	05011-CPP-01-00-4V-PID-01-K-101-0008/1	YES	IEC ZONE 2, GROUP IIC, T3	-	0	330000	kg/h	05011-CPP-01-00-4V-SCM-01-K-101-0009	BEKA ASSOCIATED LIMITED BA327SE				
01-PI-01041B	PRESSURE INDICATOR HP COMP SUCTION PRESS	NA	01-K-101-LP01	NA	24VDC LOOP POWERED 4-20 mA HART	LOP	05011-CPP-01-00-4V-PID-01-K-101-0008/1	YES	IEC ZONE 2, GROUP IIC, T3	-	0	4	barg	05011-CPP-01-00-4V-SCM-01-K-101-0009	BEKA ASSOCIATED LIMITED BA327SE				
01-FI-01019B	FLOW INDICATOR HP COMP DISCHARGE FLOW	NA	01-K-101-LP01	NA	24VDC LOOP POWERED 4-20 mA HART	LOP	05011-CPP-01-00-4V-PID-01-K-101-0008/1	YES	IEC ZONE 2, GROUP IIC, T3	-	0	308000	kg/h	05011-CPP-01-00-4V-SCM-01-K-101-0009	BEKA ASSOCIATED LIMITED BA327SE				
01-PI-01043B	PRESSURE INDICATOR HP COMP DISCHARGE PRESS	NA	01-K-101-LP01	NA	24VDC LOOP POWERED 4-20 mA HART	LOP	05011-CPP-01-00-4V-PID-01-K-101-0008/1	YES	IEC ZONE 2, GROUP IIC, T3	-	0	20	barg	05011-CPP-01-00-4V-SCM-01-K-101-0009	BEKA ASSOCIATED LIMITED BA327SE				
01-HS-01540	HAND SWITCH PUSHBUTTON ACKNOWLEDGE	NA	01-K-101-LP01	NA	POTENTIAL FREE CONTACT DRY	LOP	05011-CPP-01-00-4V-PID-01-K-101-0008/1	YES	IEC ZONE 2, GROUP IIC, T3	-	NA	NA	NA	05011-CPP-01-00-4V-SCM-01-K-101-0009	EX-TECH SOLUTION XBW4BA25				
01-HS-01546	HAND SWITCH PUSHBUTTON COMP CONTROL LOCAL/REMOTE SELECTION	NA	01-K-101-LP01	NA	POTENTIAL FREE CONTACT DRY	LOP	05011-CPP-01-00-4V-PID-01-K-101-0008/1	YES	IEC ZONE 2, GROUP IIC, T3	-	NA	NA	NA	05011-CPP-01-00-4V-SCM-01-K-101-0009	EX-TECH SOLUTION XBW4BD21				
01-XA-01540	HORN HORN	NA	01-K-101-LP01	NA	RELAY 24VDC	LOP	05011-CPP-01-00-4V-PID-01-K-101-0008/1	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-SCM-01-K-101-0009	EXTech SAS SD150DCNNARDN				
01-XL-01570	STATUS LAMP OIL PUMP START PERMISSIVE	NA	01-K-101-PK01-LP01	NA	24VDC LOOP POWERED 4-20 mA HART	LSB	05011-CPP-01-00-4V-PID-01-K-101-0008/2	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-SCM-01-K-101-0009	R. STAHL 8602A3-054-B-C02				
01-HS-01571	HAND SWITCH SELECTOR MAIN OIL PUMP SELECTOR SWITCH	NA	01-K-101-PK01-LP01	NA	POTENTIAL FREE CONTACT DRY	LSB	05011-CPP-01-00-4V-PID-01-K-101-0008/2	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-SCM-01-K-101-0009	R. STAHL 8602A3-734-B-45H-E99				
01-XL-01571	STATUS LAMP MAIN OIL PUMP RUNNING INDICATION	NA	01-K-101-PK01-LP01	NA	RELAY 24VDC	LSB	05011-CPP-01-00-4V-PID-01-K-101-0008/2	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-SCM-01-K-101-0009	R. STAHL 8602A3-054-B-C02				
01-HS-01572	HAND SWITCH SELECTOR STANDBY OIL PUMP SELECTOR SWITCH	NA	01-K-101-PK01-LP01	NA	POTENTIAL FREE CONTACT DRY	LSB	05011-CPP-01-00-4V-PID-01-K-101-0008/2	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-SCM-01-K-101-0009	R. STAHL 8602A3-734-B-45H-E99				
01-XL-01572	STATUS LAMP STANDBY OIL PUMP RUNNING INDICATION	NA	01-K-101-PK01-LP01	NA	RELAY 24VDC	LSB	05011-CPP-01-00-4V-PID-01-K-101-0008/2	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-SCM-01-K-101-0009	R. STAHL 8602A3-054-B-C02				
01-HS-01573	HAND SWITCH SELECTOR OIL HEATER SELECTOR SWITCH	NA	01-K-101-PK01-LP01	NA	POTENTIAL FREE CONTACT DRY	LSB	05011-CPP-01-00-4V-PID-01-K-101-0008/2	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-SCM-01-K-101-0009	R. STAHL 8602A3-734-B-45H-E99				
01-PDV-01509	DIFFERENTIAL PRESSURE CONTROL VALVE LP COMP N2 SEAL GAS SUPPLY DIFF PRESSURE CONTROL VALVE	3/4"-N2-01-101412-S1SBS-N	01-K-101-PK02A	FO	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/1	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	100	%	05011-CPP-01-00-4V-DSH-01-K-101-0018	EMERSON NPS 1 EZ				
01-PDV-01513	DIFFERENTIAL PRESSURE CONTROL VALVE LP COMP SEPARATION GAS SUPPLY DIFF PRESSURE CONTROL VALVE	3/4"-N2-01-101411-S1SBS-N	01-K-101-PK02A	FO	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/1	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	100	%	05011-CPP-01-00-4V-DSH-01-K-101-0018	EMERSON NPS 1 EZ				
01-PDT-01513	DIFFERENTIAL PRESSURE TRANSMITTER LP COMP SEPARATION GAS & SEAL GAS VENT DIFF PRESS	3/4"-N2-01-101416-S1SBS-N	01-K-101-PK02A	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/1	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	8	bar	05011-CPP-01-00-4V-DSH-01-K-101-0015	YOKOGAWA EJA110E-JVSSG-91DEN/KF22/X2/D3/C2/M01				
01-PT-01508	PRESSURE TRANSMITTER LP COMP SEPARATION GAS SUPPLY PRESS	3/4"-N2-01-101415-S1SBS-N	01-K-101-PK02A	NA	24VDC LOOP POWERED 4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0006/1	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	10	barg	05011-CPP-01-00-4V-DSH-01-K-101-0015	YOKOGAWA EJA530E-JBS4N-01DEN/KF22/X2/D3/C2/M15				
01-FO-01509	RESTRICTION ORIFICE LP COMP SEPARATION GAS SUPPLY FLOW	3/4"-N2-01-101415-S1SBS-N	01-K-101-PK02A	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/1	YES	NA	NA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0015	JOHN CRANE -				
01-FIF-01514	ROTAMETER -VARIABLE AREA FLOWMETER LP COMP SEPARATION GAS SUPPLY (NDE) FLOW	3/4"-N2-01-101418-S1SBS-N	01-K-101-PK02A	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/1	YES	IEC ZONE 2, GROUP IIC, T3	NA	0	56	Nm3/h	05011-CPP-01-00-4V-DSH-01-K-101-0015	KROHNE H250/RR/M40				
01-FE-01508	FLOW ELEMENT - ORIFICE PLATE LP COMP SEAL GAS SUPPLY FLOW (NDE)	3/4"-N2-01-101414-S1SBS-N	01-K-101-PK02A	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/1	YES	NA	NA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0015	YOKOGAWA SK-H020A05RF2077B/DZ/Z				
01-FT-01508	DP FLOW TRANSMITTER LP COMP SEAL GAS SUPPLY FLOW (NDE)	3/4"-N2-01-101414-S1SBS-N	01-K-101-PK02A	NA	24VDC LOOP POWERED 4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0006/1	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	3	Nm3/h	05011-CPP-01-00-4V-DSH-01-K-101-0015	YOKOGAWA EJA110E-JMSSG-91DEN/KF22/X2/D3/C2/M01				
01-PG-01512	PRESSURE GAUGE LP COMP SEAL GAS SUPPLY PRESS (NDE)	3/4"-N2-01-101414-S1SBSN-N	01-K-101-PK02A	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/1	YES	NA	NA	0	16	barg	05011-CPP-01-00-4V-DSH-01-K-101-0015	WIKA 233.30.100				
01-PG-01513	PRESSURE GAUGE LP COMP SEAL GAS SUPPLY PRESS (NDE)	3/4"-N2-01-101414-S1SBSN-N	01-K-101-PK02A	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/1	YES	NA	NA	0	16	barg	05011-CPP-01-00-4V-DSH-01-K-101-0015	WIKA 233.30.100				
01-FE-01507	FLOW ELEMENT - ORIFICE PLATE LP COMP SEAL GAS SUPPLY FLOW (DE)	3/4"-N2-01-101413-S1SBS-N	01-K-101-PK02A	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/1	YES	NA	NA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0015	YOKOGAWA SK-H020A05RF2077B/DZ/Z				
01-FT-01507	DP FLOW TRANSMITTER LP COMP SEAL GAS SUPPLY FLOW (DE)	3/4"-N2-01-101413-S1SBS-N	01-K-101-PK02A	NA	24VDC LOOP POWERED 4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0006/1	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	3	Nm3/h	05011-CPP-01-00-4V-DSH-01-K-101-0015	YOKOGAWA EJA110E-JMSSG-91DEN/KF22/X2/D3/C2/M01				
01-PG-01510	PRESSURE GAUGE LP COMP SEAL GAS SUPPLY PRESS (DE)	3/4"-N2-01-101413-S1SBSN-N	01-K-101-PK02A	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/1	YES	NA	NA	0	16	barg	05011-CPP-01-00-4V-DSH-01-K-101-0015	WIKA 233.30.100				
01-PG-01511	PRESSURE GAUGE LP COMP SEAL GAS SUPPLY PRESS (DE)	3/4"-N2-01-101413-S1SBSN-N	01-K-101-PK02A	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/1	YES	NA	NA	0	16	barg	05011-CPP-01-00-4V-DSH-01-K-101-0015	WIKA 233.30.100				
01-PDG-01503	DIFFERENTIAL PRESSURE GAUGE LP COMP BUFFER/SEAL GAS SUPPLY DIFF PRESS (DE)	3/4"-N2-01-101413-S1SBSN-N	01-K-101-PK02A	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/1	YES	NA	NA	0	6	bar	05011-CPP-01-00-4V-DSH-01-K-101-0015	WIKA 733.51.100				
01-PDZT-01510A	DIFFERENTIAL PRESSURE TRANSMITTER LP COMP BUFFER/SEAL GAS SUPPLY DIFF PRESS (DE)-A	3/4"-N2-01-101413-S1SBSN-N	01-K-101-PK02A	NA	24VDC LOOP POWERED 4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0006/1	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	6	bar	05011-CPP-01-00-4V-DSH-01-K-101-0015	YOKOGAWA EJA110E-JVSSG-91DEN/KF22/X2/D3/A1/C2/M01				
01-PDZT-01510B	DIFFERENTIAL PRESSURE TRANSMITTER LP COMP BUFFER/																		

		General comment: 1. Local indication instruments are missing in the list vendor to check and align with instruments in P&ID 2. Repeat of previous revision comment: TBD, VTA and missing details should be update in next revision for approval code of final issue.																						
DOCUMENT NAME Instrument List (01-K-101) Doc. No: 05011-CPP-01-00-4V-IIN-01-K-101-0001												Revision		Page										
												No.	Date											
												4	18-Dec-25	8 OF 9										
TAG NUMBER	INSTRUMENT TYPE DESCRIPTION	LINE NUMBER	EQUIP NO	VLV FAIL	POWER SUPPLY	LOCATION	P&ID	VENDOR SCOPE	HAZARDOUS AREA CLASSIFICATION	ELECTRICAL AREA CERTIFICATION	RANGE			DATA SHEET	MANUFACTURER	STATUS	REMARKS							
	TAG SERVICE				SIGNAL VOLTAGE LEVEL						MIN	MAX	UOM	REQUISITION N°	MODEL									
01-XV-01502	ON-OFF VALVE HP COMP NITROGEN GAS SUPPLY ON-OFF VALVE	3/4"-N2-01-051788-AA3A-N	01-K-101-PK02B	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	100	%	05011-CPP-01-00-4V-DSH-01-K-101-0015	KTM F89D SR STO									
01-XYV-01502	AUX SOLENOID VALVE HP COMP NITROGEN GAS SUPPLY SOLENOID VALVE	3/4"-N2-01-051788-AA3A-N	01-K-101-PK02B	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0015	ASCO WSNFET8327B312									
01-XZSO-01502	LIMIT SWITCH HP COMP NITROGEN GAS SUPPLY VALVE FULLY OPEN	NA	01-K-101-PK02B	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0015	TOPWORX TXS-P2CGNMM									
01-XZSC-01502	LIMIT SWITCH HP COMP NITROGEN GAS SUPPLY FULLY CLOSE	NA	01-K-101-PK02B	NA	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0015	TOPWORX TXS-P2CGNMM									
01-PDT-01507	DIFFERENTIAL PRESSURE TRANSMITTER HP COMP SEPARATION GAS FILTER DIFF PRESS	3/4"-N2-01-101431-S15BS-N	01-K-101-F04A/B	NA	24VDC LOOP POWERED 4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	1	bar	05011-CPP-01-00-4V-DSH-01-K-101-0015	YOKOGAWA EJA110E-JHS5G-91DEN/KF22/X2/D3/C2/M01									
01-FO-01513	RESTRICTION ORIFICE HP COMP SEPARATION GAS FILTER FLOW	3/4"-N2-01-101431-S15BS-N	01-K-101-F04A/B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	NA	NA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0015	JOHN CRANE									
01-PDT-01502	DIFFERENTIAL PRESSURE TRANSMITTER HP COMP SEAL GAS FILTER DIFF PRESS	3/4"-N2-01-101432-S15BS-N	01-K-101-F03A/B	NA	24VDC LOOP POWERED 4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	1	bar	05011-CPP-01-00-4V-DSH-01-K-101-0015	YOKOGAWA EJA110E-JHS5G-91DEN/KF22/X2/D3/C2/M01									
01-FO-01512	RESTRICTION ORIFICE HP COMP SEAL GAS FILTER FLOW	3/4"-N2-01-101432-S15BS-N	01-K-101-F03A/B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	NA	NA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0015	JOHN CRANE									
01-PDV-01508	DIFFERENTIAL PRESSURE CONTROL VALVE HP COMP N2 SEPARATION GAS SUPPLY CONTROL VALVE	3/4"-N2-01-101435-S15BS-N	01-K-101-PK02B	FO	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	100	%	05011-CPP-01-00-4V-DSH-01-K-101-0018	EMERSON NPS 1 EZ									
01-PDV-01503	DIFFERENTIAL PRESSURE CONTROL VALVE HP COMP SEAL GAS SUPPLY DIFF PRESS CONTROL VALVE	3/4"-N2-01-101432-S15BS-N	01-K-101-PK02B	FO	24VDC LOOP POWERED 4-20 mA HART	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	NA	Ex d	0	100	%	05011-CPP-01-00-4V-DSH-01-K-101-0018	EMERSON NPS 1 EZ									
01-PT-01507	PRESSURE TRANSMITTER HP COMP SEPARATION GAS SUPPLY PRESS	3/4"-N2-01-101435-S15BS-N	01-K-101-PK02B	NA	24VDC LOOP POWERED 4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	10	barg	05011-CPP-01-00-4V-DSH-01-K-101-0015	YOKOGAWA EJA530E-JBS4N-01DEN/KF22/X2/D3/C2/M15									
01-PDT-01508	DIFFERENTIAL PRESSURE TRANSMITTER HP COMP SEPARATION GAS SUPPLY DIFF PRESS	3/4"-N2-01-101435-S15BS-N	01-K-101-PK02B	NA	24VDC LOOP POWERED 4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	8	bar	05011-CPP-01-00-4V-DSH-01-K-101-0015	YOKOGAWA EJA110E-JVSSG-91DEN/KF22/X2/D3/C2/M01									
01-FO-01507	RESTRICTION ORIFICE HP COMP SEPARATION GAS SUPPLY FLOW (NDE)	1"-N2-01-101437-S15BS-N	01-K-101-PK02B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	NA	NA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0015	JOHN CRANE									
01-FIF-01512	ROTAMETER -VARIABLE AREA FLOWMETER HP COMP SEPARATION GAS SUPPLY FLOW (NDE)	1"-N2-01-101437-S15BS-N	01-K-101-PK02B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	IEC ZONE 2, GROUP IIC, T3	NA	0	56	Nm3/h	05011-CPP-01-00-4V-DSH-01-K-101-0015	KROHNE H250/RRM40									
01-FE-01504	FLOW ELEMENT -ORIFICE PLATE HP COMP SEAL GAS SUPPLY FLOW (NDE)	3/4"-N2-01-101434-S30BSN-N	01-K-101-PK02B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	NA	NA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0015	YOKOGAWA SK-H020A05RF2406B/DZ/Z									
01-FT-01504	DP FLOW TRANSMITTER HP COMP SEAL GAS SUPPLY FLOW (NDE)	3/4"-N2-01-101434-S30BSN-N	01-K-101-PK02B	NA	24VDC LOOP POWERED 4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	7	Nm3/h	05011-CPP-01-00-4V-DSH-01-K-101-0015	YOKOGAWA EJA110E-JMS5G-91DEN/KF22/X2/D3/C2/M01									
01-PG-01508	PRESSURE GAUGE HP COMP SEAL GAS SUPPLY PRESS (NDE)	3/4"-N2-01-101434-S30BSN-N	01-K-101-PK02B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	NA	NA	0	16	barg	05011-CPP-01-00-4V-DSH-01-K-101-0015	WIKA 233.30.100									
01-PG-01509	PRESSURE GAUGE HP COMP SEAL GAS SUPPLY PRESS (NDE)	3/4"-N2-01-101434-S30BSN-N	01-K-101-PK02B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	NA	NA	0	16	barg	05011-CPP-01-00-4V-DSH-01-K-101-0015	WIKA 233.30.100									
01-FE-01503	FLOW ELEMENT -ORIFICE PLATE HP COMP SEAL GAS SUPPLY FLOW (DE)	3/4"-N2-01-101433-S15BS-N	01-K-101-PK02B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	NA	NA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0015	YOKOGAWA SK-H020A05RF2406B/DZ/Z									
01-FT-01503	DP FLOW TRANSMITTER HP COMP SEAL GAS SUPPLY FLOW (DE)	3/4"-N2-01-101433-S15BS-N	01-K-101-PK02B	NA	24VDC LOOP POWERED 4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	7	Nm3/h	05011-CPP-01-00-4V-DSH-01-K-101-0015	YOKOGAWA EJA110E-JMS5G-91DEN/KF22/X2/D3/C2/M01									
01-PG-01506	PRESSURE GAUGE HP COMP SEAL GAS SUPPLY PRESS (DE)	3/4"-N2-01-101433-S30BSN-N	01-K-101-PK02B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	NA	NA	0	16	barg	05011-CPP-01-00-4V-DSH-01-K-101-0015	WIKA 233.30.100									
01-PG-01507	PRESSURE GAUGE HP COMP SEAL GAS SUPPLY PRESS (DE)	3/4"-N2-01-101433-S30BSN-N	01-K-101-PK02B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	NA	NA	0	16	barg	05011-CPP-01-00-4V-DSH-01-K-101-0015	WIKA 233.30.100									
01-PDG-01501	DIFFERENTIAL PRESSURE GAUGE HP COMP SEAL GAS SUPPLY PRESS (DE)	1.1/2"-H2-01-101433-S30BSN-N	01-K-101-PK02B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	NA	NA	0	6	bar	05011-CPP-01-00-4V-DSH-01-K-101-0015	WIKA 733.51.100									
01-PDT-01503A	DIFFERENTIAL PRESSURE TRANSMITTER HP COMP BUFFER/SEAL GAS SUPPLY DIFF PRESS (DE)	1.1/2"-H2-01-101433-S30BSN-N	01-K-101-PK02B	NA	24VDC LOOP POWERED 4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	6	bar	05011-CPP-01-00-4V-DSH-01-K-101-0015	YOKOGAWA EJA110E-JVSSG-91DEN/KF22/X2/D3/A1/C2/M01									
01-PDZT-01504A	DIFFERENTIAL PRESSURE TRANSMITTER HP COMP BUFFER/SEAL GAS SUPPLY DIFF PRESS (DE)-A	1.1/2"-H2-01-101433-S30BSN-N	01-K-101-PK02B	NA	24VDC LOOP POWERED 4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	6	bar	05011-CPP-01-00-4V-DSH-01-K-101-0015	YOKOGAWA EJA110E-JVSSG-91DEN/KF22/X2/D3/A1/C2/M01									
01-PDZT-01504B	DIFFERENTIAL PRESSURE TRANSMITTER HP COMP BUFFER/SEAL GAS SUPPLY DIFF PRESS (DE)-B	1.1/2"-H2-01-101433-S30BSN-N	01-K-101-PK02B	NA	24VDC LOOP POWERED 4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	6	bar	05011-CPP-01-00-4V-DSH-01-K-101-0015	YOKOGAWA EJA110E-JVSSG-91DEN/KF22/X2/D3/A1/C2/M01									
01-PDZT-01504C	DIFFERENTIAL PRESSURE TRANSMITTER HP COMP BUFFER/SEAL GAS SUPPLY DIFF PRESS (DE)-C	1.1/2"-H2-01-101433-S30BSN-N	01-K-101-PK02B	NA	24VDC LOOP POWERED 4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0006/2	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	6	bar	05011-CPP-01-00-4V										

		General comment: 1. Local indication instruments are missing in the list vendor to check and align with instruments in P&ID 2. Repeat of previous revision comment: TBD, VTA and missing details should be update in next revision for approval code of final issue.																	
DOCUMENT NAME Instrument List (01-K-101) Doc. No: 05011-CPP-01-00-4V-IIN-01-K-101-0001																Revision		Page	
																No.	Date		
4																18-Dec-25	9 OF 9		
TAG NUMBER	INSTRUMENT TYPE DESCRIPTION	LINE NUMBER	EQUIP NO	VLV FAIL	POWER SUPPLY	LOCATION	P&ID	VENDOR SCOPE	HAZARDOUS AREA CLASSIFICATION	ELECTRICAL AREA CERTIFICATION	RANGE			DATA SHEET			MANUFACTURER	STATUS	REMARKS
	TAG SERVICE				SIGNAL VOLTAGE LEVEL						MIN	MAX	UOM	REQUISITION N°	MODEL				
01-TE-01541	TEMPERATURE ELEMENT-RTD	NA	01-K-101-D02	NA	24VDC LOOP POWERED	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	-196	600	°C	05011-CPP-01-00-4V-DSH-01-K-101-0021	ROSEMOUNT				
	LUBE OIL RESERVOIR TEMP				4-20 mA HART									-					
01-TT-01541	TEMPERATURE TRANSMITTER	NA	01-K-101-D02	NA	24VDC LOOP POWERED	LGB	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	-30	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0021	ROSEMOUNT				
01-TW-01541	THERMOWELL	NA	01-K-101-D02	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0021	ROSEMOUNT				
	LUBE OIL RESERVOIR TEMP				4-20 mA HART									-	114CM0300PAC2SC050AXWR21Q76Q8/A22/B16/D05/T02				
01-TG-01511	TEMPERATURE GAUGE	NA	01-K-101-D02	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	0	100	°C	05011-CPP-01-00-4V-DSH-01-K-101-0021	WIKA				
01-TW-01511	LUBE OIL RESERVOIR TEMP	NA	01-K-101-D02	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0021	WIKA				
	THERMOWELL				24VDC LOOP POWERED									-	SAMDDBDUN0030000057G3G3PM06250220				
01-LT-01503	LEVEL TRANSMITTER (DP DIAPHRAGM SEAL)	NA	01-K-101-D02	NA	4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	0.16	barg	05011-CPP-01-00-4V-DSH-01-K-101-0021	YOKOGAWA				
01-PSV-01512	PRESSURE RELIEF VALVE	6°-LO-01-101706-S15WN-PP	01-K-101-PM01B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	0	100	%	05011-CPP-01-00-4V-DSH-01-K-101-0024	LESER				
	STANDBY LUBE OIL PUMP RELIEF VALVE				-									5264.1962-11					
01-PG-01521	PRESSURE GAUGE	6°-LO-01-101701-S15WN-PP	01-K-101-P01A	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	-1	1.5	barg	05011-CPP-01-00-4V-DSH-01-K-101-0021	WIKA				
01-PG-01522	MAIN OIL PUMP SUCTION PRESS	6°-LO-01-101702-S15WN-PP	01-K-101-P01B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	-1	1.5	barg	05011-CPP-01-00-4V-DSH-01-K-101-0021	WIKA				
	PRESSURE GAUGE				-									233.30.100					
01-PG-01523	STANDBY OIL PUMP SUCTION PRESS	6°-LO-01-101705-S15WN-PP	01-K-101-PM01A	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	0	16	barg	05011-CPP-01-00-4V-DSH-01-K-101-0021	WIKA				
01-PG-01524	MAIN OIL PUMP DISCHARGE PRESS	6°-LO-01-101706-S15WN-PP	01-K-101-PM01B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	0	16	barg	05011-CPP-01-00-4V-DSH-01-K-101-0021	WIKA				
	PRESSURE GAUGE				-									233.30.100					
01-PSV-01511	STANDBY OIL PUMP DISCHARGE PRESS	6°-LO-01-101705-S15WN-PP	01-K-101-PM01A	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	0	100	%	05011-CPP-01-00-4V-DSH-01-K-101-0024	LESER				
	PRESSURE RELIEF VALVE				-									5264.1962-11					
01-PCV-01501	MAIN LUBE OIL PUMP RELIEF VALVE	6°-LO-01-101707-S15WN-PP	NA	FC	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	0	100	%	05011-CPP-01-00-4V-DSH-01-K-101-0025	MASONNEILAN				
01-FO-01524	PRESSURE SELF ACTUATED VALVE	NA	01-K-101-D02	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	NA	NA	NA	23E033AL01L0Z1A0-SNNN	HUALICN				
	LUBE OIL CIRCULATION PCV				-									HR140202					
01-SG-01516	RESTRICTION ORIFICE	NA	01-K-101-D02	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	NA	NA	NA	23E033AL01L0Z2A0-SNNN	HUALI				
01-SG-01515	SIGHT GLASS	NA	01-K-101-D02	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0025	WIKA				
	LUBE OIL RESERVOIR SIGHT GLASS				-									85550-NS 100-4.1					
01-SG-01513	MAIN OIL COOLER COOLING WATER OUTLET TEMP	NA	01-K-101-E01A	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0025	WIKA				
	THERMOWELL				-									TW10-SAMCDBUN0022500057G3G3PM06250220					
01-SG-01511	MAIN OIL COOLER COOLING WATER OUTLET SIGHT GLASS	NA	01-K-101-E01A	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	NA	NA	NA	23E033AL01L0Z2A0-SNNN	HUALI				
	SIGHT GLASS				-									HR142015A.11					
01-PSV-01501	MAIN OIL COOLER COOLING WATER OUTLET TEMP	NA	01-K-101-E01A	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	0	100	%	05011-CPP-01-00-4V-DSH-01-K-101-0024	LESER				
	PRESSURE RELIEF VALVE				-									4592.2472-9					
01-FO-01516	MAIN OIL COOLER RELIEF VALVE	NA	01-K-101-E01A	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	0	100	%	05011-CPP-01-00-4V-DSH-01-K-101-0025	YOKOGAWA				
01-FO-01517	RESTRICTION ORIFICE	NA	01-K-101-E01A	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	NA	NA	NA	23E033AL01L0Z1A0-SNNN	HUALICN				
	MAIN OIL COOLER FLOW				-									HR140202					
01-TG-01513	TEMPERATURE GAUGE	NA	01-K-101-E01B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	0	100	°C	05011-CPP-01-00-4V-DSH-01-K-101-0025	WIKA				
01-TW-01513	STANDBY OIL COOLER COOLING WATER OUTLET TEMP	NA	01-K-101-E01A	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0025	WIKA				
	THERMOWELL				-									85550-NS 100-4.1					
01-SG-01512	MAIN OIL COOLER COOLING WATER OUTLET SIGHT GLASS	NA	01-K-101-E01B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	NA	NA	NA	23E033AL01L0Z2A0-SNNN	HUALI				
	SIGHT GLASS				-									HR142015A.11					
01-FO-01517	STANDBY OIL COOLER COOLING WATER OUTLET TEMP	NA	01-K-101-E01B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	0	100	%	05011-CPP-01-00-4V-DSH-01-K-101-0025	YOKOGAWA				
01-PSV-01502	RESTRICTION ORIFICE	NA	01-K-101-E01B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	0	100	%	05011-CPP-01-00-4V-DSH-01-K-101-0024	LESER				
	STANDBY OIL COOLER RELIEF VALVE				-									4592.2472					
01-FO-01518	MAIN OIL COOLER RELIEF VALVE	NA	01-K-101-E01B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	0	100	%	05011-CPP-01-00-4V-DSH-01-K-101-0025	YOKOGAWA				
01-TCV-01501	RESTRICTION ORIFICE	NA	01-K-101-E01B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	NA	NA	NA	23E033AL01L0Z1A0-SNNN	HUALICN				
	COOLER A/B EQUALIZER FLOW				-									HR140202					
01-TE-01542	TEMPERATURE SELF ACTUATED VALVE	4°-LO-01-101713-S15WN-N	01-K-101-PK01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	0	100	%	05011-CPP-01-00-4V-DSH-01-K-101-0025	MASONNEILAN				
01-TE-01542	LUBE OIL SUPPLY TEMPERATURE CONTROL VALVE	4°-LO-01-101714-S15WN-N	01-K-101-PK01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	-200	550	°C	05011-CPP-01-00-4V-DSH-01-K-101-0025	87-80385				
	TEMPERATURE ELEMENT-RTD				24VDC LOOP POWERED									YOKOGAWA					
01-TT-01542	LUBE OIL COOLER DOWNSTREAM TEMP	4°-LO-01-101714-S15WN-N	01-K-101-PK01	NA	4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	-30	200	°C	05011-CPP-01-00-4V-DSH-01-K-101-0025	YTA610				
01-TW-01542	TEMPERATURE TRANSMITTER	NA	NA	NA	24VDC LOOP POWERED	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0025	YOKOGAWA				
	LUBE OIL COOLER DOWNSTREAM TEMP				4-20 mA HART									YTA610					
01-FO-01519	THERMOWELL	NA	01-K-101-E01B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	NA	NA	NA	05011-CPP-01-00-4V-DSH-01-K-101-0025	ASHCROFT				
01-FO-01520	LUBE OIL SUPPLY TEMP	NA	01-K-101-F01A	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	NA	NA	NA	23E033AL01L0Z1A0-SNNN	THERMOWELL: 1/2" 150# RF X 1/2" NPT-F				
	RESTRICTION ORIFICE				-									HUALICN					
01-FO-01521	MAIN OIL FILTER SPILL OUT FLOW	NA	01-K-101-F01B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	NA	NA	NA	23E033AL01L0Z1A0-SNNN	HR140202				
	RESTRICTION ORIFICE				-									HUALICN					
01-FO-01521	LUBE OIL FILTER A/B EQUALIZER FLOW	NA	01-K-101-F01B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	NA	NA	NA	23E033AL01L0Z1A0-SNNN	HR140202				
	RESTRICTION ORIFICE				-									HUALICN					
01-PDT-01516	STANDBY OIL FILTER SPILL OUT FLOW	4°-LO-01-101717-S15WN-N	01-K-101-F01A/B	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	2.5	barg	05011-CPP-01-00-4V-DSH-01-K-101-0025	HR140202				
01-FO-01522	DIFFERENTIAL PRESSURE TRANSMITTER	NA	01-K-101-F01A/B	NA	24VDC LOOP POWERED	LGB	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	2.5	barg	05011-CPP-01-00-4V-DSH-01-K-101-0025	YOKOGAWA				
	LUBE OIL FILTER DIFF PRESS				4-20 mA HART									EJA110EJHS5JB1DEN/KF22/M01/PE3					
01-PT-01511	RESTRICTION ORIFICE	NA	01-K-101-PK01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	NA	NA	NA	23E033AL01L0Z1A0-SNNN	HUALICN				
01-PT-01511	LUBE OIL SUPPLY FLOW	4°-LO-01-101715-S15WN-N	01-K-101-PK01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	10	barg	05011-CPP-01-00-4V-DSH-01-K-101-0025	HR140202				
	PRESSURE TRANSMITTER				24VDC LOOP POWERED									YOKOGAWA					
01-PCV-01502	LUBE OIL SUPPLY PRESS	4°-LO-01-101717-S15WN-N	01-K-101-PK01	FO	4-20 mA HART	LGB	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	IEC ZONE 2, GROUP IIC, T3	Ex d	0	100	%	05011-CPP-01-00-4V-DSH-01-K-101-0025	EJA430EJAS5JB1DEN/KF22/M01/L4				
01-FO-01523	PRESSURE SELF ACTUATED VALVE	NA	01-K-101-PK01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	0	100	%	05011-CPP-01-00-4V-DSH-01-K-101-0025	MASONNEILAN				
01-PG-01525	LUBE OIL SUPPLY PCV	NA	01-K-101-PK01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	NA	NA	NA	23E033AL01L0Z1A0-SNNN	525				
	RESTRICTION ORIFICE				-									HUALICN					
01-FO-01525	LUBE OIL SUPPLY FLOW	4°-LO-01-101717-S15WN-N	01-K-101-PK01	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	0	6	barg	05011-CPP-01-00-4V-DSH-01-K-101-0025	HR140202				
	PRESSURE GAUGE				-									WIKA					
01-FO-01525	STANDBY OIL PUMP DISCHARGE PRESS	NA	01-K-101-D03	NA	NA	FIELD	05011-CPP-01-00-4V-PID-01-K-101-0007	YES	NA	NA	NA	NA	NA	233.30.100	TBD				
	RESTRICTION ORIFICE				-									TBD					
END OF THE DOCUMENT																			