

Dynamic System Modeling & PID Controller Design for a Molten Salt Microreactor

Sam J. Root

University of Idaho · Idaho Falls Center for Higher Education
Department of Nuclear Engineering and Industrial Management

December 6th, 2023



University of Idaho

Department of Nuclear Engineering
and Industrial Management

Experience

B.S Chemical Engineering (2015-2019) - Michigan Technological University
M.S. Nuclear Engineering (2021-2023) - University of Idaho - NRC Fellow
Modeling and Simulation Intern at Idaho National Lab

Select Publications

Root, S. J., et al., 2023. Thermodynamic analysis on xenon stripping to shorten restart time in molten salt microreactors.
Nuclear Engineering and Design 414, 112606

Root, S. J., et al., 2023. Cyber hardening of nuclear power plants with real-time nuclear reactor operation, 1. preliminary operational testing.
Progress in Nuclear Energy 162, 104742

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

1 The Molten Salt Nuclear Battery

2 Process Control Engineering

3 Reactor Characterization

4 Results and Analysis

5 Conclusions

1 The Molten Salt Nuclear Battery

2 Process Control Engineering

3 Reactor Characterization

4 Results and Analysis

5 Conclusions

Gen-IV

- Complete re-designs
- Smaller footprint
- Deployability
- Versatility

Molten Salt Reactors

Microreactors

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Gen-IV

Molten Salt Reactors

- High temperature
- Low pressure
- High specific heat

Microreactors

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Gen-IV

Molten Salt Reactors

Microreactors

- Less than 50 MW
- Assembly line manufacturing
- Deliver/installation vs. construction

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis


Conclusions

References

Fuel/Primary Coolant

- Self-Contained liquid fueled molten salt micro-reactor
- 10 year design
- 10 MWth using HALEU UF_4 dissolved in $FLiNaK$
- Natural circulation driven

Control Drums



Simplified schematic drawing of an MSNB

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis


Conclusions

References

Fuel/Primary Coolant

Control Drums

- Criticality is manipulated using axial control drums
- Neutron absorber plate covering cylinders of neutron reflector
- Drums are rotated to point more absorber towards the core to insert negative control reactivity



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Neutronics [3]

- Control drums give a uniform axial and radial flux profile for all reactivity insertions
- Control drum vs. reactivity curve is sinusoidal

Thermal Hydraulics [4]

Process Control

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

[3] Peterson, J., 8 2019. An analysis of the nuclear characteristics of a molten salt microreactor.
Master's thesis, University of Idaho

[4] Carter, J. P., 2022. Multi-physics investigation of a natural circulation molten salt micro-reactor that utilizes an experimental in-pile device to improve core physics and system thermal-hydraulic performance.
Ph.D. thesis, University of Idaho

Neutronics [3]

Thermal Hydraulics [4]

- Transient simulations can be reduced to 1D and still correspond to STAR-CCM+
- Stable autonomous load following for relatively small ramp function power demand transients

Process Control

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

[3] Peterson, J., 8 2019. An analysis of the nuclear characteristics of a molten salt microreactor. Master's thesis, University of Idaho

[4] Carter, J. P., 2022. Multi-physics investigation of a natural circulation molten salt micro-reactor that utilizes an experimental in-pile device to improve core physics and system thermal-hydraulic performance. Ph.D. thesis, University of Idaho

Neutronics [3]

Thermal Hydraulics [4]

Process Control

- Design controller *compliment* the autonomous capabilities provided by the passive feedback mechanisms
- Allow larger faster, more aggressive power changes
- Return MSNB to steady-state operation faster

[3] Peterson, J., 8 2019. An analysis of the nuclear characteristics of a molten salt microreactor. Master's thesis, University of Idaho

[4] Carter, J. P., 2022. Multi-physics investigation of a natural circulation molten salt micro-reactor that utilizes an experimental in-pile device to improve core physics and system thermal-hydraulic performance. Ph.D. thesis, University of Idaho

1 The Molten Salt Nuclear Battery

2 Process Control Engineering

- Control Theory
- Transport Delay Problem

3 Reactor Characterization

4 Results and Analysis

5 Conclusions

Control Theory

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

$$u(t) = \underbrace{K_P e(t)}_{\text{Proportional}} + \underbrace{K_I \int_0^t e(t) dt}_{\text{Integral}} + \underbrace{K_D \frac{de(t)}{dt}}_{\text{Derivative}}$$

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

$$u(t) = \underbrace{K_P e(t)}_{\text{Proportional}} + \underbrace{K_I \int_0^t e(t) dt}_{\text{Integral}} + \underbrace{K_D \frac{de(t)}{dt}}_{\text{Derivative}}$$

Proportional

- Control output is manipulated in proportion to the error defined by the proportional gain constant
- High gain yields an aggressive controller that is prone to overshooting the set-point
- Low gain may result in steady-state offset

Integral

Derivative

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

$$u(t) = \underbrace{K_P e(t)}_{\text{Proportional}} + \underbrace{K_I \int_0^t e(t) dt}_{\text{Integral}} + \underbrace{K_D \frac{de(t)}{dt}}_{\text{Derivative}}$$

Proportional

Integral

- Considers cumulative error to help eliminate steady-state offset
- As the process variable settles around the set-point, the cumulative error approaches a constant value and the effect of the integral controller diminishes.

Derivative

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

$$u(t) = \underbrace{K_P e(t)}_{\text{Proportional}} + \underbrace{K_I \int_0^t e(t) dt}_{\text{Integral}} + \underbrace{K_D \frac{de(t)}{dt}}_{\text{Derivative}}$$

Proportional

Integral

Derivative

- Estimates the time rate of change of the error to dampen overshoot
- Backs-off the proportional response when the process variable rapidly approaches the set-point
- Can be difficult to tune

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Transport Delay Problem

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References



Simplified block diagram of two primary passive feedback mechanisms in an MSNB

Doppler broadening

- Resonance peaks lower and broaden with increased temperature
- High kinetic energy of target nucleus introduces more relative uncertainty of the center-of-mass energy [5, Ch. 7]
- More epithermal neutrons absorbed by ^{238}U etc. [6, Ch. 6]

Thermal Expansion

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

[5] Kerlin, T. W. et al., 2019. Dynamics and Control of Nuclear Reactors.
Knoxville, Tennessee: Elsevier Inc

[6] Duderstadt, J. J. et al., 1976. Nuclear Reactor Analysis.
New York, NY: Wiley & Sons, first edition

Doppler broadening

Thermal Expansion

- Increased temperature leads to lower heavy metal density and smaller macroscopic fission cross-section at high temperature [3]
- Similar to moderator thinning in LWRs

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization


Results and
Analysis

Conclusions

References

Delayed Neutron Precursors

- Most fission events release daughter neutrons *promptly*
- Sometimes, unstable nuclides which decay by neutron emission are produced instead
- $t_{1/2}$ from less than a second to over a minute [7, Ch. 6]



Flowing Fuel

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Delayed Neutron Precursors

Flowing Fuel

- Precursors produced near the core exit and long lived precursors may emit their neutrons outside of the core
- These neutrons are effectively lost from the fission chain reaction [5, Ch. 3]
- Larger power transport requires a higher flow rate
- Greater delayed neutron losses
- Negative feedback

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Dynamics associated with anticipated transients

- Natural circulation flow mode
- Passive feedback mechanisms
- Transport delays separating heat exchanger and core

Thought Experiment

- Step increase in power demand to a steady-state critical MSNB
- Set-point is instantaneously equal to heat exchanger power consumption
- Ideal controller which produces rapid load following with minimal overshoot

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering


Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Main Operational Control Problem - Transport Delay



Simplified schematic drawing of a natural circulation MSNB

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization


Results and
Analysis

Conclusions

References

Main Operational Control Problem - Transport Delay

Immediate Response



Simplified schematic drawing of a natural circulation MSNB

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization


Results and
Analysis

Conclusions

References

Main Operational Control Problem - Transport Delay

Heat Exchanger Perturbation



Simplified schematic drawing of a natural circulation MSNB

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization


Results and
Analysis

Conclusions

References

Main Operational Control Problem - Transport Delay

Core Perturbation



Simplified schematic drawing of a natural circulation MSNB

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization


Results and
Analysis

Conclusions

References



Pre-Filter on a step-function



Pre-Filter on a ramp-function

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

1 The Molten Salt Nuclear Battery


2 Process Control Engineering

3 Reactor Characterization

- Neutronics Modeling
- Process Simulation

4 Results and Analysis

5 Conclusions



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Neutronics Modeling

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering



Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Geometry Specification



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering



Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Geometry Specification



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering



Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Geometry Specification



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering



Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Geometry Specification



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering



Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Geometry Specification



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering



Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Geometry Specification



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering



Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Geometry Specification



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Criticality

- Set Pop 1,000,000 500 100 1
- Conduct for all control drum angles
- Compare reactivity to angle to define actuator curve

Burn-Up

- Burn fuel salt to find composition after a certain amount of time - poisons, depletion of uranium
- Repeat criticality modeling to define actuator at a different point in time

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Process Simulation

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Natural Circulation (NC)

Updates flow rate by equating buoyant and frictional forces

$$v = \sqrt{2gh(\rho_{cold} - \rho_{hot})/\xi\rho}$$

Reactor Point Kinetics (RPK)

Uniform-State Uniform-Flow (USUF)

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Natural Circulation (NC)

Reactor Point Kinetics (RPK)

Updates core power by summing passive reactivity feedback

$$\rho_f = -\frac{L}{L+H} \beta_{eff} (1 - e^{-v\alpha_f})$$

$$\Delta\rho_T = \alpha_T \Delta T$$

$$\tau = \frac{l^*}{\rho} + \frac{\beta_{eff} - \rho}{\lambda\rho + \dot{\rho}}$$

$$Q_{core}[t + \delta t] = Q_{core}[t] e^{\delta t/\tau}$$

Uniform-State Uniform-Flow (USUF)

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Natural Circulation (NC)

Reactor Point Kinetics (RPK)

Uniform-State Uniform-Flow (USUF)

Updates temperature profile based on flow rate and core/heat-exchanger powers

$$\delta x A_x \frac{d\varrho}{dt} = v A_x (\varrho_{in} - \varrho_{out})$$

$$mu_x = \varrho \delta x A_x c_p (T_x - T_r)$$

$$\frac{d(mu)}{dt} = mu_{enter} - mu_{exit} + Q_{c.v.}$$

$$mu[t + \delta t] = mu[t] + \delta t \frac{d(mu)}{dt}[t]$$

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

1 The Molten Salt Nuclear Battery

2 Process Control Engineering

3 Reactor Characterization

4 Results and Analysis

- Control-Reactivity Curve
- Up-Step
- Down-Step
- Start-Up
- Shut-Down
- Demand-Response

5 Conclusions

Control-Reactivity Curve

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering


Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Control-Reactivity Curve



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering


Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Control-Reactivity Curve



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering


Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Control-Reactivity Curve



$$\rho = c_0 + c_1\theta + c_2\theta^2 + c_3\theta^3 + c_4\theta^4$$

Curve Fits

Years	$c_4 \times 10^9$	$c_3 \times 10^6$	$c_2 \times 10^4$	$c_1 \times 10^2$	c_0	root (°)	slope (pcm/°)
0.0	-2.797	1.789	-4.361	4.829	-2.009	111.41	224.24
0.5	-2.755	1.755	-4.272	4.732	-1.976	113.69	203.69
1.0	-1.838	1.253	-3.253	3.826	-1.682	115.79	189.71
1.5	-2.533	1.632	-3.253	4.507	-1.909	117.38	175.96
2.0	-2.418	1.578	-3.930	4.440	-1.895	119.45	161.06
2.5	-1.461	1.026	-2.750	3.337	-1.515	121.06	152.71
3.0	-1.137	0.856	-2.425	3.070	-1.440	122.67	146.08
3.5	-2.054	1.357	-3.433	3.953	-1.727	124.58	130.85
4.0	-2.527	1.617	-3.967	4.438	-1.892	126.46	120.67
4.5	-2.869	1.831	-4.460	4.935	-2.081	128.35	111.30
5.0	-2.338	1.520	-3.785	4.291	-1.855	130.55	102.04
5.5	-1.471	1.054	-2.852	3.467	-1.585	132.29	93.34
6.0	-2.626	1.702	-4.211	4.729	-2.027	134.96	83.90
6.5	-1.672	1.141	-2.985	3.550	-1.607	137.45	77.56
7.0	-3.321	2.095	-5.036	5.492	-2.292	139.19	69.73
7.5	-2.419	1.579	-3.936	4.459	-1.932	142.69	59.45
8.0	-7.991	0.648	-1.960	2.623	-1.305	144.62	55.65

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Up-Step

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering


Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Autonomous Response



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering


Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Autonomous Response



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering


Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Autonomous Response



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Ziegler Nichols Tuning Methodology

- P-Only Control
- Increase gain until sustained oscillations

Controller Parameters

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Ziegler Nichols Tuning Methodology

- P-Only Control
- Increase gain until sustained oscillations
- Ultimate gain - 3×10^{-4} degree/kW
- Ultimate period - 45 seconds

Controller Parameters

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Ziegler Nichols Tuning Methodology

Controller Parameters

- Controller gain - 1.35×10^{-4} degree/kW at 0 years
- Controller-Actuator gain - 30.3 pcm/MW
- Integral time-constant - 37.5 seconds
- Derivative time-constant - 0 sec
- Controller bias - 111.41° at zero years, 144.62° at eight years

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering


Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Controlled Response



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering


Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Controlled Response



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering


Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Controlled Response



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Down-Step

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering


Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Autonomous Response



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering


Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Controlled Response



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Start-Up

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering


Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Controlled Response



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering


Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Controlled Response



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Shut-Down

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering


Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Autonomous Response



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering


Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Controlled Response



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Demand-Response

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering


Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Autonomous Response



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering


Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Controlled Response



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

1 The Molten Salt Nuclear Battery

2 Process Control Engineering

3 Reactor Characterization

4 Results and Analysis

5 Conclusions

Summary of Models Completed

- Alternating criticality and burn-up models were developed in Serpent 2 to study the evolution of the control-reactivity curve over the life of the MSNB
- Mass and energy conservation were coupled to reactor point kinetics in a Python 3.10 code to predict the flow rate and power of the MSNB
- Time and spatial advancement routine simulates heat and mass advection according to uniform-state uniform-flow
- A pre-filter reshapes the heat exchanger demand
- A PI controller complements the passive feedback mechanisms inherent to the MSNB

Results In-Brief

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Summary of Models Completed

Results In-Brief

- The MSNB design studied in this work has an excess reactivity of 4.834% at hot-standby
- After 8 full-power years, the MSNB fuel is depleted enough to no longer provide enough excess reactivity for effective operation
- The autonomous response is stable, but significantly under-damped for 20% step functions and ramp functions of up to 400 kW/min
- The PI controller improves the settling time by an order of magnitude for step functions, and essentially eliminates overshoot for ramp functions
- With a robust controller, the MSNB is suitable for load-following

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

This work and my coursework is being completed under a Graduate Fellowship funded by Nuclear Regulatory Commission (NRC).

This research made use of the resources of the High Performance Computing Center at Idaho National Laboratory, which is supported by the Office of Nuclear Energy of the U.S. Department of Energy and the Nuclear Science User Facilities under Contract No. DE-AC07-05ID14517.

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References



University of Idaho
Department of Nuclear Engineering
and Industrial Management

1. Root, S. J., et al., 2023. Thermodynamic analysis on xenon stripping to shorten restart time in molten salt microreactors. *Nuclear Engineering and Design* 414, 112606.
2. Root, S. J., et al., 2023. Cyber hardening of nuclear power plants with real-time nuclear reactor operation, 1. preliminary operational testing. *Progress in Nuclear Energy* 162, 104742.
3. Peterson, J., 8 2019. An analysis of the nuclear characteristics of a molten salt microreactor. Master's thesis, University of Idaho.
4. Carter, J. P., 2022. Multi-physics investigation of a natural circulation molten salt micro-reactor that utilizes an experimental in-pile device to improve core physics and system thermal-hydraulic performance. Ph.D. thesis, University of Idaho.
5. Kerlin, T. W. et al., 2019. *Dynamics and Control of Nuclear Reactors*. Knoxville, Tennessee: Elsevier Inc.
6. Duderstadt, J. J. et al., 1976. *Nuclear Reactor Analysis*. New York, NY: Wiley & Sons, first edition.
7. Lamarsh, J. R. et al., 2001. *Introduction to Nuclear Engineering*. Upper Sadle River, New Jersey: Prentice Hall, third edition.

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References