

Dynamic System Modeling & PID Controller Design for a Molten Salt Microreactor

Sam J. Root

University of Idaho • Idaho Falls Center for Higher Education
Department of Nuclear Engineering and Industrial Management

December 6th, 2023



University of Idaho

Department of Nuclear Engineering
and Industrial Management

Experience

B.S Chemical Engineering (2015-2019) - Michigan Technological University
M.S. Nuclear Engineering (2021-2023) - University of Idaho - NRC Fellow
Modeling and Simulation Intern at Idaho National Lab

Select Publications

Root, S. J., et al., 2023. Thermodynamic analysis on xenon stripping to shorten restart time in molten salt microreactors.

Nuclear Engineering and Design 414, 112606

Root, S. J., et al., 2023. Cyber hardening of nuclear power plants with real-time nuclear reactor operation, 1. preliminary operational testing.

Progress in Nuclear Energy 162, 104742

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

- 1 The Molten Salt Nuclear Battery
- 2 Process Control Engineering
- 3 Reactor Characterization
- 4 Results and Analysis
- 5 Conclusions

1 The Molten Salt Nuclear Battery

- Introduction
- Xenon-135 Stripping In-Brief

2 Process Control Engineering

3 Reactor Characterization

4 Results and Analysis

5 Conclusions

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Introduction

Gen-IV

blah

Molten Salt Reactors

Microreactors

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Gen-IV

Molten Salt Reactors

blah

Microreactors

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Gen-IV

Molten Salt Reactors

Microreactors

blah

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Xenon-135 Stripping In-Brief

$$\sigma_a^{135}\text{Xe} = 430\text{kb}$$

$$\sigma_a^{135}\text{I} = 260\text{mb}$$

$$\sigma_f^{235}\text{U} = 180\text{b}$$

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References



MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis


Conclusions

References




$$\frac{dI}{dt} = \underbrace{\gamma_I \Sigma_f^F \phi(t)}_{\text{Fission Yield}} - \underbrace{\lambda_I I(t)}_{\text{Beta Decay}}$$

$$\frac{dXe}{dt} = \underbrace{\lambda_I I(t)}_{\text{Precursor Decay}} + \underbrace{\gamma_{Xe} \Sigma_f^F \phi(t)}_{\text{Fission Yield}} - \underbrace{\lambda_{Xe} Xe(t)}_{\text{Beta Decay}} - \underbrace{Xe(t) \sigma_a^{Xe} \phi(t)}_{\text{Radiative Capture}}$$



Concentration of ^{135}I and ^{135}Xe vs. time following start-up



Concentration of ^{135}I and ^{135}Xe vs. time following reactor scram

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization


Results and
Analysis

Conclusions

References




Schematic Drawing of Xenon Stripping Module




Schematic Drawing of Xenon Stripping Module

$$\frac{dXe}{dt} = \underbrace{\gamma_{Xe} \Sigma_f^F \phi(t)}_{\text{Fission Yield}} + \underbrace{\lambda_I I(t)}_{\text{Precursor Decay}} - \underbrace{\lambda_{Xe} Xe(t)}_{\text{Beta Decay}} - \underbrace{Xe(t) \sigma_a^{Xe} \phi(t)}_{\text{Radiative Capture}} - \underbrace{\frac{Xe(t)}{\tau_{salt}} \left(H^* \frac{\dot{V}_{salt}}{\dot{V}_{He}} + 1 \right)^{-1}}_{\text{Stripping}}$$



of ^{135}I and ^{135}Xe vs. time following reactor scram - Restart Mode



Concentration of ^{135}I and ^{135}Xe vs. time following reactor scram - Standby Mode

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

1 The Molten Salt Nuclear Battery

2 Process Control Engineering

- Control Theory
- Transport Delay Problem

3 Reactor Characterization

4 Results and Analysis

5 Conclusions

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Control Theory

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering


Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Transport Delay Problem



Simplified block diagram of two primary passive feedback mechanisms in an MSNB

- Doppler broadening of resonance peaks results in more epithermal neutrons absorbed by ^{238}U etc. [3, Ch. 6]
- Molten salt fuels have high thermal expansion coefficient [4]
- Increased temperature leads to lower heavy metal density and smaller macroscopic fission cross-section at high temperature
- Similar to moderator thinning in LWRs
- These two effects combine to result in less power production at higher temperature

[3] Duderstadt, J. J. et al., 1976. Nuclear Reactor Analysis.
New York, NY: Wiley & Sons, first edition

[4] Peterson, J., 8 2019. An analysis of the nuclear characteristics of a molten salt microreactor.
Master's thesis, University of Idaho

- Driven by advection of delayed neutron precursors [5, Ch. 3]
 - Most fission events release daughter neutrons *promptly*
 - Sometimes, unstable nuclides which decay by neutron emission are produced instead
 - $t_{1/2}$ from less than a second to over a minute [6, Ch. 6]
- Precursors produced near the core exit and long lived precursors may emit their neutrons outside of the core, so they are effectively *lost* from the fission chain reaction
- In natural circulation, larger power transport requires a higher flow rate, and greater delayed neutron losses

[5] Kerlin, T. W. et al., 2019. Dynamics and Control of Nuclear Reactors. Knoxville, Tennessee: Elsevier Inc

[6] Lamarsh, J. R. et al., 2001. Introduction to Nuclear Engineering. Upper Saddle River, New Jersey: Prentice Hall, third edition

- Start design process by discussing dynamics associated with anticipated transients
 - Natural circulation flow mode
 - Passive feedback mechanisms
 - Transport delays separating heat exchanger and core
- Thought Experiment
 - Step increase in power demand to a steady-state critical MSNB
 - Set-point is instantaneously equal to heat exchanger power consumption
 - Ideal controller which produces rapid load following with minimal overshoot

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions


References



Simplified schematic drawing of a natural circulation MSNB

Main Operational Control Problem - Transport Delay

Immediate Response



Simplified schematic drawing of a natural circulation MSNB

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization


Results and
Analysis

Conclusions

References

Main Operational Control Problem - Transport Delay

Heat Exchanger Perturbation



Simplified schematic drawing of a natural circulation MSNB

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization


Results and
Analysis

Conclusions

References

Main Operational Control Problem - Transport Delay

Core Perturbation



Simplified schematic drawing of a natural circulation MSNB

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery


Process
Control
Engineering

Reactor Char-
acterization


Results and
Analysis

Conclusions

References



Pre-Filter on a step-function



Pre-Filter on a ramp-function

1 The Molten Salt Nuclear Battery

2 Process Control Engineering

3 Reactor Characterization

- Neutronics Modeling
- Process Simulation

4 Results and Analysis

5 Conclusions

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Neutronics Modeling

Process Simulation

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

1 The Molten Salt Nuclear Battery

2 Process Control Engineering

3 Reactor Characterization

4 Results and Analysis

- Control-Reactivity Curve
- Controller Tuning
- Demand Response

5 Conclusions

Control-Reactivity Curve

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Controller Tuning

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Demand Response

- 1 The Molten Salt Nuclear Battery
- 2 Process Control Engineering
- 3 Reactor Characterization
- 4 Results and Analysis
- 5 Conclusions**

This work and my coursework is being completed under a Graduate Fellowship funded by Nuclear Regulatory Commission (NRC).

This research made use of the resources of the High Performance Computing Center at Idaho National Laboratory, which is supported by the Office of Nuclear Energy of the U.S. Department of Energy and the Nuclear Science User Facilities under Contract No. DE-AC07-05ID14517.



University of Idaho

Department of Nuclear Engineering
and Industrial Management

1. Root, S. J., et al., 2023. Thermodynamic analysis on xenon stripping to shorten restart time in molten salt microreactors. Nuclear Engineering and Design 414, 112606.
2. Root, S. J., et al., 2023. Cyber hardening of nuclear power plants with real-time nuclear reactor operation, 1. preliminary operational testing. Progress in Nuclear Energy 162, 104742.
3. Duderstadt, J. J. et al., 1976. Nuclear Reactor Analysis. New York, NY: Wiley & Sons, first edition.
4. Peterson, J., 8 2019. An analysis of the nuclear characteristics of a molten salt microreactor. Master's thesis, University of Idaho.
5. Kerlin, T. W. et al., 2019. Dynamics and Control of Nuclear Reactors. Knoxville, Tennessee: Elsevier Inc.
6. Lamarsh, J. R. et al., 2001. Introduction to Nuclear Engineering. Upper Sadle River, New Jersey: Prentice Hall, third edition.
7. Carter, J. P., 2022. Multi-physics investigation of a natural circulation molten salt micro-reactor that utilizes an experimental in-pile device to improve core physics and system thermal-hydraulic performance. Ph.D. thesis, University of Idaho.
8. Bequette, B. W., 2003. Process Control: Modeling Design and Simulation. Upper Sadle River, New Jersey: Prentice Hall.

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

9. Gahinet, P. M. et al., 2013. Automated tuning of gain-scheduled control systems. IEEE Conference on Decision and Control .
10. Al Rashdan, A. et al., 2019. A frequency domain control perspective on xenon resistance for load following of thermal nuclear reactors. IEEE Transactions on Nuclear Science 66(9), 2034.
11. Wang, S., et al., 2019. A passive decay heat removal system for emergency draining tanks of MSRs. Nuclear Engineering and Design 341, 423.

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering


Reactor Char-
acterization

Results and
Analysis

Conclusions


References

- Self-Contained liquid fueled molten salt micro-reactor - 10 year design
- 1 MW design using HALEU UF_4 dissolved in $FLiNaK$
- Criticality is manipulated using axial control drums
 - Neutron absorber plate covering cylinders of neutron reflector
 - Drums are rotated to point more absorber towards the core to insert negative control reactivity



Simplified schematic drawing of an MSNB

- Self-Contained liquid fueled molten salt micro-reactor - 10 year design
- 1 MW design using HALEU UF_4 dissolved in $FLiNaK$
- Criticality is manipulated using axial control drums
 - Neutron absorber plate covering cylinders of neutron reflector
 - Drums are rotated to point more absorber towards the core to insert negative control reactivity



Simplified schematic drawing of an MSNB

- Self-Contained liquid fueled molten salt micro-reactor - 10 year design
- 1 MW design using HALEU UF_4 dissolved in $FLiNaK$
- Criticality is manipulated using axial control drums
 - Neutron absorber plate covering cylinders of neutron reflector
 - Drums are rotated to point more absorber towards the core to

Neutronics [4]

- Control drums give a uniform axial and radial flux profile for all reactivity insertions
- Fission product poisoning is the biggest challenge to reach the desired 10-year lifespan
- Control drum vs. reactivity curve is sinusoidal

Thermal Hydraulics [7]

Process Control

[4] Peterson, J., 8 2019. An analysis of the nuclear characteristics of a molten salt microreactor. Master's thesis, University of Idaho

[7] Carter, J. P., 2022. Multi-physics investigation of a natural circulation molten salt micro-reactor that utilizes an experimental in-pile device to improve core physics and system thermal-hydraulic performance. Ph.D. thesis, University of Idaho

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Neutronics [4]

Thermal Hydraulics [7]

- The counteracting passive feedback effects of temperature reactivity and flow reactivity produce stable autonomous load following for relatively small ramp function power demand transients
- An in-core helix device can be used to manipulate temperature and power profiles in the core, as well as minimize advective loss of delayed-neutron precursors

Process Control

[4] Peterson, J., 8 2019. An analysis of the nuclear characteristics of a molten salt microreactor. Master's thesis, University of Idaho

[7] Carter, J. P., 2022. Multi-physics investigation of a natural circulation molten salt micro-reactor that utilizes an experimental in-pile device to improve core physics and system thermal-hydraulic performance. Ph.D. thesis, University of Idaho

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Neutronics [4]


Thermal Hydraulics [7]

Process Control


- Design controller *compliment* the autonomous capabilities provided by the passive feedback mechanisms
- Allow larger faster, more aggressive power changes
- Additional focus on time periods with a high degree of time variance (start-up, shut-down, re-start)

[4] Peterson, J., 8 2019. An analysis of the nuclear characteristics of a molten salt microreactor. Master's thesis, University of Idaho

[7] Carter, J. P., 2022. Multi-physics investigation of a natural circulation molten salt micro-reactor that utilizes an experimental in-pile device to improve core physics and system thermal-hydraulic performance. Ph.D. thesis, University of Idaho



Pre-Filter on a step-function



Pre-Filter on a ramp-function

- Minor perturbations will cause power fluctuations
- Fine grain and constant control actuation would burn out servos prematurely
- When the error is small, allow the passive feedback mechanisms to fine tune

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

- Disturbances, particularly temperature reactivity, are extremely high frequency - On order of mean neutron lifetime [6, Ch. 7]
- Control actuation is similarly quick
- Time delays on the order of dozens of seconds to minutes
- Inserting control reactivity to counteract temperature reactivity at the exact right moment would be difficult or impossible, so it is unlikely that a disturbance feedforward controller could reject the disturbance before it causes error [8, Ch. 10]
- Disturbance rejection best left to feedback PID controller

[6] Lamarsh, J. R. et al., 2001. Introduction to Nuclear Engineering. Upper Saddle River, New Jersey: Prentice Hall, third edition

[8] Bequette, B. W., 2003. Process Control: Modeling Design and Simulation. Upper Saddle River, New Jersey: Prentice Hall

- Sinusoidal control drum angle vs. reactivity curve - non-linear reactivity actuation - Taylor Series approximation to linearize around the operating point [8, Ch. 2]
- Fissile depletion changes the amount of control reactivity required to make the core critical - time-variant controller bias - Bias and gain schedule [9]
- Control drums manipulate *criticality*, not power directly - highly time-dependent control actuation

[9] Gahinet, P. M. et al., 2013. Automated tuning of gain-scheduled control systems. IEEE Conference on Decision and Control

[8] Bequette, B. W., 2003. Process Control: Modeling Design and Simulation. Upper Saddle River, New Jersey: Prentice Hall

- Equilibrium Poisoning
 - Poisons like ^{135}Xe and ^{149}Sm build-up after the reactor starts - this causes a negative reactivity insertion
 - Reach equilibrium over the first ~ 100 hours
 - Gain/Bias schedule may be used
 - Alternatively, a burnable poison with appropriate *effective* half-life could be selected - ^{157}Gd shows promise to counteract ^{135}Xe build-up
- Restart Poisoning
 - ^{135}Xe levels increase following shut-down because its beta-precursor (^{135}I) decays faster
 - Requires a lot of excess control reactivity and very good control to counteract the positive reactivity insertion of poison burn-out after restart
 - Low-flux burn-out instead of full shut-down
 - Stripping ^{135}Xe and other fission gasses before re-start

- Use KCODE to develop control drum vs. reactivity curve at various points in the core lifespan
- Use Burn-up routine to study how the core criticality at different conditions effects the control drum vs. reactivity
 - Cold/clean start-up
 - Burnable poison start-up
 - Equilibrium poisoning
 - Long-term depletion of fissile isotopes
- Develop bias/unity point schedule
- Will to use HPC or Falcon

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

- 1D+time finite element model that accounts for passive feedback mechanisms during unsteady state subcritical, critical, and supercritical modes to calculate the core power and flow loop temperature profile over time
- Simulate system response to:
 - Control actuation
 - Heat exchanger transients
- Empirical fitting of reactor transfer function
- Studies can be conducted locally or with cluster resources

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

- Model control loop in Simulink
- Investigate system stability using frequency response tests
- Use built-in numerical methods to implement a PID controller tuning method
- Repeat for different core conditions to develop gain-schedule and/or look-up table for the controller parameters

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

- Implement control drum reactivity, pre-filter, and PID controller into the process simulation
- Test autonomous response to heat exchanger power demand transients
- Repeat with controller active
- Quantitatively compare response using settling time, dampening ratio, peak overshoot ratio etc.

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis

Conclusions

References

Table: Timeframe for Execution of Project

Tasks	Oct.	Nov.	Dec.	Jan.	Feb.	Mar.	Apr.
Control Drums	X	X	X				
Process Simulation		X	X	X			
Controller Tuning				X	X		
Implementation					X	X	
Cross-Cutting						X	X
Defend							X

MSNB
Modeling &
Control

Sam J. Root

The Molten
Salt Nuclear
Battery

Process
Control
Engineering

Reactor Char-
acterization

Results and
Analysis


Conclusions

References

- Poison perturbations following power transients [10]
- Melting of *in-situ* frozen salt
- SCRAM system must be passive
- Decay heat system [11]
- Flow rate control

[10] Al Rashdan, A. et al., 2019. A frequency domain control perspective on xenon resistance for load following of thermal nuclear reactors. IEEE Transactions on Nuclear Science 66(9), 2034

[11] Wang, S., et al., 2019. A passive decay heat removal system for emergency draining tanks of MSRs. Nuclear Engineering and Design 341, 423



Simplified control loop of a natural circulation MSNB