batmonitor: observed states, last 4 days (wagodb.pv_victron, one row per minute = the state of the last 5 s cycle; generated 2026-11-04 18:54)

coverage 01.11. 00:00 .. 04.11. 18:54: 5455 of 5455 minutes with a state (100.00 %)			
day	**minutes**	**D1 cells**	**rule states**
Sun 01.11.	1440	8	24
Mon 02.11.	1440	12	30
Tue 03.11.	1440	6	26
Wed 04.11.	1135	8	26
gaps (minutes without a row)			
none			

D1 cells (pv_victron.bm_d1_id) through the D1 tables of bm_tables.h					
cell	**bits**	**minutes**	**set bits**	**src**	**wp_cap**
95	1+2+4+8+16+64	1522	night, wp_on, b1_above_min, b1_ge_release, winter, bat1_first	B1	WP_WINTER_W
92	4+8+16+64	1150	b1_above_min, b1_ge_release, winter, bat1_first	DAY	none
93	1+4+8+16+64	974	night, b1_above_min, b1_ge_release, winter, bat1_first	STK	none
94	2+4+8+16+64	855	wp_on, b1_above_min, b1_ge_release, winter, bat1_first	DAY	WP_WINTER_W
87	1+2+4+16+64	362	night, wp_on, b1_above_min, winter, bat1_first	B1	WP_WINTER_W
85	1+4+16+64	232	night, b1_above_min, winter, bat1_first	STK	none
127	1+2+4+8+16+32+64	141	night, wp_on, b1_above_min, b1_ge_release, winter, b1_dis, bat1_first	B1	0 W
126	2+4+8+16+32+64	124	wp_on, b1_above_min, b1_ge_release, winter, b1_dis, bat1_first	DAY	0 W
124	4+8+16+32+64	45	b1_above_min, b1_ge_release, winter, b1_dis, bat1_first	DAY	none
84	4+16+64	44	b1_above_min, winter, bat1_first	DAY	none
86	2+4+16+64	4	wp_on, b1_above_min, winter, bat1_first	DAY	WP_WINTER_W
125	1+4+8+16+32+64	2	night, b1_above_min, b1_ge_release, winter, b1_dis, bat1_first	STK	none

rule states L1 | L2 | L3 (measured values in brackets removed), 53 different		
minutes	**%**	**L1 | L2 | L3**
1351	24.8	PROP SRC:B1 EQ WPMAX(100) | PROP SRC:B1 EQ WPMAX(100) | PROP SRC:B1 EQ WPMAX(100)
1113	20.4	PROP SRC:STK EQ | PROP SRC:STK EQ | PROP SRC:STK EQ
428	7.8	CHARGE SRC:DAY EQ | CHARGE SRC:DAY EQ | CHARGE SRC:DAY EQ
357	6.5	CHARGE SRC:DAY BAL | CHARGE SRC:DAY BAL | CHARGE SRC:DAY BAL
285	5.2	PROP SRC:DAY EQ WPMAX(100) | PROP SRC:DAY EQ WPMAX(100) | PROP SRC:DAY EQ WPMAX(100)
275	5.0	PROP SRC:B1 BAL WPMAX(100) | PROP SRC:B1 WAIT WPMAX(100) | PROP SRC:B1 WAIT WPMAX(100)
246	4.5	PROP SRC:B1 WAIT WPMAX(100) | PROP SRC:B1 BAL WPMAX(100) | PROP SRC:B1 BAL WPMAX(100)
242	4.4	PROP SRC:DAY EQ | PROP SRC:DAY EQ | PROP SRC:DAY EQ
236	4.3	CHARGE SRC:DAY EQ TOP CELL | FULL | FULL
161	3.0	PROP SRC:DAY BAL WPMAX(100) | PROP SRC:DAY WAIT WPMAX(100) | PROP SRC:DAY WAIT WPMAX(100)
137	2.5	PROP SRC:B1 EQ WPMAX(0) | PROP SRC:B1 EQ WPMAX(0) | PROP SRC:B1 EQ WPMAX(0)
126	2.3	CHARGE SRC:DAY EQ TOP | FULL | FULL
88	1.6	IDLE SRC:DAY EQ WPMAX(0) | IDLE SRC:DAY EQ WPMAX(0) | IDLE SRC:DAY EQ WPMAX(0)
78	1.4	IDLE SRC:DAY EQ | IDLE SRC:DAY EQ | IDLE SRC:DAY EQ
71	1.3	PROP SRC:STK WAIT | PROP SRC:STK BAL | PROP SRC:STK BAL
39	0.7	PROP SRC:DAY BAL | PROP SRC:DAY WAIT | PROP SRC:DAY WAIT
25	0.5	CHARGE SRC:DAY BAL TOP CELL | FULL | FULL
24	0.4	PROP SRC:DAY EQ WPMAX(0) | PROP SRC:DAY EQ WPMAX(0) | PROP SRC:DAY EQ WPMAX(0)
21	0.4	CHARGE SRC:DAY EQ CELL | FULL | FULL
19	0.3	PROP SRC:STK BAL | PROP SRC:STK WAIT | PROP SRC:STK WAIT
16	0.3	CHARGING | PROP SRC:DAY EQ WPMAX(100) | PROP SRC:DAY EQ WPMAX(100)
12	0.2	CHARGE SRC:DAY EQ | FULL | FULL
11	0.2	IDLE SRC:DAY EQ WPMAX(100) | IDLE SRC:DAY EQ WPMAX(100) | IDLE SRC:DAY EQ WPMAX(100)
10	0.2	CHARGE SRC:DAY EQ CCL | CHARGE SRC:DAY EQ | CHARGE SRC:DAY EQ
9	0.2	IDLE SRC:DAY WAIT WPMAX(100) | IDLE SRC:DAY BAL WPMAX(100) | IDLE SRC:DAY BAL WPMAX(100)
7	0.1	CHARGING | PROP SRC:B1 EQ WPMAX(100) | PROP SRC:B1 EQ WPMAX(100)
7	0.1	CHARGE SRC:DAY BAL CCL | FULL | FULL
5	0.1	PROP SRC:B1 EQ WPMAX(100) | CHARGING | CHARGING
5	0.1	IDLE SRC:DAY BAL WPMAX(100) | IDLE SRC:DAY WAIT WPMAX(100) | IDLE SRC:DAY WAIT WPMAX(100)
4	0.1	IDLE SRC:DAY BAL | CHARGING | CHARGING
4	0.1	CHARGING | IDLE SRC:DAY EQ | IDLE SRC:DAY EQ
4	0.1	PROP SRC:DAY WAIT WPMAX(100) | PROP SRC:DAY BAL WPMAX(100) | PROP SRC:DAY BAL WPMAX(100)
4	0.1	CHARGE SRC:DAY EQ CCL | CHARGE SRC:DAY EQ CCL | CHARGE SRC:DAY EQ CCL
3	0.1	PROP SRC:DAY BAL | CHARGING | CHARGING
3	0.1	CHARGE SRC:DAY BAL TOP CCL | FULL | FULL
3	0.1	CHARGE SRC:DAY EQ TOP CCL | FULL | FULL
3	0.1	CHARGE SRC:DAY EQ TOP CCL | CHARGE SRC:DAY EQ CCL | CHARGE SRC:DAY EQ CCL
2	0.0	IDLE SRC:STK EQ | IDLE SRC:STK EQ | IDLE SRC:STK EQ
2	0.0	CHARGING | PROP SRC:DAY EQ | PROP SRC:DAY EQ
2	0.0	CHARGE SRC:DAY BAL CCL | CHARGE SRC:DAY BAL | CHARGE SRC:DAY BAL
2	0.0	IDLE SRC:B1 EQ WPMAX(0) | IDLE SRC:B1 EQ WPMAX(0) | IDLE SRC:B1 EQ WPMAX(0)
2	0.0	IDLE SRC:STK WAIT | IDLE SRC:STK BAL | IDLE SRC:STK BAL
2	0.0	IDLE SRC:DAY BAL | IDLE SRC:DAY WAIT | IDLE SRC:DAY WAIT
2	0.0	PROP SRC:B1 WAIT WPMAX(0) | PROP SRC:B1 BAL WPMAX(0) | PROP SRC:B1 BAL WPMAX(0)
1	0.0	PROP SRC:DAY BAL WPMAX(100) | CHARGING | CHARGING
1	0.0	CHARGE SRC:STK EQ | CHARGE SRC:STK EQ | CHARGE SRC:STK EQ
1	0.0	IDLE SRC:DAY EQ WPMAX(0) | CHARGING | CHARGING
1	0.0	CHARGING | PROP SRC:DAY EQ WPMAX(0) | PROP SRC:DAY EQ WPMAX(0)
1	0.0	PROP SRC:DAY EQ WPMAX(100) | CHARGING | CHARGING
1	0.0	IDLE SRC:DAY WAIT WPMAX(0) | IDLE SRC:DAY BAL WPMAX(0) | IDLE SRC:DAY BAL WPMAX(0)
1	0.0	CHARGING | CHARGING | CHARGING
1	0.0	IDLE SRC:DAY EQ | CHARGING | CHARGING
1	0.0	PROP SRC:DAY EQ | CHARGING | CHARGING