Sample certificate. Illustrates the Certificate of Service Cleaning Pros Plus, LLC issues; numbers and dates are illustrative.

(209) 636-6116 · firesafety@cprosplus.com · https://www.cleaningprosplus.com

CERTIFICATE OF SERVICE

NFPA 96 (2024) — Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations

This certifies that the kitchen exhaust system at the premises identified below has been professionally observed and cleaned in accordance with the standards and codes set forth in this certificate.

CERTIFICATE NO. **CERT-K-SAMPLE** | **Report No. RPT-K-SAMPLE · Job No. CPP-K-SAMPLE**

SERVICE RECORD

SERVICE COMPANY	Cleaning Pros Plus, LLC
CLIENT SERVICED	Sample Kitchen
ADDRESS	Fictional kitchen, California
SERVICES PERFORMED	KEC
SERVICE SCHEDULE	Quarterly
SERVICE DATE	06/12/2026
NEXT SERVICE DUE	September 2026
SEE REPORT	**RPT-K-SAMPLE**
LEAD TECHNICIAN	Sample Technician

STANDARDS & CODES

NFPA 96 (2024) — Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations (§4.1.5).

> **ANSI/IKECA C10** — Methodology for Cleaning of Commercial Kitchen Exhaust Systems.

> **California Fire Code** — California Fire Code — Ch. 6, §609 (Commercial Kitchen Hoods), and all applicable state and local fire codes (e.g., IFC §609 where adopted).

PROTECTIVE SAFEGUARDS ENDORSEMENT (ISO CP 04 11)

P-5 **Automatic Commercial Cooking Exhaust and Extinguishing System** — hood, grease-removal device, duct system, and wet-chemical extinguishing equipment.

P-9 The protective system described in the Schedule.

Listed safeguards must be maintained in complete working order and any suspension or impairment reported to the insurer. **Failure to do so may result in denial of coverage for loss or damage caused by or resulting from fire.**

IKECA MEMBER COMPANY
Certification #76716495
Expiration 03/01/2027

Arthur L. Haggerty, Jr

Arthur L Haggerty, Jr
Founder & CEO · CESI #200771 · CECS #200452
06/13/2026

This certificate verifies the cleaning and observation services described above. Ongoing compliance with fire codes and insurance requirements remains the responsibility of the property owner or operator per NFPA 96 §4.1.5. rev 10/11/2026

Sample certificate — no record to verify.

SAMPLE