Distribution Post Construction Inspection Checklist - Overhead

Reviewer:		**Job Location:**	
WR:		**WO:**	
Date:		**Crew:**	

Was Overhead Construction Properly Performed?

1. **Was the job built to the approved design and specifications? (Were the correct materials used? Were Distribution Standards referenced? If necessary, were Sag and Tension Charts included with design in work packet?)**

2. **Was work packet properly redlined ? (Any changes from as-built vs. designed must be redlined)**

3. **Did Crew communicate with the designer/engineer about changes? (Necessary analyses were rerun and changes ok'd by designer/engineer)**

4. **Is pole set to required depth and properly tagged (pole tags removed from old stub)?**

5. **Are transformers and equipment properly installed and properly grounded?**

6. **Was Animal Mitigation issued and installed (if required)?**

7. **Were switches installed in a position practical for safe operation?**

8. **Were anchors set properly? (were they staked first? Distance on print, in-line, bisecting angle, set to adequate depth)?**

9. **Were guy wires properly installed? (Preforms wrapped thoroughly, FBG breakers installed, Guy Marker installed, secured to the anchor head & adequate down lead distance, correct guy size)**

Did the crew leave the work area in a satisfactory condition?

1. **Picked up all debris (old pole pieces, hardware, company trash etc.)**

2. **Is excess dirt piled neatly at the butt of the pole?**

3. **Any property damages? (to structures or fences, were ruts left?)**

☐ **Inspection Pass** ☐ **Inspection Fail**

NOTE: Inspection must be recorded in DWMS and completed checklist added to work packet

Rework Inspection

Rework Inspection Date: **Rework Completed On:**

☐ **Inspection Pass** ☐ **Inspection Fail**

Management Review (Quality Control)

Signature: **Completed Date:**

Management Review Comments: