

ACOUSTIC TEST REPORT

Report No.: ATR-NK-2026-022
Test specimen: Nordkern Thermal Wall Panel NK-TWP 120
Test date: 12 August 2026

1. Test objective

To determine the airborne sound insulation performance of a representative wall-panel specimen under laboratory test conditions.

2. Test specimen

Panel thickness: 120 mm
Specimen area: 10.0 m²
Core: Mineral wool
Mounting: Standard laboratory test frame

3. Test results

Frequency (Hz)	R (dB)
100	31
125	34
160	37
200	40
250	43
315	46
400	49
500	51
630	53
800	55
1000	56
1250	57
1600	58
2000	59
2500	60
3150	61

4. Single-number rating

Weighted sound reduction index R_w : 54 dB
Spectrum adaptation terms: C = -2 dB; Ctr = -5 dB.

5. Test conditions

Laboratory temperature: 21 °C
Relative humidity: 48 %
Test environment: Reverberation test facility

Measurement equipment: Class 1 acoustic instrumentation

6. Conclusion

The tested specimen achieved a fictional weighted sound reduction index of R_w 54 dB under the stated laboratory conditions.

IMPORTANT: This is a fictional test report created for software development, document upload, OCR, and data-extraction testing. It is not an accredited laboratory report and must not be used as evidence of actual product performance.

Prepared by: Nordkern Acoustic Testing Department

Issue date: 19 August 2026

Revision: A