

Plant name : SP Imming ; Device name : WR12 ; Country/region : Germany medium voltage ; Device S/N : A2332101970

Current version :

Module name	Current module version
SDSP	DIOPSIDE-S_04011.01.05
MDSP	DIOPSIDE-S_03011.01.07
CPLD	DIOPSIDE-S_08011.01.01
LCD	DIOPSIDE-S_01011.01.06

Settings :

Parameter name	Parameter value
Startup/shutdown	Start up
Total yield correction	0(kWh)
Standby time	60(s)
Recovery time from fault	600(s)
Transparent transmission via backup RS485 port	Enable
Protection level	Level 2
Undervoltage level 1 protection threshold	631.2(V)
Overvoltage level 1 protection threshold	1008(V)
Underfrequency level 1 protection threshold	47.5(Hz)
Overfrequency level 1 protection threshold	51.5(Hz)
Undervoltage level 2 protection threshold	351.2(V)
Overvoltage level 2 protection threshold	1008(V)
Underfrequency level 2 protection threshold	47.5(Hz)
Overfrequency level 2 protection threshold	52.5(Hz)
Undervoltage level 3 protection threshold	--(V)
Overvoltage level 3 protection threshold	--(V)
Underfrequency level 3 protection threshold	--(Hz)
Overfrequency level 3 protection threshold	--(Hz)
Undervoltage level 4 protection threshold	--(V)
Overvoltage level 4 protection threshold	--(V)
Underfrequency level 4 protection threshold	--(Hz)
Overfrequency level 4 protection threshold	--(Hz)
Undervoltage level 5 protection threshold	--(V)
Overvoltage level 5 protection threshold	--(V)
Underfrequency level 5 protection threshold	--(Hz)
Overfrequency level 5 protection threshold	--(Hz)
Undervoltage level 1 protection delay	0.6(s)
Overvoltage level 1 protection delay	0.5(s)
Underfrequency level 1 protection delay	0.4(s)
Overfrequency level 1 protection delay	5.4(s)
Undervoltage level 2 protection delay	0.4(s)
Overvoltage level 2 protection delay	0.5(s)
Underfrequency level 2 protection delay	0.4(s)
Overfrequency level 2 protection delay	0.4(s)
Undervoltage level 3 protection delay	--(s)
Overvoltage level 3 protection delay	--(s)
Underfrequency level 3 protection delay	--(s)
Overfrequency level 3 protection delay	--(s)
Undervoltage level 4 protection delay	--(s)
Overvoltage level 4 protection delay	--(s)
Underfrequency level 4 protection delay	--(s)
Overfrequency level 4 protection delay	--(s)
Undervoltage level 5 protection delay	--(s)
Overvoltage level 5 protection delay	--(s)
Underfrequency level 5 protection delay	--(s)
Overfrequency level 5 protection delay	--(s)
Overvoltage protection recovery threshold	880(V)

Undervoltage protection recovery threshold	719.2(V)
Overfrequency protection recovery threshold	50.1(Hz)
Underfrequency protection recovery threshold	49.9(Hz)