



UTILITY DIVERSIONS LAYOUT



11 KV CABLE AND TELECOM DUCTS



NOTES

- 1. Northgrid 11 kV cable diversion at Ch 2+300, in twin 150 mm ducts at 1.0 m minimum cover.
- 2. OpenLine Telecom duct diversion between Ch 3+000 and Ch 3+200.
- 3. Existing telecom duct depths from utility records; to be confirmed on site.

Rev	Date	Description
C01	20/03/2025	Issued for construction
Client: Northvale County Council Designer: Arden Moss Consulting Engineers Kestrel Valley Link Road Utility Diversions Layout - Electricity and Telecom Drawing number: KVL-ADM-600-DR-U-0601 Revision: C01 Status: FC - For construction Scale: 1:500 @ A1 Date: 20 March 2025 Drawn: LC Checked: DO Approved: PN		